

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP: WTP-A
System Name: Yamhill, City of
ID#: OR4100968
Month/Year: Aug-25
Disinfection Giardia Log Inactive: 0.500

Date / Time	Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/19:00	0.9	80.00	69.5	16.7	8.02	17.5	YES	396
2/11:00	0.9	80.00	70.9	16.1	8.01	18.2	YES	396
3/22:00	0.9	80.00	70.0	15.3	8.00	19.1	YES	392
4/19:00	0.8	80.00	66.1	13.9	8.02	20.9	YES	402
5/14:00	0.8	80.00	62.2	14.2	7.99	20.2	YES	405
6/12:00	0.8	80.00	65.6	14.7	7.97	19.5	YES	399
7/21:00	0.8	80.00	66.1	14.5	8.00	20.0	YES	401
8/1:00	0.8	80.00	65.8	14.3	8.02	20.4	YES	406
9/22:00	0.7	80.00	56.5	14.7	8.01	19.5	YES	382
10/19:00	0.7	80.00	57.7	16.4	7.98	17.2	YES	385
11/1:00	0.8	80.00	62.9	16.9	8.03	17.2	YES	397
12/15:00	0.8	80.00	63.8	17.5	8.00	16.3	YES	402
13/23:00	0.8	80.00	62.2	18.0	8.01	15.8	YES	407
14/23:00	0.8	80.00	62.1	16.6	8.02	17.4	YES	404
15/23:00	0.7	80.00	59.3	15.9	8.00	18.0	YES	381
16/23:00	0.7	80.00	55.0	15.6	8.00	18.3	YES	371
17/23:00	0.8	80.00	63.1	15.6	8.02	18.7	YES	392
18/4:00	0.8	80.00	68.0	15.4	7.98	18.7	YES	379
19/13:00	0.8	80.00	66.5	15.3	7.99	18.9	YES	385
20/16:00	0.8	80.00	62.7	15.2	8.00	19.0	YES	375
21/10:00	0.8	80.00	60.2	14.6	8.01	19.8	YES	390
22/13:00	0.8	80.00	62.8	14.5	8.03	20.1	YES	387
23/8:00	0.7	80.00	59.9	14.8	8.00	19.4	YES	392
24/13:00	0.8	80.00	61.6	15.1	7.99	19.0	YES	392
25/17:00	0.8	80.00	61.7	15.4	7.97	18.5	YES	391
26/6:00	0.8	80.00	66.5	15.3	8.00	19.0	YES	381
27/12:00	0.8	80.00	61.9	15.8	8.02	18.4	YES	392
28/9:00	0.8	80.00	64.9	15.7	8.01	18.5	YES	379
29/14:00	0.8	80.00	65.7	16.0	8.01	18.1	YES	382
30/16:00	0.9	80.00	72.3	15.7	8.00	18.6	YES	384
31/8:00	0.9	80.00	70.2	15.8	7.98	18.3	YES	390

3 If C2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day. Revised October 2013

PAGE 2 of 2

Oregon Health Authority Drinking Water Section

Turbidity Monitoring Report Form

System Name: Yamhill, City of
ID#: OR4100968
August-25

Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	OFF	OFF	OFF	0.022	0.022	0.022	396
2	0.021	OFF	0.020	0.022	0.020	OFF	0.022	396
3	OFF	0.020	OFF	OFF	0.023	0.021	0.023	392
4	OFF	0.020	0.019	0.021	0.021	0.020	0.021	402
5	OFF	OFF	OFF	0.021	0.020	0.020	0.021	405
6	OFF	0.019	OFF	0.021	0.021	0.024	0.024	399
7	OFF	OFF	0.026	OFF	0.030	0.035	0.035	401
8	0.029	0.027	0.022	0.021	OFF	OFF	0.029	406
9	0.020	OFF	0.023	0.023	0.020	OFF	0.023	382
10	0.023	OFF	OFF	OFF	0.022	0.020	0.023	385
11	OFF	0.022	0.020	OFF	0.021	0.024	0.024	397
12	0.023	0.025	OFF	0.022	0.021	OFF	0.025	402
13	OFF	OFF	0.023	0.022	0.022	OFF	0.023	407
14	0.028	OFF	0.031	0.034	OFF	OFF	0.034	404
15	0.027	OFF	0.026	0.025	OFF	OFF	0.027	381
16	OFF	0.022	OFF	0.024	0.024	OFF	0.024	371
17	0.022	OFF	OFF	0.023	0.021	OFF	0.023	392
18	0.020	OFF	0.019	0.025	OFF	OFF	0.025	379
19	0.021	OFF	0.020	0.023	0.022	OFF	0.023	385
20	0.023	OFF	0.020	0.023	0.022	OFF	0.023	375
21	0.021	OFF	0.019	0.022	0.021	OFF	0.022	390
22	OFF	0.021	0.020	0.021	0.020	OFF	0.021	387
23	OFF	OFF	OFF	0.020	OFF	0.021	0.021	392
24	0.021	0.020	0.021	0.022	OFF	0.023	0.023	392
25	OFF	0.022	0.021	0.025	0.022	0.022	0.025	391
26	0.022	OFF	0.021	0.028	0.025	OFF	0.028	381
27	0.024	OFF	OFF	0.024	0.023	OFF	0.024	392
28	0.027	0.023	0.038	0.027	OFF	0.023	0.038	379
29	OFF	0.024	0.023	0.027	OFF	0.022	0.027	382
30	0.023	OFF	0.023	OFF	0.020	0.022	0.023	384
31	OFF	0.022	0.021	0.026	OFF	0.022	0.026	390

You are using a Slow Sand or Cartridge Filter
95% of Turbidity readings < MCL: Yes/No
All Turbidity readings < 5 NTU: Yes/No
CT's met every day: Yes/No
CI residual at entry point always > 2 mg/l: Yes/No
CI Residual measured in 95% of locations: Yes/No

MCL is 0.5 for conventional and direct filtration and 1.0 for slow sand and diatomaceous earth filters

Signature: Darrel Lockard
Date: 9/10/2025



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control