

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP: WTP-A	
System Name: Yamhill, City of		ID#: OR4100968	Month/Year: Sep-25		Disinfection Giardia Log Inactiv: 0.500			
Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[gpm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/8:00	0.9	80.00	72.8	15.3	7.99	19.1	YES	387
2/14:00	0.9	80.00	69.0	16.4	7.98	17.6	YES	373
3/9:00	0.7	80.00	59.9	16.6	8.01	17.3	YES	390
4/12:00	0.8	80.00	67.8	16.8	8.00	17.2	YES	394
5/7:00	0.7	80.00	59.3	16.7	7.97	16.9	YES	382
6/15:00	0.7	80.00	57.1	15.7	8.02	18.4	YES	397
7/8:00	0.7	80.00	57.8	15.5	8.00	18.5	YES	403
8/10:00	0.9	80.00	75.0	15.1	8.03	19.7	YES	400
9/13:00	0.9	80.00	72.8	15.2	8.01	19.3	YES	406
10/9:00	0.9	80.00	70.3	15.2	7.98	19.1	YES	393
11/6:00	0.9	80.00	71.2	14.7	7.96	19.6	YES	387
12/15:00	0.9	80.00	69.6	14.4	8.01	20.3	YES	394
13/20:00	0.9	80.00	70.3	14.3	8.00	20.4	YES	398
14/6:00	0.8	80.00	65.7	14.0	7.98	20.5	YES	417
15/14:00	0.8	80.00	63.8	13.2	8.03	22.0	YES	395
16/17:00	0.8	80.00	66.8	13.2	8.04	22.1	YES	404
17/13:00	0.9	80.00	69.6	14.0	8.05	21.1	YES	398
18/5:00	0.8	80.00	67.8	14.4	8.03	20.4	YES	396
19/17:00	0.9	80.00	73.8	13.3	8.04	22.2	YES	392
20/21:00	0.9	80.00	70.4	13.7	8.00	21.2	YES	404
21/21:00	0.9	80.00	73.5	13.7	8.01	21.3	YES	401
22/18:00	0.9	80.00	75.0	12.8	8.02	22.9	YES	393
23/3:00	1.0	80.00	81.4	12.7	7.97	22.8	YES	398
24/1:00	0.9	80.00	74.9	12.9	7.99	22.4	YES	406
25/4:00	0.9	80.00	71.1	14.1	8.02	20.8	YES	401
26/16:00	1.2	80.00	94.0	12.6	8.04	23.9	YES	397
27/17:00	1.0	80.00	83.1	12.2	8.00	23.8	YES	406
28/18:00	1.0	80.00	82.9	12.7	8.02	23.2	YES	395
29/14:00	1.0	80.00	79.8	12.8	8.04	23.1	YES	397
30/11:00	0.8	80.00	60.9	12.8	8.00	22.2	YES	393

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013

PAGE 2 of 2

Oregon Health Authority Drinking Water Section

Turbidity Monitoring Report Form

System Name: Yamhill, City of		ID#: OR4100968	Sep-25					
Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	OFF	0.021	0.025	0.024	0.022	0.025	387
2	0.021	OFF	0.022	0.023	0.021	0.023	0.023	373
3	0.024	OFF	0.022	0.022	0.025	0.023	0.025	390
4	0.022	OFF	0.021	0.030	0.036	0.024	0.036	394
5	0.022	0.021	0.021	0.026	OFF	0.023	0.026	382
6	OFF	OFF	0.022	0.023	0.025	0.024	0.025	397
7	0.029	OFF	0.026	0.027	0.024	OFF	0.029	403
8	OFF	0.025	0.022	0.024	0.023	OFF	0.025	400
9	0.023	OFF	OFF	0.025	0.026	0.020	0.026	406
10	OFF	OFF	0.021	OFF	0.022	0.023	0.023	393
11	0.023	0.021	0.021	0.024	OFF	0.023	0.024	387
12	OFF	OFF	0.021	0.025	0.021	0.021	0.025	394
13	OFF	0.020	0.020	0.026	0.023	OFF	0.026	398
14	OFF	0.021	0.020	0.023	0.024	OFF	0.024	417
15	OFF	0.027	0.026	0.027	0.024	OFF	0.027	395
16	OFF	OFF	OFF	OFF	0.022	0.026	0.026	404
17	0.024	OFF	OFF	OFF	0.023	0.024	0.024	398
18	0.025	0.020	0.021	OFF	0.022	0.024	0.025	396
19	0.021	OFF	0.021	0.027	0.021	0.024	0.024	392
20	OFF	OFF	0.021	0.022	0.023	0.022	0.023	404
21	OFF	OFF	0.020	0.022	OFF	OFF	0.022	401
22	OFF	OFF	0.022	0.020	0.021	OFF	0.022	393
23	0.020	OFF	0.021	0.020	OFF	OFF	0.021	398
24	0.024	0.030	OFF	OFF	0.027	0.022	0.030	406
25	OFF	OFF	0.023	0.022	0.025	OFF	0.025	401
26	OFF	OFF	0.022	0.027	0.023	OFF	0.027	397
27	OFF	OFF	0.021	0.024	0.025	OFF	0.025	406
28	0.021	OFF	0.026	0.030	0.024	OFF	0.030	395
29	0.021	OFF	0.022	0.021	OFF	0.024	0.024	397
30	0.024	OFF	0.023	0.026	OFF	0.025	0.026	393
31								

You are using a Slow Sand or Cartridge Filter ☐		☐ Monthly Summary	
99% of Turbidity readings < 0.5 NTU ☒ Yes	CT's met every 2 samples ☒ No (see back for notes)	Cl residual at entry point always > 2.0 mg/L ☒ Yes	Cl Residual measured in 5 samples ☒ Yes

MCL is 0.5 for conventional and direct filtration and 1.0 for slow sand and diatomaceous earth filters

Signature: Daniel Lockard
Date: 10/10/2025



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control