

OHA - Drinking Water Program - Surface Water Quality Data Form
WTP: WTP-A
System Name: Yamhill, City of
ID#: OR4100968
Month/Year: Oct-25
Disinfection Giardia Log Inactiv: 0.500

Date / Time	Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1/17:00	0.9	80.00	73.8	12.8	8.0	22.5	YES	396
2/17:00	0.9	80.00	68.4	12.7	8.0	22.3	YES	399
3/16:00	1.1	80.00	90.7	12.2	8.0	23.6	YES	392
4/17:00	1.1	80.00	84.3	11.9	8.0	24.4	YES	386
5/12:00	1.1	80.00	86.9	12.0	8.0	24.1	YES	391
6/15:00	1.1	80.00	85.9	11.8	8.0	24.5	YES	388
7/11:00	1.1	80.00	84.5	11.6	7.9	24.2	YES	390
8/17:00	1.0	80.00	81.5	11.7	8.0	24.4	YES	386
9/7:00	1.0	80.00	80.9	11.7	8.0	24.1	YES	391
10/10:00	1.0	80.00	82.0	11.1	8.0	25.5	YES	396
11/14:00	1.1	80.00	85.5	11.0	8.0	26.1	YES	390
12/3:00	1.0	80.00	76.9	11.0	8.0	25.8	YES	400
13/18:00	0.9	80.00	74.6	10.2	8.0	27.0	YES	405
14/11:00	0.9	80.00	74.0	9.6	8.0	27.8	YES	396
15/11:00	1.1	80.00	86.1	9.3	7.9	28.6	YES	394
16/20:00	0.9	80.00	75.7	9.4	8.0	28.2	YES	397
17/15:00	0.9	80.00	75.7	9.7	8.0	27.7	YES	400
18/15:00	0.9	80.00	75.8	10.1	8.0	27.0	YES	394
19/13:00	0.9	80.00	74.1	10.1	7.9	26.4	YES	406
20/17:00	0.7	80.00	59.4	10.0	7.9	26.2	YES	402
21/11:00	1.0	80.00	77.8	10.1	8.0	27.2	YES	396
22/10:00	1.0	80.00	79.3	9.7	8.0	27.8	YES	393
23/12:00	1.0	80.00	81.2	10.1	8.0	26.9	YES	408
24/18:00	0.8	80.00	66.8	10.6	8.0	25.5	YES	401
25/7:00	0.8	80.00	67.4	10.9	7.9	24.9	YES	398
26/14:00	1.0	80.00	77.6	10.4	7.9	25.8	YES	400
27/16:00	1.1	80.00	90.1	10.0	7.9	27.1	YES	397
28/16:00	1.1	80.00	84.7	9.4	7.9	28.0	YES	396
29/18:00	1.1	80.00	86.2	9.8	8.0	27.6	YES	396
30/21:00	1.1	80.00	88.0	9.9	7.9	27.2	YES	392
31/10:00	1.1	80.00	88.2	9.6	7.9	27.7	YES	408

3 If Cl2 at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.
Revised October 2013
PAGE 2 of 2

Oregon Health Authority Drinking Water Section
Turbidity Monitoring Report Form
System Name: Yamhill, City of
ID#: OR4100968
Oct-25

Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	0.027	OFF	0.029	0.032	OFF	0.032	396
2	OFF	OFF	0.025	0.050	0.021	OFF	0.050	399
3	OFF	OFF	0.023	0.021	0.022	OFF	0.023	392
4	OFF	OFF	0.024	0.025	OFF	OFF	0.025	386
5	0.024	OFF	0.024	0.027	OFF	0.022	0.027	391
6	OFF	OFF	0.034	OFF	0.024	OFF	0.034	388
7	OFF	OFF	0.023	0.021	OFF	0.021	0.023	390
8	OFF	OFF	0.022	0.025	0.021	OFF	0.025	386
9	OFF	OFF	0.026	0.029	OFF	0.024	0.029	391
10	OFF	0.021	0.022	0.024	OFF	OFF	0.024	396
11	0.022	OFF	0.020	0.023	OFF	0.025	0.025	390
12	OFF	OFF	0.026	0.024	OFF	OFF	0.026	400
13	OFF	OFF	0.021	0.025	0.022	OFF	0.025	405
14	OFF	0.023	OFF	0.024	0.024	OFF	0.024	396
15	0.023	OFF	0.022	0.022	0.021	OFF	0.023	394
16	0.025	OFF	0.022	0.030	OFF	0.034	0.034	397
17	OFF	0.022	OFF	0.021	0.021	OFF	0.022	400
18	OFF	OFF	0.021	0.023	0.022	OFF	0.023	394
19	0.021	OFF	0.020	0.021	OFF	0.023	0.023	406
20	OFF	0.023	0.027	OFF	0.025	OFF	0.027	402
21	0.025	OFF	0.023	OFF	0.022	OFF	0.025	396
22	0.023	OFF	0.024	OFF	0.020	OFF	0.024	393
23	OFF	OFF	0.026	0.023	OFF	0.021	0.026	408
24	OFF	0.022	OFF	0.023	OFF	OFF	0.023	401
25	OFF	OFF	0.024	0.031	0.038	OFF	0.038	398
26	OFF	OFF	0.049	0.044	0.041	OFF	0.049	400
27	OFF	OFF	0.033	0.027	0.028	OFF	0.033	397
28	OFF	OFF	0.022	0.020	0.027	OFF	0.027	396
29	0.026	OFF	OFF	OFF	0.026	0.024	0.026	396
30	OFF	OFF	0.026	OFF	0.025	OFF	0.026	392
31	OFF	OFF	0.022	0.024	0.021	OFF	0.024	408

You are using a Slow Sand or Cartridge Filter
Monthly Summary
95% of Turbidity readings < MCL Y / N
All Turbidity readings < 5 NTU Y / N
CT's met every day: Yes / No (see back of sheet)
Cl residual at entry point always >= 2 mg/l Yes / No
Cl Residual measured in 95% of distribution samples Yes / No

MCL is 0.5 for conventional and direct filtration and 1.0 for slow sand and diatomaceous earth filters

Signature: Darrel Lockard
Date: 11/10/2025



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control