

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: WTP-A

System Name: Yamhill, City of		ID#: OR4100968	Month/Year: Dec-25		Disinfection Giardia Log Inactive:		0.500	
Date / Time	Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/13:00	0.6	80.00	51.6	8.8	7.9	27.9	YES	405
2/11:00	0.6	80.00	50.2	8.3	7.9	28.0	YES	389
3/18:00	0.6	80.00	45.5	8.8	7.7	25.5	YES	392
4/15:00	0.6	80.00	45.1	8.8	7.7	25.4	YES	408
5/6:00	0.5	80.00	42.0	8.7	7.7	25.5	YES	405
6/15:00	0.5	80.00	41.9	9.5	7.7	24.4	YES	406
7/6:00	0.5	80.00	40.1	10.0	7.8	23.8	YES	401
8/17:00	0.5	80.00	42.4	10.0	7.7	23.5	YES	396
9/16:00	0.6	80.00	44.5	10.2	7.8	23.7	YES	408
10/21:00	0.5	80.00	37.8	10.9	7.8	22.5	YES	398
11/23:00	0.5	80.00	42.4	11.3	7.7	21.6	YES	407
12/9:00	0.5	80.00	43.8	11.3	7.8	22.7	YES	399
13/1:00	0.6	80.00	45.3	11.1	8.0	24.0	YES	388
14/12:00	0.5	80.00	36.7	10.1	7.7	23.3	YES	392
15/23:00	0.5	80.00	36.8	10.3	7.9	24.1	YES	401
16/19:00	0.5	80.00	38.6	10.6	7.8	23.4	YES	397
17/14:00	0.5	80.00	40.3	10.3	7.8	23.6	YES	394
18/18:00	0.5	80.00	39.5	9.8	7.8	24.7	YES	400
19/9:00	0.5	80.00	41.6	10.1	7.8	24.1	YES	402
20/22:00	0.5	80.00	39.3	9.2	7.8	25.4	YES	398
21/18:00	0.5	80.00	43.0	9.6	7.9	25.9	YES	395
22/22:00	0.5	80.00	39.2	9.2	7.8	25.2	YES	404
23/4:00	0.6	80.00	44.0	9.3	7.8	25.1	YES	401
24/15:00	0.5	80.00	41.6	9.4	7.8	25.2	YES	397
25/18:00	0.5	80.00	36.6	9.3	7.8	24.9	YES	399
26/10:00	0.5	80.00	36.1	9.4	7.8	25.3	YES	400
27/16:00	0.5	80.00	42.4	8.9	7.8	26.1	YES	406
28/16:00	0.5	80.00	40.8	8.2	7.7	26.7	YES	402
29/16:00	0.5	80.00	37.3	7.9	7.8	27.3	YES	398
30/1:00	0.6	80.00	44.0	8.1	7.8	27.2	YES	395
31/10:00	0.5	80.00	43.2	7.7	7.8	27.9	YES	401

³ If CT at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day. Revised October 2013

Oregon Health Authority Drinking Water Section

Turbidity Monitoring Report Form

System Name: Yamhill, City of		ID#: OR4100968		Dec-25				
Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	0.024	OFF	0.024	OFF	0.028	OFF	0.028	405
2	0.026	OFF	OFF	0.026	OFF	0.022	0.026	389
3	0.023	OFF	0.024	OFF	0.023	OFF	0.024	392
4	OFF	OFF	0.034	0.048	0.023	OFF	0.048	408
5	OFF	OFF	0.027	OFF	0.028	0.022	0.028	405
6	OFF	OFF	0.028	0.032	0.034	OFF	0.034	406
7	0.025	OFF	0.022	0.024	OFF	OFF	0.025	401
8	OFF	0.023	OFF	OFF	0.055	0.022	0.055	396
9	OFF	OFF	0.029	0.027	0.026	OFF	0.029	408
10	OFF	0.022	OFF	0.022	OFF	0.034	0.034	398
11	OFF	OFF	0.024	0.025	0.022	OFF	0.025	407
12	OFF	OFF	0.027	0.026	0.025	OFF	0.027	399
13	0.023	OFF	0.023	OFF	OFF	0.023	0.023	388
14	OFF	0.025	0.022	0.024	OFF	OFF	0.025	392
15	0.024	OFF	OFF	0.024	OFF	0.023	0.024	401
16	0.026	OFF	OFF	0.028	0.032	0.023	0.032	397
17	OFF	OFF	0.028	0.023	OFF	0.024	0.028	394
18	OFF	0.025	OFF	0.033	0.026	OFF	0.033	400
19	0.027	OFF	OFF	0.030	0.035	OFF	0.035	402
20	OFF	0.043	OFF	0.033	0.030	OFF	0.043	398
21	0.033	OFF	0.029	OFF	0.026	OFF	0.033	395
22	OFF	OFF	0.022	0.024	OFF	0.026	0.026	404
23	OFF	0.027	OFF	0.025	0.025	OFF	0.027	401
24	0.027	OFF	0.036	OFF	0.031	OFF	0.036	397
25	OFF	0.024	OFF	0.026	0.024	OFF	0.026	399
26	OFF	OFF	0.027	OFF	0.023	0.024	0.027	400
27	OFF	0.023	OFF	0.025	0.024	OFF	0.025	406
28	OFF	0.024	OFF	0.020	0.025	OFF	0.025	402
29	0.026	OFF	0.028	0.024	0.024	OFF	0.028	398
30	0.025	OFF	0.024	OFF	0.024	OFF	0.025	395
31	OFF	OFF	0.025	0.025	0.027	OFF	0.027	401

You are using a Slow Sand or Cartridge Filter Monthly Summary

95% of Turbidity readings < MCL: N Yes No

All Turbidity readings < 5 NTU: N Yes No

CT's met every day: Yes No (see back of sheet)

CT residual in treatment always ≥ 2 mg·min: Yes No

95% of disinfection samples: Yes No

MCL is 0.5 for conventional and direct filtration and 1.0 for slow sand and diatomaceous earth filters

Darrel Lockard
Date: 1/9/2026

