

OHA - Drinking Water Program - Surface Water Quality Data Form								WTP: WTP-A	
System Name: Yamhill, City of			ID#: OR4100968		Month/Year: Jan-26		Disinfection Giardia Log Ineffici: 0.500		
Date / Time	Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1/11:00	0.6	80.00	44.0	7.6	7.8	28.6	YES	403	
2/17:00	0.6	80.00	44.8	8.3	7.8	26.9	YES	412	
3/16:00	0.5	80.00	41.6	9.0	7.8	26.1	YES	408	
4/15:00	0.5	80.00	41.6	9.2	7.8	25.5	YES	407	
5/13:00	0.6	80.00	44.0	8.7	7.8	26.2	YES	404	
6/16:00	0.5	80.00	43.2	8.1	7.8	27.7	YES	399	
7/17:00	0.5	80.00	42.4	8.1	7.8	27.6	YES	396	
8/17:00	0.5	80.00	41.6	7.9	7.8	28.2	YES	400	
9/15:00	0.5	80.00	40.0	8.3	7.8	26.9	YES	394	
10/15:00	0.6	80.00	45.6	8.2	7.8	27.1	YES	398	
11/14:00	0.5	80.00	40.8	8.5	7.7	25.9	YES	396	
12/12:00	0.5	80.00	43.2	8.9	7.7	25.4	YES	399	
13/1:00	0.6	80.00	44.8	9.3	7.7	24.8	YES	406	
14/16:00	0.7	80.00	52.0	8.5	7.8	26.9	YES	401	
15/8:00	0.6	80.00	48.0	8.5	7.8	26.7	YES	397	
16/15:00	0.6	80.00	46.4	8.3	7.8	27.1	YES	395	
17/16:00	0.6	80.00	44.6	8.4	7.8	27.5	YES	403	
18/17:00	0.6	80.00	44.8	7.9	7.8	27.6	YES	398	
19/9:00	0.6	80.00	44.8	7.5	7.8	28.4	YES	403	
20/20:00	0.6	80.00	44.0	7.3	7.8	28.9	YES	395	
21/9:00	0.5	80.00	40.8	6.9	7.8	29.5	YES	405	
22/10:00	0.5	80.00	40.0	6.6	7.8	30.2	YES	402	
23/16:00	0.5	80.00	38.4	6.5	7.8	30.5	YES	400	
24/14:00	0.5	80.00	40.0	6.3	7.8	31.1	YES	399	
25/15:00	0.5	80.00	38.4	6.0	7.8	31.4	YES	389	
26/23:00	0.5	80.00	36.0	6.1	7.8	31.1	YES	396	
27/23:00	0.4	80.00	35.2	7.0	7.8	29.4	YES	390	
28/8:00	0.5	80.00	42.4	7.1	7.8	29.7	YES	395	
29/17:00	0.5	80.00	41.6	7.9	7.8	27.8	YES	388	
30/15:00	0.5	80.00	38.4	8.3	7.8	27.2	YES	403	
31/10:00	0.5	80.00	36.0	8.9	7.8	26.1	YES	405	

³ If CT at entry point < 0.2 mg/l or CT not met, DWS to be notified by end of next business day.

Revised October 2013

PAGE 2 of 2

Day	12AM (NTU)	4AM (NTU)	8AM (NTU)	NOON (NTU)	4PM (NTU)	8PM (NTU)	Highest (NTU)	Peak Hourly Flow (GPM)
1	OFF	0.027	OFF	0.034	0.025	OFF	0.034	403
2	OFF	OFF	0.022	OFF	0.025	OFF	0.025	412
3	OFF	OFF	OFF	0.024	0.023	0.026	0.026	408
4	OFF	0.024	OFF	0.023	0.027	OFF	0.027	407
5	0.022	OFF	0.025	0.020	0.022	OFF	0.025	404
6	0.023	OFF	OFF	0.026	0.023	OFF	0.026	399
7	OFF	OFF	0.034	OFF	0.030	0.037	0.037	396
8	OFF	OFF	0.028	0.027	0.025	OFF	0.028	400
9	OFF	0.029	0.031	OFF	0.026	OFF	0.031	394
10	0.028	OFF	0.028	0.024	0.024	OFF	0.028	398
11	0.024	OFF	OFF	0.025	OFF	0.027	0.027	396
12	0.021	OFF	0.026	0.025	OFF	0.026	0.026	399
13	0.023	OFF	0.023	OFF	0.025	OFF	0.025	406
14	OFF	OFF	0.025	0.023	0.023	OFF	0.025	401
15	0.026	OFF	0.027	OFF	0.030	0.028	0.030	397
16	OFF	0.024	OFF	OFF	0.023	OFF	0.024	395
17	0.026	OFF	0.026	0.024	0.025	OFF	0.026	403
18	0.026	OFF	0.028	0.028	0.026	OFF	0.028	398
19	0.027	OFF	OFF	0.024	0.024	OFF	0.027	403
20	OFF	0.026	OFF	0.025	OFF	0.028	0.028	395
21	OFF	OFF	0.031	OFF	0.033	OFF	0.033	405
22	OFF	0.031	0.030	OFF	0.026	OFF	0.031	402
23	0.027	OFF	0.024	0.022	0.025	OFF	0.027	400
24	OFF	OFF	0.024	OFF	0.024	OFF	0.024	399
25	0.026	OFF	OFF	OFF	0.027	0.022	0.027	389
26	OFF	0.032	OFF	0.033	0.039	OFF	0.039	396
27	0.035	OFF	0.032	0.030	OFF	OFF	0.035	390
28	0.032	OFF	0.031	OFF	0.028	OFF	0.032	395
29	OFF	OFF	0.035	0.033	0.040	OFF	0.040	388
30	OFF	0.033	OFF	0.029	0.025	OFF	0.033	403
31	OFF	OFF	0.025	0.028	OFF	0.025	0.028	405

You are using a Slow Sand or Cartridge Filter Monthly Summary

95% of Turbidity readings < MCL: Yes No

All Turbidity readings < 5 NTU: Yes No

CT's met every day: Yes No (see back or sheet)

CT residual always > 2.0 mg/l: Yes No

CT Residual measured in 95% of samples: Yes No

MCL is 0.5 for conventional and direct filtration and 1.0 for slow sand and diatomaceous earth filters

Darrol Lockard
Date: 2/10/2026

Day	pH	Alk	Phos	Sili	Y/N
1					
2	7.73	56			Y
3					
4	7.76	57			Y
5					
6					

<< Have minimums been met for this day?

System Name: City of Yamhill
Entry Point: EP-A
Sample Period: Jan-26

ENTRY POINT

PWS ID: 41 0 0 9 6 8

City of Yamhill

Month / Year: Jan-26



7					
8	7.79	56			Y
9					
10					
11					
12					
13					
14	7.77	56			Y
15					
16					
17					
18	7.79	58			Y
19					
20					
21					
22	7.80	58			Y
23					
24					
25	7.80	58			Y
26					
27					
28	7.83	58			Y
29					
30	7.82	58			Y
31					

(NO=N=Excursions) Total N's

Number of excursions* during this month:

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text" value="55"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Darrel Lockard Darrel Lockard

Signature: *Darrel Lockard*

Date: 2/10/2026