

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Tillamook**  
 Month/Year: **Mar-21**

System Name: <b>Neskowin Regional Water District ID#: 4100970</b>		WTP : TP -					WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
3/1/2021	Off	Off	Off	Off	Off	Off	Off
3/2/2021	Off	0.0138	0.0131	0.0130	0.0132	0.0131	0.0138
3/3/2021	0.0130	0.0129	Off	Off	Off	Off	0.0130
3/4/2021	Off	Off	Off	Off	Off	Off	Off
3/5/2021	0.0131	0.0130	0.0131	0.0132	0.0131	0.0131	0.0132
3/6/2021	Off	Off	Off	Off	Off	Off	Off
3/7/2021	Off	Off	Off	0.0132	0.0130	0.0129	0.0132
3/8/2021	0.0130	0.0129	0.0128	0.0128	Off	Off	0.0130
3/9/2021	Off	Off	Off	Off	Off	Off	Off
3/10/2021	Off	Off	0.0417	0.0131	0.0133	0.0131	0.0417
3/11/2021	0.0130	0.0130	Off	Off	Off	Off	0.0130
3/12/2021	Off	Off	Off	Off	Off	0.0132	0.0132
3/13/2021	0.0134	0.0131	0.0130	0.0129	0.0130	0.0131	0.0134
3/14/2021	Off	Off	Off	Off	Off	Off	Off
3/15/2021	Off	Off	Off	0.0130	0.0133	0.0129	0.0133
3/16/2021	0.0128	0.0128	0.0128	0.0129	Off	Off	0.0129
3/17/2021	Off	Off	Off	Off	Off	Off	Off
3/18/2021	Off	0.0142	0.0131	0.0130	0.0129	0.0133	0.0142
3/19/2021	0.0131	Off	Off	Off	Off	Off	0.0131
3/20/2021	Off	Off	Off	Off	0.0140	0.0132	0.0140
3/21/2021	0.0131	0.0131	0.0131	0.0132	0.0131	Off	0.0132
3/22/2021	Off	Off	Off	Off	Off	Off	Off
3/23/2021	Off	0.0133	0.0134	0.0131	0.0132	0.0131	0.0134
3/24/2021	0.0135	0.0132	Off	Off	Off	Off	0.0135
3/25/2021	Off	Off	Off	0.0135	0.0132	0.0135	0.0135
3/26/2021	0.0132	0.0131	0.0131	Off	Off	Off	0.0132
3/27/2021	Off	Off	Off	Off	0.0156	0.0137	0.0156
3/28/2021	0.0133	0.0132	0.0132	0.0131	0.0136	Off	0.0136
3/29/2021	Off	Off	Off	Off	Off	Off	Off
3/30/2021	Off	Off	0.0137	0.0134	0.0131	0.0130	0.0137
3/31/2021	Off	Off	Off	Off	Off	Off	Off

**Slow Sand/Membrane/DE Filtration/Unfiltered**

**Monthly Summary (Answer Yes or No)**

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>  Yes / No

CT's met everyday? (see back)  Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes / No

All daily turbidity readings ≤ 5 NTU?  Yes / No

Yes / No

Yes / No

**Notes:**

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: **4/7/2021**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:  
Neskowin  
Regional Water  
District

ID#: 4100970

Month/Year: March-21

Disinfection  
Gardias Log  
Inactive:

1.0

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	9.0	7.9	Off	Off	Off
2	1.4	129	180.6	9.0	7.9	59.4	Yes	215
3	1.4	129	180.6	9.0	7.7	55.2	Yes	202
4	Off	129	Off	9.0	7.7	Off	Off	Off
5	0.8	129	103.2	9.0	7.7	51.6	Yes	243
6	Off	129	Off	9.0	7.8	Off	Off	Off
7	1.15	129	148.4	9.0	7.8	55.6	Yes	214
8	1.2	129	154.8	9.0	7.8	56.0	Yes	234
9	Off	129	Off	9.0	7.8	Off	Off	Off
10	1	129	129.0	9.0	7.7	52.8	Yes	206
11	0.98	129	126.4	9.0	7.8	54.6	Yes	204
12	1.21	129	156.1	9.0	7.8	56.0	Yes	219
13	1.12	129	144.5	9.0	7.8	55.4	Yes	227
14	Off	129	Off	8.0	7.7	Off	Off	Off
15	0.99	129	127.7	8.0	7.7	56.4	Yes	202
16	1.25	129	161.3	7.0	7.8	64.5	Yes	202
17	Off	129	Off	7.0	7.8	Off	Off	Off
18	1.1	129	141.9	7.0	7.7	61.1	Yes	219
19	1.18	129	152.2	7.0	7.7	61.7	Yes	202
20	0.8	129	103.2	7.0	7.8	61.2	Yes	203
21	0.8	129	103.2	7.0	7.8	61.2	Yes	204
22	Off	129	Off	7.0	7.7	Off	Off	Off
23	1.05	129	135.5	7.0	7.7	60.7	Yes	205
24	1.09	129	140.6	8.0	7.7	57.0	Yes	205
25	0.8	129	103.2	8.0	7.8	57.2	Yes	202
26	0.9	129	116.1	8.0	7.7	55.8	Yes	202
27	0.91	129	117.4	8.0	7.6	53.9	Yes	202
28	1.09	129	140.6	8.0	7.4	51.2	Yes	203
29	Off	129	Off	8.0	7.6	Off	Off	Off
30	0.8	129	103.2	8.0	7.6	53.2	Yes	208
31	Off	129	Off	9.0	7.6	Off	Off	Off

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350