

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**
 Month/Year: **Apr-21**

System Name: Neskowin Regional Water District ID#: 4100970		WTP : TP -					WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
4/1/2021	Off	Off	Off	Off	Off	Off	Off
4/2/2021	Off	Off	0.0130	0.0129	0.0135	0.0130	0.0135
4/3/2021	0.0129	Off	Off	Off	Off	Off	0.0129
4/4/2021	Off	Off	Off	Off	0.0132	0.0129	0.0132
4/5/2021	0.0135	0.0132	0.0129	0.0129	Off	Off	0.0135
4/6/2021	Off	Off	Off	Off	Off	Off	Off
4/7/2021	Off	Off	Off	0.0131	0.0130	0.0134	0.0134
4/8/2021	0.0131	0.0130	0.0137	0.0133	Off	Off	0.0137
4/9/2021	Off	Off	Off	Off	Off	Off	Off
4/10/2021	Off	Off	Off	0.0136	0.0132	0.0136	0.0136
4/11/2021	0.0137	0.0142	0.0144	0.0133	0.0136	0.0131	0.0144
4/12/2021	0.0131	Off	Off	Off	Off	Off	0.0131
4/13/2021	Off	Off	Off	Off	Off	Off	Off
4/14/2021	0.0130	0.0129	0.0128	0.0127	0.0127	0.0126	0.0130
4/15/2021	Off	Off	Off	Off	Off	Off	Off
4/16/2021	Off	Off	Off	Off	0.0130	0.0128	0.0130
4/17/2021	0.0127	0.0128	0.0131	0.0127	0.0127	0.0127	0.0131
4/18/2021	0.0131	Off	Off	Off	Off	Off	0.0131
4/19/2021	Off	Off	Off	0.0129	0.0132	0.0128	0.0132
4/20/2021	0.0128	0.0128	0.0128	Off	Off	Off	0.0128
4/21/2021	Off	Off	Off	0.0137	0.0127	0.0127	0.0137
4/22/2021	0.0127	Off	Off	Off	Off	Off	0.0127
4/23/2021	Off	Off	Off	Off	0.0131	0.0133	0.0133
4/24/2021	0.0128	0.0128	0.0129	0.0128	0.0131	Off	0.0131
4/25/2021	Off	Off	Off	Off	Off	Off	Off
4/26/2021	Off	Off	0.0130	0.0128	0.0130	0.0128	0.0130
4/27/2021	0.0128	0.0128	Off	Off	Off	Off	0.0128
4/28/2021	Off	Off	Off	Off	Off	0.0130	0.0130
4/29/2021	0.0128	0.0128	Off	Off	Off	Off	0.0128
4/30/2021	Off	Off	Off	Off	0.0126	0.0127	0.0127
5/1/2021	0.0127	0.0127	0.0125	0.0125	Off	Off	0.0127

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **5/7/2021**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: April-21	Disinfection Giardia Log Inactive: 1.0
--	--------------	----------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	9.0	7.7	Off	Off	Off
2	0.8	129	103.2	9.0	7.6	49.8	Yes	206
3	0.96	129	123.8	9.0	7.6	50.7	Yes	201
4	0.81	129	104.5	9.0	7.6	49.8	Yes	206
5	0.7	129	90.3	9.0	7.7	51.0	Yes	203
6	Off	129	Off	9.0	7.7	Off	Off	Off
7	0.8	129	103.2	9.0	7.7	51.6	Yes	211
8	1.2	129	154.8	9.0	7.9	58.0	Yes	206
9	Off	129	Off	9.0	7.8	Off	Off	Off
10	0.8	129	103.2	9.0	7.7	51.6	Yes	205
11	1.19	129	153.5	9.0	7.8	55.9	Yes	204
12	0.9	129	116.1	9.0	7.7	52.2	Yes	201
13	Off	129	Off	9.0	7.8	Off	Off	Off
14	0.8	129	103.2	10.0	7.7	48.2	Yes	221
15	Off	129	Off	10.0	7.7	Off	Off	Off
16	0.9	129	116.1	10.0	7.6	47.1	Yes	211
17	1.15	129	148.4	10.0	7.7	50.2	Yes	219
18	1.21	129	156.1	10.0	7.7	50.5	Yes	202
19	0.9	129	116.1	11.0	7.6	44.1	Yes	204
20	1	129	129.0	12.0	7.6	41.7	Yes	206
21	1	129	129.0	12.0	7.7	43.2	Yes	204
22	1	129	129.0	11.0	7.8	47.8	Yes	206
23	1	129	129.0	10.8	7.8	48.5	Yes	206
24	1.2	129	154.8	10.5	7.9	52.4	Yes	208
25	Off	129	Off	10.6	7.9	Off	Off	Off
26	1	129	129.0	11.0	7.7	46.2	Yes	206
27	0.9	129	116.1	11.0	7.6	44.1	Yes	205
28	0.7	129	90.3	12.0	7.7	41.8	Yes	205
29	0.8	129	103.2	12.0	7.7	42.3	Yes	202
30	0.7	129	90.3	12.0	7.8	43.3	Yes	208

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350