

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**
 Month/Year: **Jun-21**

System Name: Neskowin Regional Water District ID#: 4100970		WTP : TP -					WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
6/1/2021	0.0129	0.0127	0.0126	0.0124	Off	Off	0.0129
6/2/2021	Off	Off	Off	Off	Off	Off	Off
6/3/2021	Off	Off	0.0128	0.0125	0.0125	0.0127	0.0128
6/4/2021	0.0127	0.0127	Off	Off	0.0124	0.0124	0.0127
6/5/2021	0.0127	0.0125	0.0125	Off	Off	Off	0.0127
6/6/2021	Off	0.0143	0.0128	0.0125	0.0125	0.0126	0.0143
6/7/2021	0.0129	0.0129	0.0126	0.0125	Off	Off	0.0129
6/8/2021	Off	Off	Off	Off	Off	Off	Off
6/9/2021	Off	Off	0.0133	0.0131	0.0125	0.0126	0.0133
6/10/2021	0.0131	0.0128	0.0127	Off	Off	Off	0.0131
6/11/2021	Off	Off	Off	0.0126	0.0127	0.0126	0.0127
6/12/2021	0.0126	Off	Off	Off	Off	Off	0.0126
6/13/2021	Off	Off	Off	0.0169	0.0126	0.0133	0.0169
6/14/2021	0.0128	0.0128	0.0128	0.0128	Off	Off	0.0128
6/15/2021	Off	Off	Off	Off	Off	Off	Off
6/16/2021	Off	Off	Off	0.0126	0.0134	0.0129	0.0134
6/17/2021	0.0129	0.0129	0.0129	Off	Off	Off	0.0129
6/18/2021	Off	Off	Off	Off	0.0157	0.0130	0.0157
6/19/2021	0.0130	Off	Off	0.0196	0.0194	0.0194	0.0196
6/20/2021	0.0199	0.0203	0.0197	0.0195	0.0194	0.0195	0.0203
6/21/2021	0.0197	Off	Off	Off	Off	Off	0.0197
6/22/2021	Off	Off	Off	0.0196	0.0195	0.0190	0.0196
6/23/2021	0.0195	0.0198	0.0197	0.0194	0.0189	0.0192	0.0198
6/24/2021	Off	Off	Off	Off	Off	Off	Off
6/25/2021	Off	Off	Off	0.0199	0.0192	0.0192	0.0199
6/26/2021	0.0193	0.0195	0.0200	0.0194	0.0191	0.0191	0.0200
6/27/2021	0.0198	0.0196	Off	Off	Off	Off	0.0198
6/28/2021	Off	Off	Off	Off	0.0125	0.0127	0.0127
6/29/2021	0.0133	0.0133	Off	Off	Off	Off	0.0133
6/30/2021	Off	Off	Off	0.0128	0.0134	0.0128	0.0134
7/1/2021	0.0128	0.0128	0.0130	0.0128	0.0128	Off	0.0130

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: 7/7/2021

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: WTP-A

System Name:
Neskowin
Regional Water
District

ID#: 4100970

Month/Year: June-21

Disinfection
Giardia Log
Inactive:

1.0

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.7	129	90.3	12.0	8.0	46.4	Yes	229
2	Off	129	Off	12.0	7.8	Off	Off	Off
3	0.7	129	90.3	12.0	7.8	43.3	Yes	246
4	0.8	129	103.2	12.0	7.7	42.3	Yes	205
5	1	129	129.0	12.8	7.9	44.0	Yes	202
6	1	129	129.0	12.5	7.8	43.2	Yes	250
7	0.8	129	103.2	12.0	7.7	42.3	Yes	229
8	Off	129	Off	13.0	7.8	Off	Off	Off
9	0.8	129	103.2	13.0	7.7	39.4	Yes	246
10	0.7	129	90.3	13.0	7.7	39.0	Yes	207
11	0.7	129	90.3	13.0	7.7	39.0	Yes	247
12	0.8	129	103.2	13.0	7.8	40.9	Yes	201
13	0.8	129	103.2	13.0	7.7	39.4	Yes	251
14	0.8	129	103.2	13.0	7.8	40.9	Yes	242
15	Off	129	Off	13.0	7.8	Off	Off	Off
16	0.6	129	77.4	13.0	7.7	38.5	Yes	201
17	0.8	129	103.2	13.0	7.8	40.9	Yes	243
18	0.98	129	126.4	12.0	7.8	44.7	Yes	202
19	1.21	129	156.1	12.0	7.9	47.5	Yes	251
20	1.19	129	153.5	13.0	7.9	44.3	Yes	256
21	1.08	129	139.3	13.0	7.8	42.2	Yes	201
22	0.8	129	103.2	13.1	7.9	42.1	Yes	251
23	0.8	129	103.2	13.0	7.8	40.9	Yes	256
24	Off	129	Off	13.0	7.7	Off	Off	Off
25	0.8	129	103.2	13.0	7.7	39.4	Yes	252
26	1	129	129.0	13.6	8.2	46.6	Yes	259
27	1	129	129.0	14.5	7.9	39.3	Yes	203
28	0.8	129	103.2	15.0	7.8	35.8	Yes	201
29	0.8	129	103.2	15.0	7.9	37.2	Yes	202
30	0.7	129	90.3	14.0	7.8	37.8	Yes	201

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350