

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**

Month/Year: **Nov-21**

System Name: **Neskowin Regional Water District ID#: 4100970**

WTP: TP - **WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
11/1/2021	Off	Off	Off	Off	Off	Off	Off
11/2/2021	Off	Off	Off	Off	Off	Off	Off
11/3/2021	Off	Off	Off	0.0128	0.0134	0.0131	0.0134
11/4/2021	0.0146	Off	Off	Off	Off	Off	0.0146
11/5/2021	Off	Off	Off	Off	Off	Off	Off
11/6/2021	Off	0.0147	0.0138	0.0138	Off	Off	0.0147
11/7/2021	Off	Off	0.0150	0.0138	0.0141	0.0139	0.0150
11/8/2021	Off	Off	Off	0.0134	0.0133	0.0133	0.0134
11/9/2021	Off	Off	Off	Off	Off	Off	Off
11/10/2021	Off	Off	Off	Off	Off	Off	Off
11/11/2021	Off	Off	Off	Off	Off	Off	Off
11/12/2021	Off	0.0133	0.0133	Off	Off	Off	0.0133
11/13/2021	Off	0.0133	0.0133	0.0133	0.0134	Off	0.0134
11/14/2021	Off	Off	Off	Off	Off	Off	Off
11/15/2021	Off	Off	Off	Off	Off	Off	Off
11/16/2021	Off	Off	Off	0.0133	Off	Off	0.0133
11/17/2021	Off	Off	Off	0.0188	0.0134	0.0133	0.0188
11/18/2021	0.0133	0.0135	0.0134	Off	Off	Off	0.0135
11/19/2021	Off	Off	Off	Off	Off	Off	Off
11/20/2021	Off	Off	Off	0.0134	0.0135	0.0134	0.0135
11/21/2021	0.0134	0.0135	Off	Off	Off	Off	0.0135
11/22/2021	Off	Off	Off	Off	Off	Off	Off
11/23/2021	Off	Off	Off	0.0138	0.0134	0.0134	0.0138
11/24/2021	0.0135	0.0134	0.0135	Off	Off	Off	0.0135
11/25/2021	Off	Off	Off	Off	Off	Off	Off
11/26/2021	0.0135	0.0137	0.0135	0.0136	0.0135	0.0135	0.0137
11/27/2021	Off	Off	Off	Off	Off	Off	Off
11/28/2021	Off	Off	Off	Off	Off	Off	Off
11/29/2021	0.0134	0.0136	0.0134	0.0134	Off	Off	0.0136
11/30/2021	Off	Off	Off	Off	Off	Off	Off
12/1/2021	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: **12/3/2021**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: November-21	Disinfection Giardia Log Inactiv: 1.0
--	--------------	-------------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	11.1	7.4	Off	Off	Off
2	Off	129	Off	11.0	7.4	Off	Off	Off
3	0.80	129	103.2	11.1	7.5	41.8	Yes	206
4	1.00	129	129.0	11.3	7.2	38.0	Yes	201
5	Off	129	Off	11.1	7.4	Off	Off	Off
6	0.80	129	103.2	11.8	8.0	47.6	Yes	239
7	0.80	129	103.2	11.3	7.9	47.5	Yes	224
8	1.00	129	129.0	10.3	7.3	42.0	Yes	202
9	Off	129	Off	10.3	7.2	Off	Off	Off
10	Off	129	Off	10.4	7.2	Off	Off	Off
11	Off	129	Off	10.8	7.4	Off	Off	Off
12	1.08	129	139.3	10.0	7.4	44.8	Yes	229
13	0.95	129	122.6	11.5	7.4	40.0	Yes	220
14	Off	129	Off	11.1	7.4	Off	Off	Off
15	Off	129	Off	11.3	7.5	Off	Off	Off
16	1.20	129	154.8	11.0	7.2	39.6	Yes	201
17	1.00	129	129.0	10.8	7.3	40.7	Yes	201
18	1.00	129	129.0	10.8	7.5	43.6	Yes	205
19	Off	129	Off	10.8	7.2	Off	Off	Off
20	1.20	129	154.8	10.4	7.3	42.7	Yes	219
21	1.20	129	154.8	10.2	7.4	44.8	Yes	234
22	Off	129	Off	10.3	7.5	Off	Off	Off
23	1.20	129	154.8	10.0	7.2	42.3	Yes	213
24	0.80	129	103.2	9.9	7.9	52.1	Yes	201
25	Off	129	Off	9.7	8.1	Off	Off	Off
26	0.80	129	103.2	11.0	8.0	50.2	Yes	230
27	Off	129	Off	11.0	8.2	Off	Off	Off
28	Off	129	Off	11.0	8.2	Off	Off	Off
29	1.00	129	129.0	10.7	7.4	42.4	Yes	208
30	Off	129	Off	10.6	7.2	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350