

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**

Month/Year: **Jul-22**

System Name: **Neskowin Regional Water District ID#: 4100970**

WTP: **TP - WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
7/1/2022	0.0107	0.0107	Off	Off	Off	Off	0.0107
7/2/2022	Off	Off	Off	0.0109	0.0106	0.0106	0.0109
7/3/2022	0.0107	0.0108	0.0108	0.0107	0.0108	Off	0.0108
7/4/2022	0.0111	0.0111	0.0108	0.0108	Off	Off	0.0111
7/5/2022	Off	Off	Off	Off	Off	0.0113	0.0113
7/6/2022	0.0109	0.0109	Off	0.0111	0.0115	0.0109	0.0115
7/7/2022	0.0108	0.0108	Off	0.0112	0.0110	0.0108	0.0112
7/8/2022	Off	Off	Off	Off	Off	Off	Off
7/9/2022	Off	Off	Off	0.0107	0.0108	0.0108	0.0108
7/10/2022	0.0111	0.0112	0.0109	Off	0.0104	Off	0.0112
7/11/2022	Off	Off	Off	0.0131	0.0104	0.0104	0.0131
7/12/2022	0.0104	Off	0.0106	0.0103	0.0105	Off	0.0106
7/13/2022	Off	Off	Off	Off	Off	0.0104	0.0104
7/14/2022	0.0104	0.0105	0.0106	0.0106	0.0106	0.0106	0.0106
7/15/2022	Off	Off	Off	Off	Off	Off	Off
7/16/2022	Off	Off	Off	Off	0.0112	0.0106	0.0112
7/17/2022	0.0106	0.0107	0.0106	0.0106	0.0110	0.0107	0.0110
7/18/2022	0.0106	0.0108	0.0106	Off	0.0111	Off	0.0111
7/19/2022	Off	Off	Off	Off	Off	Off	Off
7/20/2022	0.0189	Off	0.0109	0.0111	0.0110	0.0110	0.0189
7/21/2022	0.0109	0.0111	0.0109	0.0113	Off	Off	0.0113
7/22/2022	Off	Off	Off	Off	Off	0.0109	0.0109
7/23/2022	0.0108	0.0111	0.0108	0.0108	0.0109	0.0111	0.0111
7/24/2022	0.0110	Off	Off	Off	Off	Off	0.0110
7/25/2022	Off	Off	Off	Off	Off	Off	Off
7/26/2022	Off	0.0149	0.0104	0.0103	0.0104	Off	0.0149
7/27/2022	Off	Off	Off	Off	0.0108	0.0104	0.0108
7/28/2022	0.0103	0.0105	0.0104	0.0104	0.0106	0.0104	0.0106
7/29/2022	0.0104	0.0105	0.0104	0.0105	0.0105	0.0104	0.0105
7/30/2022	0.0104	Off	Off	Off	Off	Off	0.0104
7/31/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings \leq 1 NTU? ² Yes/ No

CT's met everyday? (see back)

All Cl2 residual at entry point \geq 0.2 mg/l?

All daily turbidity readings \leq 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **8/2/2022**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: WTP-A

System Name:
Neskowin
Regional Water
District

ID#: 4100970

Month/Year: July-22

Disinfection
Giardia Log
Inactiv:

1.0

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.20	129	154.8	12.5	7.8	44.2	Yes	202
2	1.20	129	154.8	12.5	7.8	44.2	Yes	207
3	1.20	129	154.8	12.6	7.8	43.9	Yes	207
4	1.20	129	154.8	12.5	7.8	44.2	Yes	202
5	1.20	129	154.8	12.6	7.8	43.9	Yes	204
6	1.20	129	154.8	12.9	7.8	43.1	Yes	202
7	1.20	129	154.8	13.0	7.9	44.4	Yes	203
8	Off	129	Off	13.0	7.9	Off	Off	Off
9	1.09	129	140.6	12.9	8.0	45.8	Yes	202
10	1.10	129	141.9	13.4	7.8	41.2	Yes	204
11	1.00	129	129.0	13.3	8.0	44.1	Yes	204
12	1.00	129	129.0	13.2	7.9	42.8	Yes	202
13	1.00	129	129.0	13.2	7.9	42.8	Yes	202
14	1.00	129	129.0	13.2	7.9	42.8	Yes	212
15	Off	129	Off	13.4	7.8	Off	Off	Off
16	1.00	129	129.0	13.5	7.8	40.5	Yes	202
17	0.80	129	103.2	13.3	7.8	40.1	Yes	202
18	0.60	129	77.4	13.4	7.7	37.5	Yes	203
19	Off	129	Off	13.3	7.8	Off	Off	Off
20	1.00	129	129.0	13.2	7.8	41.3	Yes	204
21	0.80	129	103.2	13.1	7.8	40.6	Yes	204
22	0.80	129	103.2	13.2	7.6	37.5	Yes	202
23	1.01	129	130.3	13.0	7.8	41.9	Yes	205
24	1.15	129	148.4	13.0	7.8	42.5	Yes	205
25	Off	129	Off	12.9	7.7	Off	Off	Off
26	0.80	129	103.2	13.3	7.7	38.6	Yes	202
27	0.80	129	103.2	13.3	7.7	38.6	Yes	202
28	0.80	129	103.2	13.4	7.7	38.4	Yes	208
29	0.80	129	103.2	13.3	7.7	38.6	Yes	207
30	1.00	129	129.0	13.7	7.7	38.5	Yes	202
31	Off	129	Off	13.5	7.8	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350