

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Sep-22

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
9/1/2022	0.0122	0.0123	0.0118	0.0119	0.0120	0.0123	0.0123
9/2/2022	0.0126	Off	Off	Off	Off	Off	0.0126
9/3/2022	Off	Off	Off	0.0154	0.0121	0.0122	0.0154
9/4/2022	0.0122	0.0121	0.0122	0.0121	0.0121	0.0122	0.0122
9/5/2022	0.0133	Off	Off	Off	Off	Off	0.0133
9/6/2022	0.0123	0.0121	0.0130	0.0123	0.0123	0.0123	0.0130
9/7/2022	0.0124	Off	Off	Off	Off	Off	0.0124
9/8/2022	Off	Off	Off	Off	Off	Off	Off
9/9/2022	Off	Off	0.0139	0.0122	0.0126	0.0138	0.0139
9/10/2022	0.0130	Off	Off	Off	Off	Off	0.0130
9/11/2022	Off	Off	Off	Off	Off	Off	Off
9/12/2022	Off	Off	Off	Off	Off	Off	Off
9/13/2022	Off	0.0115	0.0115	0.0117	Off	Off	0.0117
9/14/2022	Off	Off	Off	Off	Off	Off	Off
9/15/2022	0.0116	0.0116	0.0116	0.0118	0.0117	0.0116	0.0118
9/16/2022	0.0116	Off	Off	Off	Off	Off	0.0116
9/17/2022	Off	Off	Off	0.0118	0.0117	0.0117	0.0118
9/18/2022	0.0117	0.0117	0.0118	Off	Off	Off	0.0118
9/19/2022	Off	Off	Off	Off	Off	Off	Off
9/20/2022	Off	0.0120	0.0118	0.0118	0.0118	0.0123	0.0123
9/21/2022	0.0125	Off	Off	Off	Off	Off	0.0125
9/22/2022	Off	Off	Off	Off	0.0119	0.0120	0.0120
9/23/2022	0.0122	0.0121	0.0122	0.0134	0.0122	0.0125	0.0134
9/24/2022	0.0125	0.0123	Off	Off	Off	Off	0.0125
9/25/2022	Off	Off	Off	Off	Off	0.0121	0.0121
9/26/2022	0.0123	0.0127	0.0121	0.0134	0.0135	Off	0.0135
9/27/2022	Off	Off	Off	Off	Off	Off	Off
9/28/2022	Off	Off	Off	Off	Off	0.0125	0.0125
9/29/2022	0.0126	Off	Off	Off	Off	Off	0.0126
9/30/2022	Off	Off	Off	Off	Off	Off	Off
10/1/2022	0.0127	Off	Off	Off	Off	Off	0.0127

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?² Yes / No

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE:  DATE: 10/3/2022

PHONE #: (503) 392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: WTP-A

System Name:
Neskowin
Regional Water
District

ID#: 4100970

Month/Year: September-22

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.50	129	64.5	14.2	7.7	17.6	Yes	205
2	0.50	129	64.5	14.0	7.8	18.5	Yes	201
3	1.00	129	129.0	14.0	7.8	19.6	Yes	210
4	1.12	129	144.5	15.0	7.8	18.6	Yes	202
5	0.60	129	77.4	15.0	7.8	17.5	Yes	200
6	1.00	129	129.0	13.9	7.8	19.7	Yes	202
7	0.80	129	103.2	13.8	7.8	19.4	Yes	209
8	Off	129	Off	13.7	7.8	Off	Off	Off
9	1.00	129	129.0	13.9	7.7	19.0	Yes	206
10	1.10	129	141.9	14.3	7.8	19.4	Yes	211
11	Off	129	Off	14.5	7.8	Off	Off	Off
12	Off	129	Off	14.4	8.0	Off	Off	Off
13	0.80	129	103.2	14.3	7.9	19.5	Yes	206
14	Off	129	Off	14.1	7.9	Off	Off	Off
15	1.20	129	154.8	14.0	7.7	19.3	Yes	205
16	1.20	129	154.8	13.9	7.7	19.4	Yes	202
17	1.11	129	143.2	13.8	7.8	20.1	Yes	203
18	1.05	129	135.5	14.0	7.8	19.7	Yes	206
19	Off	129	Off	13.4	7.7	Off	Off	Off
20	1.40	129	180.6	13.3	7.8	21.5	Yes	209
21	1.20	129	154.8	13.3	7.8	21.0	Yes	201
22	1.40	129	180.6	13.4	7.8	21.3	Yes	202
23	1.40	129	180.6	13.5	7.7	20.4	Yes	205
24	1.40	129	180.6	13.6	7.6	19.5	Yes	203
25	1.40	129	180.6	13.1	7.7	21.0	Yes	212
26	1.40	129	180.6	13.2	7.7	20.8	Yes	213
27	Off	129	Off	13.1	7.8	Off	Off	Off
28	1.40	129	180.6	13.1	7.8	21.7	Yes	202
29	1.40	129	180.6	13.1	7.7	21.0	Yes	201
30	Off	129	Off	13.1	7.8	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350