

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook
 Month/Year: Oct-22

System Name: Neskowin Regional Water District ID#: 4100970							WTP : TP -	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]	
10/1/2022	Off	Off	Off	Off	Off	Off	Off	
10/2/2022	Off	Off	Off	Off	Off	Off	Off	
10/3/2022	0.0121	0.0122	0.0122	0.0122	0.0134	0.0132	0.0134	
10/4/2022	0.0128	0.0127	0.0128	0.0127	0.0128	0.0129	0.0129	
10/5/2022	0.0132	0.0130	0.0138	0.0137	0.0131	0.0129	0.0138	
10/6/2022	Off	Off	Off	Off	Off	Off	Off	
10/7/2022	Off	Off	Off	Off	Off	Off	Off	
10/8/2022	0.0123	0.0122	0.0124	0.0126	0.0127	0.0137	0.0137	
10/9/2022	0.0130	0.0129	Off	Off	Off	Off	0.0130	
10/10/2022	Off	Off	Off	Off	Off	Off	Off	
10/11/2022	Off	Off	0.0123	0.0124	0.0128	0.0143	0.0143	
10/12/2022	Off	Off	Off	0.0220	0.0129	Off	0.0220	
10/13/2022	Off	Off	Off	Off	0.0117	0.0117	0.0117	
10/14/2022	0.0117	Off	Off	0.0117	0.0117	Off	0.0117	
10/15/2022	Off	Off	Off	Off	Off	Off	Off	
10/16/2022	Off	Off	Off	Off	Off	Off	Off	
10/17/2022	Off	Off	0.0128	0.0117	0.0117	0.0117	0.0128	
10/18/2022	0.0118	0.0117	0.0118	0.0120	0.0117	0.0118	0.0120	
10/19/2022	Off	Off	Off	Off	Off	Off	Off	
10/20/2022	Off	Off	Off	0.0118	Off	Off	0.0118	
10/21/2022	0.0118	0.0117	0.0122	0.0119	0.0124	0.0120	0.0124	
10/22/2022	0.0119	Off	Off	Off	0.0121	0.0119	0.0121	
10/23/2022	Off	Off	Off	Off	Off	Off	Off	
10/24/2022	Off	Off	Off	Off	Off	Off	Off	
10/25/2022	Off	Off	Off	Off	Off	Off	Off	
10/26/2022	Off	Off	0.0132	0.0118	0.0118	0.0118	0.0132	
10/27/2022	0.0118	0.0118	0.0118	0.0118	Off	Off	0.0118	
10/28/2022	Off	Off	Off	Off	0.0226	0.0119	0.0226	
10/29/2022	0.0120	0.0121	Off	Off	Off	Off	0.0121	
10/30/2022	Off	Off	Off	Off	Off	Off	Off	
10/31/2022	Off	Off	Off	0.0123	0.0121	0.0125	0.0125	

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE: 

DATE: 11/3/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:
Neskowin
Regional Water
District

ID#: 4100970

Month/Year: October-22

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	13.0	7.7	Off	Off	Off
2	Off	129	Off	13.0	7.8	Off	Off	Off
3	1.00	129	129.0	13.3	7.7	19.8	Yes	211
4	0.80	129	103.2	13.1	7.7	19.6	Yes	208
5	0.80	129	103.2	13.0	7.7	19.7	Yes	210
6	Off	129	Off	13.1	7.8	Off	Off	Off
7	Off	129	Off	13.0	7.7	Off	Off	Off
8	0.80	129	103.2	12.9	7.6	19.1	Yes	209
9	0.80	129	103.2	12.7	7.6	19.4	Yes	210
10	Off	129	Off	12.9	7.7	Off	Off	Off
11	0.80	129	103.2	12.8	7.7	20.0	Yes	203
12	0.80	129	103.2	12.6	7.7	20.2	Yes	202
13	0.80	129	103.2	12.4	7.7	20.6	Yes	202
14	0.80	129	103.2	12.5	7.7	20.4	Yes	201
15	Off	129	Off	12.0	7.8	Off	Off	Off
16	Off	129	Off	12.0	7.7	Off	Off	Off
17	0.70	129	90.3	12.7	7.7	19.9	Yes	202
18	0.80	129	103.2	12.6	7.7	20.2	Yes	205
19	Off	129	Off	12.3	7.7	Off	Off	Off
20	0.80	129	103.2	12.1	7.7	21.0	Yes	209
21	0.80	129	103.2	12.0	7.7	21.1	Yes	210
22	0.60	129	77.4	11.6	7.7	21.2	Yes	201
23	Off	129	Off	11.7	7.5	Off	Off	Off
24	Off	129	Off	11.7	7.5	Off	Off	Off
25	Off	129	Off	11.7	7.6	Off	Off	Off
26	0.50	129	64.5	11.2	7.5	20.1	Yes	209
27	0.60	129	77.4	12.0	7.5	19.3	Yes	201
28	0.68	129	87.7	12.0	7.8	21.6	Yes	204
29	0.72	129	92.9	12.0	7.7	20.9	Yes	201
30	Off	129	Off	12.0	7.8	Off	Off	Off
31	0.50	129	64.5	11.4	7.5	19.8	Yes	205

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350