

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**
 Month/Year: **May-23**

System Name: Neskowin Regional Water District ID#: 4100970		WTP: TP - WTP-A					
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
5/1/2023	0.0129	0.0128	0.0136	0.0128	0.0129	0.0130	0.0136
5/2/2023	Off	Off	Off	Off	Off	Off	Off
5/3/2023	Off	Off	Off	Off	Off	Off	Off
5/4/2023	Off	Off	Off	Off	Off	Off	Off
5/5/2023	Off	0.0128	0.0129	0.0129	Off	Off	0.0129
5/6/2023	0.0123	0.0123	0.0124	0.0124	0.0124	Off	0.0124
5/7/2023	Off	Off	Off	Off	Off	Off	Off
5/8/2023	Off	Off	Off	Off	0.0130	0.0130	0.0130
5/9/2023	0.0129	0.0129	0.0129	0.0129	Off	Off	0.0129
5/10/2023	Off	Off	Off	Off	Off	Off	Off
5/11/2023	Off	Off	Off	Off	Off	Off	Off
5/12/2023	0.0141	0.0132	0.0130	0.0136	0.0130	0.0135	0.0141
5/13/2023	0.0131	Off	Off	Off	Off	Off	0.0131
5/14/2023	Off	Off	Off	Off	0.0131	0.0131	0.0131
5/15/2023	0.0131	Off	0.0135	0.0136	0.0133	0.0132	0.0136
5/16/2023	0.0133	0.0132	Off	Off	Off	Off	0.0133
5/17/2023	Off	Off	Off	Off	Off	Off	Off
5/18/2023	Off	Off	0.0151	0.0134	0.0131	0.0138	0.0151
5/19/2023	0.0131	0.0134	0.0131	Off	Off	Off	0.0134
5/20/2023	Off	Off	Off	Off	Off	Off	Off
5/21/2023	Off	Off	0.0136	0.0130	0.0134	0.0131	0.0136
5/22/2023	0.0137	0.0131	0.0131	Off	Off	Off	0.0137
5/23/2023	Off	Off	Off	Off	Off	Off	Off
5/24/2023	Off	Off	0.0131	0.0132	0.0131	0.0138	0.0138
5/25/2023	0.0132	0.0131	Off	Off	Off	Off	0.0132
5/26/2023	Off	Off	Off	Off	0.0140	0.0131	0.0140
5/27/2023	0.0131	0.0131	0.0132	0.0132	0.0133	Off	0.0133
5/28/2023	Off	Off	Off	Off	Off	Off	Off
5/29/2023	Off	Off	Off	Off	0.0127	0.0126	0.0127
5/30/2023	0.0127	0.0127	0.0129	0.0126	0.0126	0.0126	0.0129
5/31/2023	0.0127	0.0127	0.0128	0.0126	Off	Off	0.0128

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: **6/6/2023**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: May-23	Disinfection Giardia Log Inactiv: 0.5
--	--------------	--------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	129	129.0	10.0	8.0	27.5	Yes	202
2	Off	129	Off	10.0	8.0	Off	Off	Off
3	Off	129	Off	10.0	8.0	Off	Off	Off
4	Off	129	Off	10.0	8.0	Off	Off	Off
5	1.00	129	129.0	10.0	8.0	27.5	Yes	201
6	1.20	129	154.8	10.0	8.0	28.1	Yes	202
7	Off	129	Off	10.0	8.0	Off	Off	Off
8	1.10	129	141.9	10.0	8.0	27.8	Yes	205
9	1.10	129	141.9	10.0	8.0	27.8	Yes	201
10	Off	129	Off	10.0	8.0	Off	Off	Off
11	Off	129	Off	10.0	8.0	Off	Off	Off
12	1.30	129	167.7	10.0	8.0	28.4	Yes	202
13	1.15	129	148.4	10.0	7.9	27.0	Yes	201
14	1.09	129	140.6	10.0	7.9	26.8	Yes	201
15	1.11	129	143.2	11.0	8.0	26.0	Yes	201
16	1.19	129	153.5	11.0	8.0	26.2	Yes	201
17	Off	129	Off	11.0	8.0	Off	Off	Off
18	1.19	129	153.5	11.0	8.0	26.2	Yes	201
19	1.20	129	154.8	12.0	8.0	24.6	Yes	201
20	Off	129	Off	12.0	8.0	Off	Off	Off
21	1.15	129	148.4	12.0	8.0	24.4	Yes	202
22	1.19	129	153.5	11.0	8.0	26.2	Yes	201
23	Off	129	Off	11.0	8.0	Off	Off	Off
24	0.80	129	103.2	11.0	8.0	25.1	Yes	201
25	0.80	129	103.2	11.0	8.0	25.1	Yes	201
26	0.80	129	103.2	11.0	8.0	25.1	Yes	201
27	1.21	129	156.1	12.0	8.0	24.6	Yes	201
28	Off	129	Off	12.0	8.0	Off	Off	Off
29	1.01	129	130.3	12.0	8.0	24.0	Yes	202
30	0.60	129	77.4	11.0	8.0	24.5	Yes	201
31	0.80	129	103.2	11.0	8.0	25.1	Yes	201

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350