

Membrane Filter Monthly Operating Report

County: Tillamook

System Name: Neskowin Regional Water District

Month/Year: Sep-2025

PWS ID#: 41 - 00970

Minimum test pressure applied || req'd: 16.0 psi || 11.3 psi

Plant ID: WTP - A (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [psi/min]

LRC [log removal]

0.910

4.00


DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.013	0.01312	0.013	0.66	4.09	Y
2	0.013	0.01334	0.013	0.67	4.10	Y
3	0.013	0.0131	0.013	0.67	4.09	Y
4	Off	Off	Off	Off	Off	Off
5	0.012	0.01256	0.013	0.66	4.09	Y
6	0.013	0.01357	0.014	0.66	4.09	Y
7	Off	Off	Off	Off	Off	Off
8	0.013	0.013	0.013	0.66	4.10	Y
9	0.014	0.01935	0.019	0.66	4.09	Y
10	0.013	0.01287	0.013	0.66	4.07	Y
11	0.013	0.01313	0.013	0.66	4.08	Y
12	0.013	0.01292	0.013	0.66	4.08	Y
13	Off	Off	Off	Off	Off	Off
14	0.013	0.0137	0.014	0.66	4.06	Y
15	0.013	0.01331	0.013	0.66	4.06	Y
16	Off	Off	Off	Off	Off	Off
17	0.013	0.01325	0.013	0.66	4.12	Y
18	Off	Off	Off	Off	Off	Off
19	0.013	0.01292	0.013	0.66	4.12	Y
20	0.013	0.01287	0.013	0.66	4.12	Y
21	0.013	0.01284	0.013	0.66	4.12	Y
22	Off	Off	Off	Off	Off	Off
23	0.013	0.0132	0.013	0.76	4.12	Y
24	0.013	0.01267	0.013	0.77	4.12	Y
25	Off	Off	Off	Off	Off	Off
26	Off	Off	Off	Off	Off	Off
27	0.013	0.01275	0.013	0.77	4.12	Y
28	Off	Off	Off	Off	Off	Off
29	Off	Off	Off	Off	Off	Off
30	0.013	0.01326	0.013	0.77	4.12	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: Troy N. Trute

SIGNATURE: 

Notes:

DATE: 10/7/2025

WT CERT #: D-08123 T-08076

PHONE #: 541-992-1655

p. 1 of 2

Disinfection Monthly Operating Report

System Name: **Neskowin Regional Water District**PWS ID#: 41 - **00970**Plant ID : WTP - **A****0.5**

↩ Log
Inactivation
Required via
Disinfection

Day		Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.700	129	90.3	16.0	7.70	16.0	YES	262	
2	0.700	129	90.3	16.0	7.80	16.6	YES	263	
3	0.720	129	92.9	16.0	7.70	16.0	YES	261	
4	Off	129	Off	16.0	7.80	Off	Off	Off	Plant Off
5	0.600	129	77.4	16.0	7.80	16.4	YES	260	
6	0.690	129	89.0	15.0	7.70	17.0	YES	262	
7	Off	129	Off	15.0	7.70	Off	Off	Off	Plant Off
8	0.600	129	77.4	16.0	7.80	16.4	YES	261	
9	0.600	129	77.4	16.0	7.80	16.4	YES	261	
10	0.700	129	90.3	16.0	7.80	16.6	YES	258	
11	0.600	129	77.4	16.0	7.80	16.4	YES	262	
12	0.600	129	77.4	15.0	7.80	17.5	YES	260	
13	Off	129	Off	16.0	7.70	Off	Off	Off	Plant Off
14	0.700	129	90.3	15.0	7.70	17.1	YES	270	
15	0.700	129	90.3	15.0	7.80	17.7	YES	263	
16	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
17	0.600	129	77.4	15.0	7.80	17.5	YES	261	
18	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
19	0.700	129	90.3	15.0	7.80	17.7	YES	260	
20	0.700	129	90.3	15.0	7.80	17.7	YES	261	
21	0.700	129	90.3	15.0	7.80	17.7	YES	261	
22	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
23	1.200	129	154.8	15.0	7.80	18.7	YES	262	
24	1.000	129	129.0	15.0	7.80	18.3	YES	264	
25	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
26	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
27	0.600	129	77.4	15.0	7.80	17.5	YES	262	
28	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
29	Off	129	Off	15.0	7.80	Off	Off	Off	Plant Off
30	0.700	129	90.3	15.0	7.80	17.7	YES	261	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350
email: dwp.dmce@odhsoha.oregon.gov
fax: 971-673-0458