

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: **Neskowin Regional Water District**

County: **Tillamook**

PWS ID#: **41 - 00970**

Month/Year: **Nov-2025**

Minimum test pressure applied || req'd: **16.0** psi || **11.3** p

Plant ID: **WTP - A** (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [psi/min]

LRC [log removal]

0.910

4.00

DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	Off	Off	Off	Off	Off	Off
2	Off	Off	Off	Off	Off	Off
3	Off	Off	Off	Off	Off	Off
4	0.013	0.01267	0.013	0.40	4.31	Y
5	0.013	0.01303	0.013	0.40	4.37	Y
6	Off	Off	Off	Off	Off	Off
7	0.013	0.0133	0.013	0.40	4.37	Y
8	Off	Off	Off	Off	Off	Off
9	Off	Off	Off	Off	Off	Off
10	0.014	0.01363	0.014	0.40	4.39	Y
11	0.014	0.01363	0.014	0.40	4.39	Y
12	Off	Off	Off	Off	Off	Off
13	Off	Off	Off	Off	Off	Off
14	0.013	0.01346	0.013	0.40	4.38	Y
15	0.013	0.01325	0.013	0.40	4.37	Y
16	0.013	0.01352	0.014	0.40	4.36	Y
17	0.014	0.01353	0.014	0.40	4.31	Y
18	Off	Off	Off	Off	Off	Off
19	0.013	0.01354	0.014	0.40	4.34	Y
20	Off	Off	Off	Off	Off	Off
21	Off	Off	Off	Off	Off	Off
22	0.013	0.01288	0.013	0.40	4.36	Y
23	0.013	0.01288	0.013	0.40	4.36	Y
24	Off	Off	Off	Off	Off	Off
25	Off	Off	Off	Off	Off	Off
26	0.013	0.01332	0.013	0.40	4.34	Y
27	0.013	0.01309	0.013	0.40	4.31	Y
28	Off	Off	Off	Off	Off	Off
29	0.013	0.01331	0.013	0.40	4.31	Y
30	0.013	0.01287	0.013	0.40	4.35	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: **Troy N. Trute**

DATE: **12/5/2025**

SIGNATURE:

WT CERT #:

D-08123 T-08076

Notes:

PHONE #:

541-992-1655

p. 1 of 2

Disinfection Monthly Operating Report

System Name: **Neskowin Regional Water District**PWS ID#: 41 - **00970**Plant ID : WTP - **A****0.5**Log
Inactivation
Required via
Disinfection

Day		Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
2	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
3	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
4	0.800	129	103.2	13.0	7.70	19.7	YES	261	
5	0.900	129	116.1	13.0	7.70	19.9	YES	261	
6	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
7	0.800	129	103.2	13.0	7.70	19.7	YES	261	
8	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
9	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
10	0.800	129	103.2	13.0	7.70	19.7	YES	260	
11	0.800	129	103.2	13.0	7.70	19.7	YES	95	
12	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
13	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
14	0.700	129	90.3	13.0	7.70	19.5	YES	260	
15	0.850	129	109.7	13.0	7.70	19.8	YES	261	
16	0.810	129	104.5	13.0	7.80	20.5	YES	260	
17	0.800	129	103.2	13.0	7.60	19.0	YES	172	
18	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
19	0.700	129	90.3	13.0	7.70	19.5	YES	261	
20	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
21	Off	129	Off	13.0	7.70	Off	Off	Off	Plant Off
22	0.800	129	103.2	13.0	7.70	19.7	YES	259	
23	0.900	129	116.1	12.0	7.70	21.4	YES	245	
24	Off	129	Off	12.0	7.70	Off	Off	Off	Plant Off
25	Off	129	Off	12.0	7.70	Off	Off	Off	Plant Off
26	0.900	129	116.1	12.0	7.70	21.4	YES	262	
27	0.800	129	103.2	12.0	7.80	21.9	YES	263	
28	Off	129	Off	12.0	7.80	Off	Off	Off	Plant Off
29	0.750	129	96.8	12.0	7.80	21.8	YES	261	
30	0.800	129	103.2	12.0	7.80	21.9	YES	262	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458