

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**
 Month/Year: **Feb-21**

System Name: Neskowin Regional Water District ID#: 4100970		WTP : TP -		WTP-A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
2/1/2021	Off	Off	Off	Off	Off	Off	Off
2/2/2021	Off	Off	Off	Off	0.0154	0.0131	0.0154
2/3/2021	0.0131	0.0130	0.0130	0.0128	Off	Off	0.0131
2/4/2021	Off	Off	Off	Off	Off	Off	Off
2/5/2021	Off	Off	Off	Off	Off	Off	Off
2/6/2021	0.0171	0.0129	0.0137	0.0129	0.0129	0.0128	0.0171
2/7/2021	0.0131	Off	Off	Off	Off	Off	0.0131
2/8/2021	Off	Off	Off	Off	Off	0.0128	0.0128
2/9/2021	0.0128	0.0126	0.0132	Off	Off	Off	0.0132
2/10/2021	Off	Off	Off	Off	Off	Off	Off
2/11/2021	Off	Off	Off	0.0154	0.0137	0.0133	0.0154
2/12/2021	0.0132	0.0131	0.0135	Off	Off	Off	0.0135
2/13/2021	Off	Off	Off	Off	Off	Off	Off
2/14/2021	Off	Off	Off	Off	0.0141	0.0135	0.0141
2/15/2021	0.0136	0.0136	0.0135	Off	Off	Off	0.0136
2/16/2021	Off	Off	0.0167	0.0134	0.0133	0.0134	0.0167
2/17/2021	0.0134	0.0132	0.0135	0.0132	Off	Off	0.0135
2/18/2021	Off	Off	Off	Off	Off	Off	Off
2/19/2021	Off	Off	0.0133	0.0134	0.0131	0.0131	0.0134
2/20/2021	0.0136	0.0134	Off	Off	Off	Off	0.0136
2/21/2021	Off	Off	Off	Off	0.0134	0.0134	0.0134
2/22/2021	0.0133	0.0133	Off	Off	Off	Off	0.0133
2/23/2021	Off	Off	Off	Off	Off	Off	Off
2/24/2021	Off	Off	0.0176	0.0133	0.0132	0.0132	0.0176
2/25/2021	0.0129	0.0130	0.0132	0.0131	0.0130	0.0129	0.0132
2/26/2021	Off	Off	Off	Off	Off	Off	Off
2/27/2021	Off	Off	Off	0.0138	0.0131	0.0130	0.0138
2/28/2021	0.0134	0.0131	0.0130	0.0130	Off	Off	0.0134

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **3/8/2021**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:
Neskowin
Regional Water
District

ID#: 4100970

Month/Year: February-21

Disinfection
Giardia Log
Inactive:

1.0

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	8.0	7.7	Off	Off	Off
2	1.6	129	206.4	8.2	7.9	64.2	Yes	202
3	1.1	129	141.9	8.0	7.9	61.4	Yes	225
4	Off	129	Off	8.0	7.9	Off	Off	Off
5	Off	129	Off	8.0	7.8	Off	Off	Off
6	1.4	129	180.6	8.0	7.8	61.3	Yes	202
7	1.1	129	141.9	9.0	7.8	55.3	Yes	200
8	1	129	129.0	9.0	7.8	54.7	Yes	202
9	1	129	129.0	9.0	7.7	52.8	Yes	203
10	Off	129	Off	9.0	7.8	Off	Off	Off
11	1	129	129.0	9.0	7.7	52.8	Yes	204
12	1.1	129	141.9	9.0	7.7	53.4	Yes	201
13	Off	129	Off	9.0	7.8	Off	Off	Off
14	1.2	129	154.8	9.0	7.8	56.0	Yes	214
15	1.1	129	141.9	9.0	7.8	55.3	Yes	202
16	0.9	129	116.1	9.0	7.8	54.1	Yes	204
17	0.8	129	103.2	8.0	7.7	55.1	Yes	210
18	Off	129	Off	8.0	7.8	Off	Off	Off
19	0.8	129	103.2	8.0	7.9	59.3	Yes	217
20	1.1	129	141.9	8.0	7.8	59.2	Yes	204
21	1	129	129.0	8.0	7.8	58.5	Yes	206
22	0.8	129	103.2	9.0	7.7	51.6	Yes	203
23	Off	129	Off	9.0	7.8	Off	Off	Off
24	0.6	129	77.4	8.0	7.6	52.0	Yes	202
25	0.6	129	77.4	9.0	7.7	50.4	Yes	243
26	Off	129	Off	9.0	7.6	Off	Off	Off
27	1	129	129.0	8.0	7.7	56.4	Yes	252
28	1.1	129	141.9	9.0	7.7	53.4	Yes	206

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350