

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Tillamook**

Month/Year: **May-21**

System Name: <b>Neskowin Regional Water District ID#: 4100970</b>		WTP: <b>TP - WTP-A</b>					
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
5/1/2021	0.0127	0.0127	0.0126	0.0125	0.0128	Off	0.0128
5/2/2021	Off	Off	Off	Off	Off	Off	Off
5/3/2021	Off	Off	Off	0.0173	0.0126	0.0126	0.0173
5/4/2021	0.0128	0.0130	Off	Off	Off	Off	0.0130
5/5/2021	Off	Off	Off	Off	Off	Off	Off
5/6/2021	Off	Off	Off	0.0129	0.0129	0.0132	0.0132
5/7/2021	0.0129	0.0128	0.0128	Off	Off	Off	0.0129
5/8/2021	Off	Off	Off	Off	Off	Off	Off
5/9/2021	Off	0.0130	0.0132	0.0128	0.0125	0.0126	0.0132
5/10/2021	0.0127	Off	Off	Off	Off	Off	0.0127
5/11/2021	Off	Off	Off	Off	Off	Off	Off
5/12/2021	0.0138	0.0127	0.0126	0.0127	0.0126	0.0126	0.0138
5/13/2021	Off	Off	Off	Off	Off	Off	Off
5/14/2021	Off	Off	Off	Off	Off	0.0168	0.0168
5/15/2021	0.0128	0.0127	0.0127	0.0127	0.0129	0.0127	0.0129
5/16/2021	Off	Off	Off	Off	Off	Off	Off
5/17/2021	Off	Off	Off	Off	0.0127	0.0128	0.0128
5/18/2021	0.0131	0.0129	0.0129	Off	Off	Off	0.0131
5/19/2021	Off	Off	Off	Off	Off	0.0193	0.0193
5/20/2021	0.0129	0.0128	0.0129	0.0128	0.0131	Off	0.0131
5/21/2021	Off	Off	Off	Off	Off	Off	Off
5/22/2021	Off	Off	Off	Off	0.0129	0.0129	0.0129
5/23/2021	0.0129	0.0129	0.0133	0.0130	0.0132	Off	0.0133
5/24/2021	Off	Off	Off	Off	Off	Off	Off
5/25/2021	Off	Off	Off	Off	Off	Off	Off
5/26/2021	Off	Off	Off	Off	0.0127	0.0128	0.0128
5/27/2021	0.0128	0.0127	0.0127	0.0127	0.0129	0.0127	0.0129
5/28/2021	0.0128	0.0130	Off	Off	Off	Off	0.0130
5/29/2021	0.0138	0.0127	0.0126	0.0127	0.0126	0.0126	0.0138
5/30/2021	Off	Off	Off	0.0127	0.0123	0.0125	0.0127
5/31/2021	0.0129	0.0125	0.0123	0.0123	0.0128	0.0126	0.0129

**Slow Sand/Membrane/DE Filtration/Unfiltered**

**Monthly Summary (Answer Yes or No)**

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>  Yes/ No

CT's met everyday? (see back)  Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes/ No

All daily turbidity readings ≤ 5 NTU?  Yes/ No

Yes/ No

Yes/ No

**Notes:**

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **6/9/2021**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:  
Neskowin  
Regional Water  
District

ID#: 4100970

Month/Year: May-21

Disinfection  
Giardia Log  
Inactiv:

1.0

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	129	103.2	12.0	7.6	40.8	Yes	210
2	Off	129	Off	12.0	7.7	Off	Off	Off
3	0.9	129	116.1	12.0	7.8	44.3	Yes	205
4	1.1	129	141.9	11.0	7.9	50.1	Yes	208
5	Off	129	Off	11.0	8.0	Off	Off	Off
6	1	129	129.0	11.0	7.8	47.8	Yes	204
7	1.2	129	154.8	11.0	7.8	48.9	Yes	205
8	Off	129	Off	11.0	7.8	Off	Off	Off
9	1.19	129	153.5	11.0	7.8	48.9	Yes	203
10	1.1	129	141.9	11.2	7.7	46.1	Yes	207
11	Off	129	Off	11.1	7.8	Off	Off	Off
12	1	129	129.0	11.2	7.7	45.6	Yes	205
13	Off	129	Off	11.1	7.7	Off	Off	Off
14	0.9	129	116.1	12.0	7.7	42.7	Yes	206
15	1.2	129	154.8	10.9	7.9	51.0	Yes	204
16	Off	129	Off	10.9	7.7	Off	Off	Off
17	0.9	129	116.1	11.0	7.7	45.6	Yes	202
18	1.1	129	141.9	10.9	7.9	50.5	Yes	202
19	1	129	129.0	10.8	7.9	50.2	Yes	201
20	1	129	129.0	10.7	7.9	50.6	Yes	204
21	Off	129	Off	11.0	7.8	Off	Off	Off
22	0.9	129	116.1	11.0	7.7	45.6	Yes	202
23	0.9	129	116.1	12.0	7.7	42.7	Yes	204
24	Off	129	Off	11.1	7.7	Off	Off	Off
25	Off	129	Off	11.1	7.8	Off	Off	Off
26	1	129	129.0	11.2	7.8	47.2	Yes	202
27	1	129	129.0	11.4	7.8	46.6	Yes	204
28	0.8	129	103.2	11.5	7.6	42.2	Yes	208
29	1.05	129	135.5	12.0	7.8	45.0	Yes	205
30	0.97	129	125.1	12.0	7.8	44.6	Yes	202
31	1.11	129	143.2	12.0	7.8	45.3	Yes	203

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350