

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Sep-21

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
9/1/2021	Off	0.0127	0.0125	0.0124	0.0124	0.0128	0.0128
9/2/2021	Off	Off	Off	Off	Off	Off	Off
9/3/2021	Off	0.0126	0.0126	0.0126	0.0126	0.0126	0.0126
9/4/2021	0.0127	Off	Off	Off	Off	Off	0.0127
9/5/2021	Off	0.0126	0.0126	0.0125	0.0127	0.0125	0.0127
9/6/2021	0.0126	0.0126	0.0126	Off	Off	Off	0.0126
9/7/2021	Off	0.0126	0.0126	0.0128	0.0125	0.0125	0.0128
9/8/2021	Off	Off	Off	Off	Off	Off	Off
9/9/2021	Off	Off	Off	0.0129	0.0125	0.0127	0.0129
9/10/2021	0.0126	0.0126	0.0126	0.0127	0.0127	Off	0.0127
9/11/2021	Off	Off	Off	Off	Off	Off	Off
9/12/2021	0.0176	0.0126	0.0127	0.0130	0.0126	0.0127	0.0176
9/13/2021	0.0127	Off	Off	Off	0.0126	0.0129	0.0129
9/14/2021	Off	Off	Off	0.0135	0.0126	0.0130	0.0135
9/15/2021	Off	Off	Off	Off	Off	0.0150	0.0150
9/16/2021	Off	Off	0.0127	0.0126	0.0128	0.0129	0.0129
9/17/2021	0.0128	0.0127	Off	0.0130	Off	Off	0.0130
9/18/2021	Off	Off	Off	Off	Off	Off	Off
9/19/2021	Off	Off	Off	0.0129	0.0127	0.0136	0.0136
9/20/2021	0.0129	0.0129	Off	Off	Off	Off	0.0129
9/21/2021	Off	Off	Off	0.0130	0.0128	0.0131	0.0131
9/22/2021	0.0134	0.0130	Off	Off	Off	Off	0.0134
9/23/2021	Off	Off	Off	0.0128	Off	Off	0.0128
9/24/2021	Off	Off	Off	Off	0.0123	0.0123	0.0123
9/25/2021	0.0135	0.0131	0.0128	Off	Off	0.0127	0.0135
9/26/2021	0.0128	0.0129	0.0129	Off	Off	Off	0.0129
9/27/2021	Off	Off	Off	Off	Off	Off	Off
9/28/2021	Off	Off	Off	Off	Off	Off	Off
9/29/2021	Off	Off	Off	0.0137	Off	0.0139	0.0139
9/30/2021	0.0137	0.0137	0.0137	0.0137	Off	Off	0.0137

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings \leq 1 NTU?² Yes / No

CT's met everyday? (see back)

All Cl2 residual at entry point \geq 0.2 mg/l?

All daily turbidity readings \leq 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE: 

DATE: 10/5/2021

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : WTP-A
 Disinfection
Giardia Log
 Inactiv: 1.0

System Name: Neskowin
 Regional Water District
 ID#: 4100970
 Month/Year: September-21

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.2	129	154.8	12.8	7.6	40.3	Yes	237
2	Off	129	Off	12.8	7.6	Off	Off	Off
3	1.2	129	154.8	12.7	7.6	40.5	Yes	226
4	0.7	129	90.3	15.2	8.0	37.6	Yes	201
5	0.8	129	103.2	14.3	8.0	40.4	Yes	231
6	0.7	129	90.3	14.0	8.1	42.3	Yes	203
7	0.8	129	103.2	15.2	8.1	39.5	Yes	208
8	Off	129	Off	14.4	8.1	Off	Off	Off
9	0.7	129	90.3	15.9	8.0	35.9	Yes	232
10	0.8	129	103.2	16.2	8.0	35.6	Yes	202
11	Off	129	Off	14.8	7.7	Off	Off	Off
12	1.01	129	130.3	15.0	7.8	36.7	Yes	209
13	0.6	129	77.4	14.6	7.7	34.6	Yes	207
14	0.6	129	77.4	15.2	7.9	35.8	Yes	233
15	0.5	129	64.5	16.0	7.7	31.2	Yes	203
16	0.4	129	51.6	13.9	8.0	39.6	Yes	204
17	0.5	129	64.5	13.6	7.9	39.4	Yes	204
18	Off	129	Off	15.0	7.9	Off	Off	Off
19	0.5	129	64.5	13.5	7.8	38.2	Yes	205
20	0.4	129	51.6	14.3	7.8	35.8	Yes	201
21	0.5	129	64.5	13.2	7.2	31.3	Yes	205
22	0.6	129	77.4	13.5	7.3	32.2	Yes	204
23	0.5	129	64.5	13.3	7.2	31.0	Yes	211
24	0.5	129	64.5	13.4	7.2	30.8	Yes	205
25	0.5	129	64.5	14.9	7.9	36.2	Yes	203
26	0.5	129	64.5	14.0	7.7	35.6	Yes	213
27	Off	129	Off	13.6	7.2	Off	Off	Off
28	Off	129	Off	13.5	7.2	Off	Off	Off
29	0.5	129	64.5	13.4	7.3	32.0	Yes	257
30	0.7	129	90.3	13.3	7.3	33.0	Yes	252

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350