

OHA - Drinking Water Program - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Oct-21

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
10/1/2021	Off	Off	Off	Off	Off	Off	Off
10/2/2021	Off	Off	Off	0.0137	0.0135	0.0137	0.0137
10/3/2021	0.0136	0.0135	0.0135	0.0135	Off	Off	0.0136
10/4/2021	Off	Off	Off	Off	Off	Off	Off
10/5/2021	Off	Off	Off	Off	Off	Off	Off
10/6/2021	Off	Off	Off	0.0138	0.0134	0.0134	0.0138
10/7/2021	0.0135	0.0134	0.0154	0.0133	0.0133	Off	0.0154
10/8/2021	Off	Off	Off	Off	Off	Off	Off
10/9/2021	Off	Off	Off	Off	0.0134	0.0134	0.0134
10/10/2021	0.0134	0.0137	0.0137	0.0137	Off	Off	0.0137
10/11/2021	Off	Off	0.0158	0.0135	Off	Off	0.0158
10/12/2021	Off	Off	Off	Off	Off	Off	Off
10/13/2021	Off	Off	Off	Off	Off	0.0136	0.0136
10/14/2021	0.0134	0.0134	0.0142	0.0136	Off	Off	0.0142
10/15/2021	Off	Off	Off	Off	Off	Off	Off
10/16/2021	Off	Off	Off	0.0135	0.0135	0.0138	0.0138
10/17/2021	0.0109	Off	Off	Off	Off	Off	0.0109
10/18/2021	Off	Off	Off	Off	Off	0.0152	0.0152
10/19/2021	0.0130	0.0107	0.0108	0.0113	Off	Off	0.0130
10/20/2021	Off	Off	Off	Off	Off	Off	Off
10/21/2021	Off	Off	Off	Off	0.0160	0.0140	0.0160
10/22/2021	0.0132	0.0132	0.0139	Off	Off	Off	0.0139
10/23/2021	Off	Off	Off	Off	Off	Off	Off
10/24/2021	Off	Off	Off	0.0127	0.0147	Off	0.0147
10/25/2021	Off	Off	Off	Off	Off	Off	Off
10/26/2021	Off	Off	0.0195	0.0135	0.0122	0.0129	0.0195
10/27/2021	0.0122	0.0144	0.0144	0.0132	Off	Off	0.0144
10/28/2021	Off	Off	Off	Off	Off	Off	Off
10/29/2021	Off	Off	Off	Off	Off	0.0145	0.0145
10/30/2021	0.0138	0.0132	0.0132	0.0141	Off	Off	0.0141
10/31/2021	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>  Yes/ No

CT's met everyday? (see back)  Yes/ No

All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l?  Yes/ No

All daily turbidity readings ≤ 5 NTU?  Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE: 

DATE: 11/1/2021

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:  
Neskowin  
Regional Water  
District

ID#: 4100970

Month/Year: October-21

Disinfection  
Giardia Log  
Inactiv:

1.0

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	13.0	7.2	Off	Off	Off
2	0.89	129	114.8	12.8	7.6	38.9	Yes	242
3	1.11	129	143.2	13.0	7.5	37.9	Yes	205
4	Off	129	Off	12.3	7.2	Off	Off	Off
5	Off	129	Off	14.0	7.8	Off	Off	Off
6	0.6	129	77.4	14.6	7.8	35.9	Yes	205
7	0.7	129	90.3	12.6	7.8	41.5	Yes	206
8	Off	129	Off	13.0	7.7	Off	Off	Off
9	1.09	129	140.6	12.9	7.6	39.5	Yes	257
10	1.15	129	148.4	13.5	7.6	38.2	Yes	251
11	0.5	129	64.5	9.2	8.0	54.7	Yes	230
12	Off	129	Off	9.9	8.0	Off	Off	Off
13	0.5	129	64.5	8.1	8.0	58.9	Yes	236
14	0.5	129	64.5	11.3	8.0	47.5	Yes	224
15	Off	129	Off	12.1	7.8	Off	Off	Off
16	0.5	129	64.5	11.9	7.8	42.6	Yes	242
17	0.5	129	64.5	11.4	7.8	44.0	Yes	201
18	0.7	129	90.3	11.6	7.8	44.4	Yes	207
19	0.5	129	64.5	13.0	7.7	38.1	Yes	245
20	Off	129	Off	14.0	7.7	Off	Off	Off
21	0.5	129	64.5	12.8	7.8	40.1	Yes	229
22	0.4	129	51.6	11.6	8.0	46.1	Yes	202
23	Off	129	Off	11.0	7.8	Off	Off	Off
24	0.9	129	116.1	10.8	7.8	47.9	Yes	244
25	Off	129	Off	11.0	7.8	Off	Off	Off
26	0.6	129	77.4	11.3	7.2	36.4	Yes	204
27	0.5	129	64.5	11.4	7.2	35.7	Yes	205
28	Off	129	Off	11.5	7.3	Off	Off	Off
29	0.6	129	77.4	12.0	7.6	39.9	Yes	202
30	0.8	129	103.2	11.5	7.2	36.7	Yes	228
31	Off	129	Off	11.1	7.5	Off	Off	Off

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350