

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Dec-21

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
12/1/2021	0.0135	0.0137	0.0134	Off	Off	Off	0.0137
12/2/2021	Off	Off	Off	Off	Off	Off	Off
12/3/2021	Off	Off	Off	0.0142	0.0134	0.0134	0.0142
12/4/2021	0.0137	Off	Off	Off	Off	Off	0.0137
12/5/2021	Off	Off	Off	Off	Off	Off	Off
12/6/2021	Off	Off	Off	0.0140	0.0136	0.0136	0.0140
12/7/2021	0.0135	Off	Off	Off	Off	Off	0.0135
12/8/2021	Off	Off	Off	Off	Off	Off	Off
12/9/2021	Off	Off	Off	Off	Off	Off	Off
12/10/2021	Off	Off	0.0136	0.0135	0.0135	Off	0.0136
12/11/2021	Off	Off	Off	Off	Off	Off	Off
12/12/2021	Off	0.0139	0.0137	0.0136	0.0136	0.0139	0.0139
12/13/2021	0.0136	0.0136	Off	Off	Off	Off	0.0136
12/14/2021	Off	Off	Off	Off	Off	Off	Off
12/15/2021	Off	Off	Off	Off	Off	Off	Off
12/16/2021	Off	Off	Off	0.0138	0.0136	0.0137	0.0138
12/17/2021	0.0138	0.0140	0.0136	Off	Off	Off	0.0140
12/18/2021	Off	Off	Off	Off	Off	Off	Off
12/19/2021	Off	Off	Off	Off	Off	Off	Off
12/20/2021	Off	0.0159	0.0137	0.0136	0.0136	0.0138	0.0159
12/21/2021	Off	Off	Off	Off	Off	Off	Off
12/22/2021	Off	Off	Off	Off	Off	0.0136	0.0136
12/23/2021	0.0135	0.0141	0.0136	Off	Off	Off	0.0141
12/24/2021	Off	Off	Off	Off	Off	Off	Off
12/25/2021	Off	Off	Off	Off	Off	0.0136	0.0136
12/26/2021	0.0136	0.0137	0.0137	Off	0.0135	0.0136	0.0137
12/27/2021	Off	Off	Off	Off	Off	Off	Off
12/28/2021	Off	Off	Off	Off	Off	Off	Off
12/29/2021	Off	0.0141	0.0137	0.0135	0.0135	0.0135	0.0141
12/30/2021	0.0136	Off	Off	Off	Off	Off	0.0136
12/31/2021	Off	Off	Off	Off	0.0139	0.0136	0.0139

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE:  DATE: 1/7/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: December-21	Disinfection <i>Giardia</i> Log Inactiv: 1.0
--	--------------	-------------------------	--

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.20	129	154.8	10.6	7.5	45.2	Yes	208
2	Off	129	Off	10.6	7.4	Off	Off	Off
3	1.15	129	148.4	10.0	7.7	50.2	Yes	223
4	1.15	129	148.4	10.0	7.5	46.8	Yes	201
5	Off	129	Off	10.0	7.5	Off	Off	Off
6	0.70	129	90.3	10.5	8.3	57.1	Yes	229
7	0.80	129	103.2	10.5	8.4	59.9	Yes	204
8	Off	129	Off	9.8	7.4	Off	Off	Off
9	Off	129	Off	10.0	8.3	Off	Off	Off
10	0.80	129	103.2	9.7	7.4	44.3	Yes	213
11	Off	129	Off	9.5	7.4	Off	Off	Off
12	1.00	129	129.0	9.1	7.3	45.5	Yes	208
13	1.09	129	140.6	10.0	7.8	51.7	Yes	201
14	Off	129	Off	8.4	7.5	Off	Off	Off
15	Off	129	Off	8.3	8.3	Off	Off	Off
16	0.70	129	90.3	8.4	7.9	57.0	Yes	219
17	0.80	129	103.2	8.6	7.3	45.9	Yes	201
18	Off	129	Off	8.8	8.3	Off	Off	Off
19	Off	129	Off	8.3	8.4	Off	Off	Off
20	0.80	129	103.2	9.4	8.4	64.6	Yes	214
21	Off	129	Off	10.0	8.0	Off	Off	Off
22	0.80	129	103.2	8.9	7.3	45.0	Yes	202
23	0.70	129	90.3	9.6	8.3	60.7	Yes	202
24	Off	129	Off	8.0	7.9	Off	Off	Off
25	1.12	129	144.5	9.0	7.9	57.5	Yes	202
26	1.15	129	148.4	8.0	7.8	59.5	Yes	202
27	Off	129	Off	9.0	8.3	Off	Off	Off
28	Off	129	Off	8.0	8.0	Off	Off	Off
29	0.80	129	103.2	7.8	7.6	53.9	Yes	224
30	0.80	129	103.2	9.1	8.1	59.1	Yes	200
31	1.00	129	129.0	7.5	7.5	54.3	Yes	95

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350