

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Jan-22

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1/1/2022	Off	Off	Off	Off	Off	Off	Off
1/2/2022	Off	Off	Off	Off	0.0138	0.0136	0.0138
1/3/2022	Off	Off	Off	Off	Off	Off	Off
1/4/2022	Off	Off	Off	Off	Off	Off	Off
1/5/2022	Off	Off	Off	Off	Off	0.0137	0.0137
1/6/2022	0.0137	0.0139	0.0138	Off	Off	Off	0.0139
1/7/2022	Off	Off	Off	Off	0.0147	0.0137	0.0147
1/8/2022	Off	Off	Off	Off	Off	Off	Off
1/9/2022	Off	Off	Off	Off	Off	Off	Off
1/10/2022	Off	Off	Off	Off	Off	Off	Off
1/11/2022	Off	Off	Off	Off	Off	Off	Off
1/12/2022	0.0139	Off	Off	Off	Off	Off	0.0139
1/13/2022	0.0148	Off	Off	Off	Off	Off	0.0148
1/14/2022	Off	Off	Off	Off	Off	Off	Off
1/15/2022	Off	Off	Off	Off	Off	Off	Off
1/16/2022	Off	Off	Off	Off	0.0148	Off	0.0148
1/17/2022	Off	Off	Off	0.0128	0.0114	Off	0.0128
1/18/2022	Off	Off	Off	0.0116	0.0116	Off	0.0116
1/19/2022	Off	Off	Off	Off	0.0112	Off	0.0112
1/20/2022	Off	Off	Off	Off	Off	Off	Off
1/21/2022	Off	Off	Off	Off	Off	Off	Off
1/22/2022	Off	Off	Off	Off	0.0114	Off	0.0114
1/23/2022	Off	Off	Off	0.0124	0.0115	Off	0.0124
1/24/2022	Off	Off	Off	0.0116	0.0112	Off	0.0116
1/25/2022	Off	Off	Off	0.0114	Off	Off	0.0114
1/26/2022	Off	Off	Off	0.0115	0.0113	Off	0.0115
1/27/2022	Off	Off	Off	Off	Off	Off	Off
1/28/2022	Off	Off	Off	Off	0.0113	Off	0.0113
1/29/2022	Off	Off	Off	Off	0.0113	Off	0.0113
1/30/2022	Off	Off	Off	0.0114	0.0113	0.0113	0.0114
1/31/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings \leq 1 NTU?² Yes / No

CT's met everyday? (see back)

All Cl2 residual at entry point \geq 0.2 mg/l?

All daily turbidity readings \leq 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE:  DATE: 2/3/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	Disinfection <i>Giardia</i> Log Inactiv: 1.0
ID#: 4100970	Month/Year: January-22

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	7.3	7.5	Off	Off	Off
2	1.20	129	154.8	7.4	7.5	56.0	Yes	213
3	Off	129	Off	7.6	7.4	Off	Off	Off
4	Off	129	Off	7.3	7.4	Off	Off	Off
5	1.00	129	129.0	7.6	7.3	50.2	Yes	329
6	1.00	129	129.0	8.5	7.4	49.0	Yes	303
7	0.80	129	103.2	9.2	8.0	56.6	Yes	280
8	Off	129	Off	8.5	8.2	Off	Off	Off
9	Off	129	Off	7.9	8.0	Off	Off	Off
10	Off	129	Off	9.5	8.0	Off	Off	Off
11	Off	129	Off	9.2	7.2	Off	Off	Off
12	0.90	129	116.1	10.5	8.4	60.6	Yes	280
13	1.20	129	154.8	9.3	7.5	49.3	Yes	301
14	Off	129	Off	9.4	7.4	Off	Off	Off
15	Off	129	Off	9.0	7.7	Off	Off	Off
16	1.05	129	135.5	9.0	7.8	55.0	Yes	304
17	1.10	129	141.9	8.0	7.7	57.1	Yes	301
18	1.10	129	141.9	9.4	7.5	48.4	Yes	301
19	1.20	129	154.8	9.5	7.3	45.3	Yes	301
20	Off	129	Off	9.0	7.6	Off	Off	Off
21	Off	129	Off	10.0	7.6	Off	Off	Off
22	0.90	129	116.1	7.7	7.7	56.9	Yes	310
23	0.80	129	103.2	8.5	8.2	63.9	Yes	301
24	1.10	129	141.9	9.3	7.8	54.2	Yes	301
25	1.00	129	129.0	9.1	7.4	47.1	Yes	309
26	1.20	129	154.8	9.0	7.5	50.3	Yes	303
27	Off	129	Off	10.0	7.9	Off	Off	Off
28	1.05	129	135.5	9.0	7.4	47.7	Yes	301
29	1.11	129	143.2	10.0	7.6	48.2	Yes	301
30	1.01	129	130.3	10.0	7.5	46.0	Yes	303
31	Off	129	Off	9.6	7.7	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350