

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Feb-22

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
2/1/2022	Off	Off	Off	0.0112	0.0113	Off	0.0113
2/2/2022	Off	Off	Off	Off	Off	Off	Off
2/3/2022	Off	Off	Off	Off	Off	Off	Off
2/4/2022	Off	Off	Off	Off	Off	0.0116	0.0116
2/5/2022	Off	Off	Off	Off	Off	Off	Off
2/6/2022	Off	Off	Off	Off	Off	Off	Off
2/7/2022	Off	Off	Off	Off	Off	Off	Off
2/8/2022	Off	Off	Off	Off	Off	Off	Off
2/9/2022	Off	Off	Off	Off	0.0118	0.0116	0.0118
2/10/2022	0.0113	0.0114	0.0113	0.0115	Off	0.0112	0.0115
2/11/2022	0.0113	Off	Off	Off	Off	Off	0.0113
2/12/2022	Off	Off	Off	Off	Off	Off	Off
2/13/2022	Off	Off	Off	Off	Off	0.0112	0.0112
2/14/2022	Off	Off	Off	Off	Off	Off	Off
2/15/2022	Off	Off	Off	Off	Off	Off	Off
2/16/2022	Off	Off	Off	Off	Off	Off	Off
2/17/2022	Off	Off	0.0114	0.0111	0.0112	0.0111	0.0114
2/18/2022	0.0112	0.0123	0.0112	Off	Off	Off	0.0123
2/19/2022	Off	Off	Off	Off	Off	0.0113	0.0113
2/20/2022	0.0111	0.0111	0.0111	0.0111	0.0111	0.0111	0.0111
2/21/2022	Off	Off	Off	Off	Off	Off	Off
2/22/2022	Off	Off	Off	Off	Off	0.0118	0.0118
2/23/2022	0.0111	0.0111	0.0110	0.0111	0.0110	0.0111	0.0111
2/24/2022	0.0110	Off	Off	Off	Off	Off	0.0110
2/25/2022	Off	Off	Off	Off	0.0113	0.0113	0.0113
2/26/2022	0.0113	Off	Off	Off	Off	Off	0.0113
2/27/2022	Off	Off	Off	Off	Off	Off	Off
2/28/2022	Off	Off	Off	Off	Off	0.0117	0.0117

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?² Yes / No

CT's met everyday? (see back)

All Cl₂ residual at entry point ≥ 0.2 mg/l?

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE: 

DATE: 3/3/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: February-22	Disinfection Giardia Log Inactiv: 1.0
--	--------------	-------------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.80	129	103.2	9.0	8.0	57.4	Yes	303
2	Off	129	Off	10.0	7.6	Off	Off	Off
3	Off	129	Off	9.7	7.7	Off	Off	Off
4	0.80	129	103.2	9.6	7.6	47.8	Yes	301
5	Off	129	Off	8.0	8.1	Off	Off	Off
6	Off	129	Off	8.7	8.3	Off	Off	Off
7	Off	129	Off	8.4	7.5	Off	Off	Off
8	Off	129	Off	9.4	8.0	Off	Off	Off
9	0.70	129	90.3	10.5	7.5	43.0	Yes	222
10	1.15	129	148.4	9.0	7.6	51.8	Yes	235
11	0.80	129	103.2	8.6	8.1	61.2	Yes	201
12	Off	129	Off	10.0	7.8	Off	Off	Off
13	1.01	129	130.3	10.0	7.8	51.2	Yes	203
14	Off	129	Off	9.5	7.8	Off	Off	Off
15	Off	129	Off	8.7	8.1	Off	Off	Off
16	Off	129	Off	9.3	7.9	Off	Off	Off
17	0.70	129	90.3	9.0	7.8	52.8	Yes	311
18	1.06	129	136.7	8.0	7.8	58.9	Yes	202
19	0.80	129	103.2	8.2	8.0	60.6	Yes	202
20	0.70	129	90.3	8.7	8.1	60.1	Yes	202
21	Off	129	Off	8.6	8.1	Off	Off	Off
22	0.90	129	116.1	8.3	8.0	60.9	Yes	201
23	0.90	129	116.1	8.0	8.1	64.5	Yes	297
24	1.01	129	130.3	10.0	7.7	49.4	Yes	212
25	1.18	129	152.2	10.0	7.8	52.2	Yes	202
26	1.06	129	136.7	9.0	7.7	53.1	Yes	200
27	Off	129	Off	10.0	7.6	Off	Off	Off
28	0.90	129	116.1	9.0	7.5	48.6	Yes	202

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dpw.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350