

OHA - Drinking Water Program - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Mar-22

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
3/1/2022	Off	Off	Off	Off	Off	Off	Off
3/2/2022	Off	Off	Off	Off	0.0137	0.0111	0.0137
3/3/2022	0.0111	0.0111	0.0111	0.0111	0.0111	0.0111	0.0111
3/4/2022	0.0111	0.0111	Off	Off	Off	Off	0.0111
3/5/2022	Off	Off	Off	Off	Off	Off	Off
3/6/2022	Off	Off	Off	Off	Off	Off	Off
3/7/2022	Off	Off	0.0126	0.0111	0.0111	0.0111	0.0126
3/8/2022	0.0111	0.0111	0.0111	0.0111	Off	Off	0.0111
3/9/2022	Off	Off	Off	Off	Off	Off	Off
3/10/2022	Off	Off	Off	Off	0.0112	Off	0.0112
3/11/2022	Off	Off	Off	Off	Off	Off	Off
3/12/2022	Off	Off	Off	Off	Off	Off	Off
3/13/2022	0.0122	0.0113	0.0112	0.0113	0.0115	0.0113	0.0122
3/14/2022	0.0113	0.0113	0.0113	0.0113	Off	Off	0.0113
3/15/2022	Off	Off	Off	Off	0.0113	0.0113	0.0113
3/16/2022	Off	Off	Off	Off	Off	Off	Off
3/17/2022	Off	Off	Off	Off	Off	Off	Off
3/18/2022	Off	Off	Off	0.0113	0.0114	0.0112	0.0114
3/19/2022	0.0115	0.0113	Off	Off	Off	Off	0.0115
3/20/2022	Off	Off	Off	Off	Off	0.0162	0.0162
3/21/2022	0.0112	0.0111	0.0111	0.0110	0.0110	0.0110	0.0112
3/22/2022	Off	Off	Off	Off	Off	Off	Off
3/23/2022	Off	Off	Off	Off	Off	Off	Off
3/24/2022	0.0110	0.0110	0.0110	0.0109	0.0110	0.0110	0.0110
3/25/2022	0.0110	0.0110	Off	Off	Off	Off	0.0110
3/26/2022	Off	Off	Off	Off	Off	Off	Off
3/27/2022	Off	Off	Off	Off	0.0109	0.0109	0.0109
3/28/2022	0.0109	0.0109	0.0109	Off	Off	Off	0.0109
3/29/2022	Off	Off	Off	Off	Off	Off	Off
3/30/2022	Off	Off	Off	Off	Off	Off	Off
3/31/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?<sup>2</sup>  Yes/  No

CT's met everyday? (see back)  Yes/  No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes/  No

All daily turbidity readings ≤ 5 NTU?  Yes/  No

Yes/  No

Yes/  No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE:  DATE: 4/5/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	Disinfection <i>Giardia</i> Log Inactiv: 1.0
ID#: 4100970	Month/Year: March-22

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	0.3	7.5	Off	Off	Off
2	1.00	129	129.0	7.4	7.3	50.9	Yes	202
3	1.00	129	129.0	8.0	7.3	48.9	Yes	206
4	1.20	129	154.8	8.4	7.5	52.3	Yes	202
5	Off	129	Off	7.6	8.3	Off	Off	Off
6	Off	129	Off	7.9	8.1	Off	Off	Off
7	1.00	129	129.0	8.5	7.3	47.3	Yes	206
8	0.90	129	116.1	8.9	7.2	44.0	Yes	208
9	Off	129	Off	8.5	7.4	Off	Off	Off
10	1.00	129	129.0	8.6	7.3	47.0	Yes	202
11	Off	129	Off	8.3	7.5	Off	Off	Off
12	Off	129	Off	9.0	7.8	Off	Off	Off
13	1.09	129	140.6	9.0	7.7	53.3	Yes	204
14	1.00	129	129.0	8.5	7.3	47.3	Yes	200
15	1.20	129	154.8	8.9	7.4	48.8	Yes	207
16	Off	129	Off	8.9	7.4	Off	Off	Off
17	Off	129	Off	8.8	7.5	Off	Off	Off
18	1.40	129	180.6	9.0	7.3	47.9	Yes	202
19	0.90	129	116.1	9.0	8.6	72.2	Yes	201
20	0.90	129	116.1	9.2	8.2	61.6	Yes	200
21	1.60	129	206.4	8.9	7.4	51.1	Yes	202
22	Off	129	Off	8.9	7.4	Off	Off	Off
23	Off	129	Off	9.5	7.5	Off	Off	Off
24	1.20	129	154.8	10.0	8.1	58.3	Yes	204
25	1.50	129	193.5	9.4	7.3	47.2	Yes	201
26	Off	129	Off	9.0	7.5	Off	Off	Off
27	1.25	129	161.3	9.0	7.6	52.4	Yes	209
28	1.60	129	206.4	9.8	7.4	48.1	Yes	206
29	Off	129	Off	9.7	7.4	Off	Off	Off
30	Off	129	Off	9.8	7.4	Off	Off	Off
31	Off	129	Off	9.9	7.4	Off	Off	Off

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350