

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Apr-22

System Name: Neskwin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
4/1/2022	Off	Off	Off	Off	Off	Off	Off
4/2/2022	Off	Off	Off	Off	Off	Off	Off
4/3/2022	Off	Off	Off	Off	Off	Off	Off
4/4/2022	Off	Off	0.0124	0.0112	0.0112	0.0111	0.0124
4/5/2022	0.0112	Off	0.0122	0.0114	0.0111	0.0112	0.0122
4/6/2022	0.0111	0.0113	0.0112	0.0113	0.0112	Off	0.0113
4/7/2022	Off	Off	Off	Off	Off	Off	Off
4/8/2022	Off	Off	Off	Off	0.0112	0.0110	0.0112
4/9/2022	0.0109	0.0109	0.0109	0.0109	Off	Off	0.0109
4/10/2022	Off	Off	Off	Off	Off	0.0111	0.0111
4/11/2022	0.0109	0.0110	Off	Off	Off	Off	0.0110
4/12/2022	Off	Off	Off	Off	Off	Off	Off
4/13/2022	Off	Off	Off	Off	Off	Off	Off
4/14/2022	Off	Off	Off	Off	Off	Off	Off
4/15/2022	Off	Off	Off	Off	Off	Off	Off
4/16/2022	Off	Off	Off	Off	Off	Off	Off
4/17/2022	Off	Off	Off	0.0117	0.0111	0.0111	0.0117
4/18/2022	0.0110	0.0110	0.0110	0.0110	0.0110	0.0110	0.0110
4/19/2022	Off	Off	Off	Off	Off	Off	Off
4/20/2022	Off	Off	Off	Off	Off	Off	Off
4/21/2022	Off	Off	Off	Off	0.0122	0.0111	0.0122
4/22/2022	0.0113	0.0115	0.0115	0.0115	0.0116	Off	0.0116
4/23/2022	Off	Off	Off	Off	Off	Off	Off
4/24/2022	Off	Off	Off	Off	Off	Off	Off
4/25/2022	Off	Off	Off	Off	0.0114	0.0113	0.0114
4/26/2022	0.0111	0.0123	0.0110	0.0112	Off	Off	0.0123
4/27/2022	Off	Off	Off	Off	Off	Off	Off
4/28/2022	Off	Off	Off	Off	Off	Off	Off
4/29/2022	0.0112	0.0112	0.0110	0.0110	0.0112	0.0110	0.0112
4/30/2022	0.0111	Off	Off	Off	Off	Off	0.0111

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE: 

DATE: 5/2/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only. Page 1 of 2

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP-: WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: April-22	Disinfection Giardia Log Inactiv: 1.0
--	--------------	----------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	9.7	7.6	Off	Off	Off
2	Off	129	Off	9.7	7.5	Off	Off	Off
3	Off	129	Off	9.9	7.3	Off	Off	Off
4	1.60	129	206.4	10.2	7.4	46.9	Yes	202
5	1.40	129	180.6	9.6	7.4	47.7	Yes	203
6	1.40	129	180.6	9.1	7.3	47.6	Yes	208
7	Off	129	Off	9.2	7.4	Off	Off	Off
8	1.20	129	154.8	9.2	7.4	47.9	Yes	205
9	1.11	129	143.2	9.0	7.5	49.7	Yes	206
10	1.08	129	139.3	9.0	7.6	51.4	Yes	205
11	1.20	129	154.8	9.1	7.4	48.2	Yes	206
12	Off	129	Off	8.7	7.5	Off	Off	Off
13	Off	129	Off	8.7	7.5	Off	Off	Off
14	Off	129	Off	8.6	7.4	Off	Off	Off
15	Off	129	Off	8.6	7.5	Off	Off	Off
16	Off	129	Off	9.0	7.6	Off	Off	Off
17	1.05	129	135.5	10.0	7.6	47.9	Yes	202
18	1.10	129	141.9	8.7	7.6	52.5	Yes	202
19	Off	129	Off	8.2	7.2	Off	Off	Off
20	Off	129	Off	8.2	7.2	Off	Off	Off
21	1.20	129	154.8	8.4	7.2	47.0	Yes	203
22	1.10	129	141.9	8.5	7.4	49.6	Yes	203
23	Off	129	Off	8.3	7.4	Off	Off	Off
24	Off	129	Off	9.3	7.4	Off	Off	Off
25	0.60	129	77.4	9.1	7.3	43.5	Yes	201
26	0.60	129	77.4	9.1	7.4	45.0	Yes	202
27	Off	129	Off	9.1	7.4	Off	Off	Off
28	Off	129	Off	9.4	7.5	Off	Off	Off
29	0.50	129	64.5	10.0	7.9	50.0	Yes	202
30	0.50	129	64.5	10.0	7.8	48.3	Yes	201

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350