

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: May-22

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
5/1/2022	0.0112	0.0110	0.0113	0.0110	0.0111	0.0110	0.0113
5/2/2022	Off	Off	Off	Off	Off	Off	Off
5/3/2022	Off	Off	Off	Off	0.0139	0.0110	0.0139
5/4/2022	0.0110	Off	Off	0.0115	0.0107	0.0107	0.0115
5/5/2022	Off	Off	Off	Off	Off	Off	Off
5/6/2022	Off	Off	0.0108	0.0110	0.0110	0.0109	0.0110
5/7/2022	0.0108	0.0108	Off	Off	Off	Off	0.0108
5/8/2022	Off	Off	Off	Off	Off	Off	Off
5/9/2022	Off	Off	Off	Off	0.0108	0.0108	0.0108
5/10/2022	0.0107	0.0108	0.0107	Off	Off	Off	0.0108
5/11/2022	Off	Off	Off	0.0108	0.0107	0.0107	0.0108
5/12/2022	0.0107	0.0107	Off	Off	Off	Off	0.0107
5/13/2022	Off	Off	Off	Off	Off	Off	Off
5/14/2022	0.0108	0.0109	0.0108	0.0108	0.0108	Off	0.0109
5/15/2022	Off	Off	Off	Off	Off	Off	Off
5/16/2022	Off	Off	Off	Off	Off	Off	Off
5/17/2022	Off	Off	Off	Off	0.0107	Off	0.0107
5/18/2022	Off	Off	Off	0.0108	0.0107	0.0107	0.0108
5/19/2022	0.0107	0.0108	Off	Off	Off	Off	0.0108
5/20/2022	Off	Off	Off	Off	Off	Off	Off
5/21/2022	Off	Off	0.0108	0.0107	0.0107	0.0107	0.0108
5/22/2022	0.0107	0.0112	Off	Off	Off	Off	0.0112
5/23/2022	Off	Off	Off	Off	Off	Off	Off
5/24/2022	Off	Off	Off	Off	Off	0.0107	0.0107
5/25/2022	0.0107	0.0107	0.0107	0.0107	0.0109	Off	0.0109
5/26/2022	Off	Off	Off	Off	Off	Off	Off
5/27/2022	Off	Off	0.0111	0.0108	0.0108	0.0108	0.0111
5/28/2022	0.0108	0.0110	0.0108	Off	Off	Off	0.0110
5/29/2022	Off	Off	Off	Off	0.0116	0.0109	0.0116
5/30/2022	0.0108	Off	Off	Off	Off	Off	0.0108
5/31/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?² Yes / No

CT's met everyday? (see back)

All Cl2 residual at entry point ≥ 0.2 mg/l?

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE:  DATE: 6/6/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A
 Disinfection
Giardia Log
 Inactiv: 1.0

System Name:
 Neskowin
 Regional Water
 District

ID#: 4100970

Month/Year: May-22

Date / Time	Cl ₂ Residual at 1st User (-C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.50	129	64.5	10.0	7.8	48.3	Yes	202
2	Off	129	Off	10.0	8.0	Off	Off	Off
3	0.50	129	64.5	10.0	7.7	46.6	Yes	202
4	0.70	129	90.3	9.6	7.4	44.0	Yes	202
5	Off	129	Off	10.0	7.9	Off	Off	Off
6	0.70	129	90.3	9.9	7.3	41.7	Yes	202
7	1.01	129	130.3	10.0	7.8	51.2	Yes	201
8	Off	129	Off	10.0	7.8	Off	Off	Off
9	1.00	129	129.0	10.0	7.6	47.6	Yes	203
10	1.30	129	167.7	9.5	7.6	51.0	Yes	205
11	0.90	129	116.1	9.0	7.8	54.1	Yes	202
12	0.90	129	116.1	10.0	7.9	52.4	Yes	201
13	Off	129	Off	10.0	7.8	Off	Off	Off
14	1.40	129	180.6	9.3	7.4	48.6	Yes	213
15	Off	129	Off	9.5	7.6	Off	Off	Off
16	Off	129	Off	10.0	7.7	Off	Off	Off
17	1.00	129	129.0	10.0	7.7	49.3	Yes	206
18	1.20	129	154.8	9.8	7.4	46.0	Yes	205
19	1.20	129	154.8	9.8	7.4	46.0	Yes	203
20	Off	129	Off	10.0	7.7	Off	Off	Off
21	1.00	129	129.0	11.0	7.8	47.8	Yes	207
22	1.00	129	129.0	12.0	7.9	46.4	Yes	202
23	Off	129	Off	10.3	7.5	Off	Off	Off
24	1.20	129	154.8	10.5	7.3	42.4	Yes	206
25	0.90	129	116.1	11.0	7.7	45.6	Yes	205
26	Off	129	Off	11.0	7.8	Off	Off	Off
27	1.00	129	129.0	11.0	7.7	46.2	Yes	209
28	1.09	129	140.6	11.0	7.8	48.3	Yes	201
29	1.01	129	130.3	10.0	7.9	53.1	Yes	201
30	1.00	129	129.0	11.0	7.9	49.6	Yes	202
31	Off	129	Off	13.0	7.7	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350