

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Jun-22

System Name: Neskwin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
6/1/2022	0.0108	Off	Off	Off	Off	Off	0.0108
6/2/2022	Off	Off	Off	Off	Off	Off	Off
6/3/2022	Off	Off	Off	0.0109	0.0107	0.0108	0.0109
6/4/2022	0.0111	0.0108	0.0111	0.0109	0.0111	0.0111	0.0111
6/5/2022	0.0112	Off	Off	Off	Off	Off	0.0112
6/6/2022	Off	Off	Off	Off	Off	Off	Off
6/7/2022	Off	Off	Off	0.0113	0.0109	0.0108	0.0113
6/8/2022	Off	0.0108	0.0111	Off	Off	Off	0.0111
6/9/2022	Off	Off	Off	Off	Off	Off	Off
6/10/2022	Off	Off	Off	0.0110	0.0109	Off	0.0110
6/11/2022	Off	Off	Off	Off	Off	Off	Off
6/12/2022	0.0108	0.0110	0.0109	0.0109	Off	Off	0.0110
6/13/2022	Off	0.0107	0.0106	0.0106	0.0106	Off	0.0107
6/14/2022	Off	Off	Off	Off	Off	Off	Off
6/15/2022	Off	0.0109	0.0106	0.0106	0.0106	0.0106	0.0109
6/16/2022	0.0106	0.0106	Off	Off	Off	Off	0.0106
6/17/2022	Off	Off	Off	Off	Off	Off	Off
6/18/2022	0.0106	0.0106	0.0106	0.0106	0.0105	0.0105	0.0106
6/19/2022	Off	Off	Off	Off	Off	Off	Off
6/20/2022	Off	Off	Off	Off	0.0112	0.0106	0.0112
6/21/2022	0.0105	0.0106	0.0105	0.0105	0.0106	Off	0.0106
6/22/2022	Off	Off	Off	0.0107	0.0105	0.0105	0.0107
6/23/2022	0.0106	Off	Off	Off	Off	Off	0.0106
6/24/2022	Off	Off	Off	0.0106	0.0105	0.0105	0.0106
6/25/2022	0.0105	0.0106	0.0105	0.0106	0.0106	0.0108	0.0108
6/26/2022	0.0106	Off	Off	Off	Off	Off	0.0106
6/27/2022	Off	Off	Off	Off	0.0172	0.0106	0.0172
6/28/2022	0.0106	0.0107	0.0106	0.0110	Off	0.0108	0.0110
6/29/2022	0.0107	0.0111	0.0111	Off	Off	Off	0.0111
6/30/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?²

Yes/ No

CT's met everyday? (see back)

Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l?

Yes/ No

All daily turbidity readings ≤ 5 NTU?

Yes/ No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE: 

DATE: 7/7/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: WTP-A

System Name:
Neskowin
Regional Water
District

ID#: 4100970

Month/Year: June-22

Disinfection
Giardia Log
Inactiv:

1.0

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.10	129	141.9	11.0	7.3	40.6	Yes	202
2	Off	129	Off	11.0	7.4	Off	Off	Off
3	1.20	129	154.8	11.0	7.3	41.0	Yes	210
4	1.20	129	154.8	11.3	7.5	43.2	Yes	206
5	1.10	129	141.9	11.2	7.5	42.9	Yes	199
6	Off	129	Off	12.0	7.8	Off	Off	Off
7	1.00	129	129.0	11.0	7.8	47.8	Yes	204
8	1.10	129	141.9	12.0	7.8	45.3	Yes	202
9	Off	129	Off	12.5	7.8	Off	Off	Off
10	1.11	129	143.2	12.5	7.8	43.8	Yes	202
11	Off	129	Off	11.0	7.8	Off	Off	Off
12	1.19	129	153.5	11.0	7.8	48.9	Yes	202
13	0.90	129	116.1	11.5	7.6	42.6	Yes	210
14	Off	129	Off	11.3	7.8	Off	Off	Off
15	1.00	129	129.0	11.3	7.7	45.3	Yes	208
16	1.00	129	129.0	11.3	7.6	43.7	Yes	203
17	Off	129	Off	11.2	7.6	Off	Off	Off
18	1.00	129	129.0	11.3	8.0	50.3	Yes	206
19	Off	129	Off	11.3	8.0	Off	Off	Off
20	1.00	129	129.0	11.3	8.0	50.3	Yes	201
21	1.00	129	129.0	11.4	8.0	50.0	Yes	207
22	1.00	129	129.0	11.5	8.0	49.7	Yes	202
23	1.00	129	129.0	11.5	8.0	49.7	Yes	202
24	1.05	129	135.5	12.0	8.0	48.3	Yes	202
25	1.00	129	129.0	11.5	8.0	49.7	Yes	210
26	1.00	129	129.0	12.7	8.0	45.9	Yes	202
27	1.20	129	154.8	12.8	8.1	48.4	Yes	202
28	1.20	129	154.8	12.8	7.8	43.4	Yes	207
29	1.00	129	129.0	12.5	7.8	43.2	Yes	206
30	Off	129	Off	12.5	8.2	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350