

OHA - Drinking Water Program - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**  
 Month/Year: **Aug-22**

System Name: <b>Neskowin Regional Water District ID#: 4100970</b>		WTP: TP -		WTP-A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
8/1/2022	0.0104	Off	Off	Off	Off	Off	0.0104
8/2/2022	Off	Off	0.0120	0.0105	0.0105	0.0105	0.0120
8/3/2022	0.0108	0.0108	0.0105	0.0105	0.0105	0.0106	0.0108
8/4/2022	0.0113	Off	Off	Off	Off	Off	0.0113
8/5/2022	Off	Off	0.0106	0.0106	0.0106	0.0108	0.0108
8/6/2022	0.0111	0.0109	0.0107	0.0108	0.0109	0.0109	0.0111
8/7/2022	0.0114	0.0110	Off	Off	Off	Off	0.0114
8/8/2022	Off	Off	0.0110	0.0107	0.0108	0.0108	0.0110
8/9/2022	0.0113	0.0113	0.0111	0.0110	0.0109	0.0109	0.0113
8/10/2022	Off	Off	Off	Off	Off	0.0108	0.0108
8/11/2022	0.0109	0.0113	0.0109	0.0109	0.0108	0.0110	0.0113
8/12/2022	Off	Off	Off	Off	Off	Off	Off
8/13/2022	0.0117	0.0110	0.0112	0.0110	0.0108	0.0112	0.0117
8/14/2022	0.0111	Off	Off	Off	Off	Off	0.0111
8/15/2022	Off	Off	Off	0.0115	0.0109	0.0112	0.0115
8/16/2022	0.0118	0.0111	0.0108	0.0109	0.0116	Off	0.0118
8/17/2022	Off	Off	Off	Off	0.0107	0.0103	0.0107
8/18/2022	0.0103	0.0103	0.0103	0.0103	0.0103	0.0106	0.0106
8/19/2022	0.0104	0.0104	Off	Off	Off	Off	0.0104
8/20/2022	Off	0.0113	0.0103	0.0103	0.0104	0.0107	0.0113
8/21/2022	0.0104	0.0104	0.0103	Off	Off	Off	0.0104
8/22/2022	Off	Off	Off	Off	Off	0.0107	0.0107
8/23/2022	0.0103	0.0102	0.0102	0.0103	Off	Off	0.0103
8/24/2022	0.0116	0.0117	0.0116	0.0116	Off	0.0116	0.0117
8/25/2022	0.0116	0.0116	0.0116	0.0116	0.0118	Off	0.0118
8/26/2022	Off	Off	Off	Off	Off	Off	Off
8/27/2022	Off	0.0116	0.0116	0.0120	0.0117	0.0117	0.0120
8/28/2022	0.0118	0.0117	0.0118	Off	Off	Off	0.0118
8/29/2022	Off	Off	Off	Off	Off	0.0126	0.0126
8/30/2022	0.0117	0.0117	0.0119	0.0124	Off	Off	0.0124
8/31/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>  Yes / No

CT's met everyday? (see back)  Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l?  Yes / No

All daily turbidity readings ≤ 5 NTU?  Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **9/1/2022**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

WTP- :    WTP-A

**System Name:**  
Neskowin  
Regional Water  
District

ID#: 4100970

Month/Year: August-22

**Disinfection  
Giardia Log  
Inactiv:**

0.5

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.20	129	154.8	13.6	7.8	20.6	Yes	201
2	1.20	129	154.8	13.7	7.8	20.4	Yes	202
3	1.20	129	154.8	13.8	7.8	20.3	Yes	210
4	1.20	129	154.8	13.7	7.8	20.4	Yes	201
5	1.20	129	154.8	13.7	7.8	20.4	Yes	204
6	1.11	129	143.2	13.0	7.8	21.2	Yes	208
7	1.09	129	140.6	13.0	7.8	21.1	Yes	208
8	1.20	129	154.8	13.7	7.8	20.4	Yes	206
9	1.20	129	154.8	13.5	7.8	20.7	Yes	209
10	1.10	129	141.9	13.5	7.8	20.5	Yes	205
11	1.10	129	141.9	13.4	7.9	21.4	Yes	209
12	Off	129	Off	13.6	7.8	Off	Off	Off
13	1.20	129	154.8	13.7	7.8	20.4	Yes	207
14	1.20	129	154.8	14.2	7.9	20.5	Yes	209
15	1.05	129	135.5	13.0	7.8	21.0	Yes	205
16	1.00	129	129.0	13.9	7.8	19.7	Yes	211
17	1.20	129	154.8	14.0	7.9	20.8	Yes	202
18	1.20	129	154.8	14.2	7.9	20.5	Yes	203
19	1.00	129	129.0	14.2	7.8	19.3	Yes	202
20	1.11	129	143.2	13.0	7.8	21.2	Yes	202
21	1.08	129	139.3	13.0	7.8	21.1	Yes	201
22	1.20	129	154.8	14.4	7.8	19.5	Yes	204
23	1.20	129	154.8	14.6	7.8	19.2	Yes	202
24	1.00	129	129.0	14.5	7.8	18.9	Yes	202
25	1.10	129	141.9	14.5	7.8	19.1	Yes	207
26	Off	129	Off	14.4	7.8	Off	Off	Off
27	1.00	129	129.0	14.7	7.8	18.7	Yes	207
28	0.80	129	103.2	14.6	7.8	18.4	Yes	202
29	0.80	129	103.2	14.2	7.8	18.9	Yes	202
30	0.60	129	77.4	14.0	7.8	18.7	Yes	205
31	Off	129	Off	14.2	7.8	Off	Off	Off

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

**Return by 10th of following month by email, fax, or mail to:**

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350