

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Nov-22

System Name: Neskowin Regional Water District ID#: 4100970

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
11/1/2022	0.0119	0.0119	Off	Off	Off	Off	0.0119
11/2/2022	Off	Off	Off	Off	Off	Off	Off
11/3/2022	Off	Off	Off	Off	0.0119	0.0117	0.0119
11/4/2022	0.0118	Off	Off	Off	Off	Off	0.0118
11/5/2022	Off	Off	Off	0.0121	0.0119	0.0122	0.0122
11/6/2022	0.0119	0.0119	0.0120	Off	Off	Off	0.0120
11/7/2022	Off	Off	Off	Off	Off	Off	Off
11/8/2022	Off	Off	Off	Off	Off	0.0119	0.0119
11/9/2022	0.0119	0.0119	0.0119	0.0120	Off	Off	0.0120
11/10/2022	Off	Off	Off	Off	Off	Off	Off
11/11/2022	Off	Off	Off	Off	Off	Off	Off
11/12/2022	Off	Off	Off	Off	Off	Off	Off
11/13/2022	Off	Off	Off	Off	Off	Off	Off
11/14/2022	Off	Off	Off	Off	Off	0.0121	0.0121
11/15/2022	0.0121	0.0126	0.0120	0.0121	Off	Off	0.0126
11/16/2022	Off	Off	Off	Off	Off	Off	Off
11/17/2022	Off	Off	Off	Off	Off	0.0126	0.0126
11/18/2022	0.0124	0.0120	0.0120	0.0120	0.0120	Off	0.0124
11/19/2022	Off	Off	Off	Off	Off	Off	Off
11/20/2022	Off	Off	Off	Off	Off	Off	Off
11/21/2022	Off	Off	Off	0.0135	0.0121	0.0123	0.0135
11/22/2022	0.0123	0.0124	0.0123	0.0123	0.0125	Off	0.0125
11/23/2022	Off	Off	Off	Off	Off	Off	Off
11/24/2022	Off	Off	Off	Off	0.0124	0.0124	0.0124
11/25/2022	0.0126	0.0123	0.0123	0.0124	0.0126	Off	0.0126
11/26/2022	Off	Off	Off	Off	Off	Off	Off
11/27/2022	Off	Off	Off	0.0134	0.0123	Off	0.0134
11/28/2022	Off	Off	Off	Off	Off	0.0136	0.0136
11/29/2022	0.0128	0.0139	Off	Off	Off	Off	0.0139
11/30/2022	Off	Off	Off	Off	Off	Off	Off
12/1/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU? ² Yes / No

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

All daily turbidity readings ≤ 5 NTU? Yes / No

Yes / No

Yes / No

Notes:

PRINTED NAME: Troy N. Trute

SIGNATURE:  DATE: 12/1/2022

PHONE #: (503)392-3966

CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: November-22	Disinfection <i>Giardia</i> Log Inactiv: 0.5
--	--------------	-------------------------	--

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.82	129	105.8	12.0	7.7	21.2	Yes	205
2	Off	129	Off	11.0	7.7	Off	Off	Off
3	0.75	129	96.8	11.0	7.8	23.2	Yes	207
4	0.50	129	64.5	10.7	7.5	20.7	Yes	202
5	0.50	129	64.5	10.5	7.5	21.0	Yes	204
6	0.50	129	64.5	10.1	7.7	23.2	Yes	201
7	Off	129	Off	10.1	7.5	Off	Off	Off
8	0.70	129	90.3	10.0	7.5	22.2	Yes	202
9	0.80	129	103.2	9.4	7.7	25.1	Yes	206
10	Off	129	Off	9.5	7.7	Off	Off	Off
11	Off	129	Off	8.5	7.7	Off	Off	Off
12	Off	129	Off	9.2	7.7	Off	Off	Off
13	Off	129	Off	9.1	7.7	Off	Off	Off
14	1.00	129	129.0	8.7	7.7	26.9	Yes	202
15	1.00	129	129.0	8.9	7.7	26.6	Yes	202
16	Off	129	Off	8.8	7.7	Off	Off	Off
17	1.20	129	154.8	8.9	7.7	27.2	Yes	201
18	1.20	129	154.8	8.4	7.7	28.1	Yes	201
19	Off	129	Off	8.5	7.7	Off	Off	Off
20	Off	129	Off	7.7	7.7	Off	Off	Off
21	1.30	129	167.7	8.0	7.7	29.2	Yes	202
22	1.30	129	167.7	7.9	7.7	29.4	Yes	204
23	Off	129	Off	8.1	7.7	Off	Off	Off
24	1.41	129	181.9	8.0	7.7	29.6	Yes	201
25	1.25	129	161.3	8.0	7.7	29.0	Yes	202
26	Off	129	Off	8.0	7.7	Off	Off	Off
27	1.30	129	167.7	8.0	7.7	29.2	Yes	201
28	1.30	129	167.7	7.9	7.8	30.5	Yes	202
29	1.40	129	180.6	8.3	7.7	29.0	Yes	201
30	Off	129	Off	8.2	7.9	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350