

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**

Month/Year: **Dec-22**

System Name: **Neskowin Regional Water District ID#: 4100970**

WTP: **TP - WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
12/1/2022	0.0142	Off	Off	Off	Off	Off	0.0142
12/2/2022	Off	Off	Off	0.0124	0.0123	0.0123	0.0124
12/3/2022	0.0124	0.0124	Off	Off	Off	Off	0.0124
12/4/2022	Off	Off	Off	Off	Off	Off	Off
12/5/2022	Off	Off	Off	Off	0.0126	0.0127	0.0127
12/6/2022	0.0123	0.0123	0.0123	Off	0.0121	Off	0.0123
12/7/2022	Off	Off	Off	Off	Off	Off	Off
12/8/2022	Off	Off	Off	Off	Off	Off	Off
12/9/2022	Off	Off	Off	0.0125	0.0120	0.0120	0.0125
12/10/2022	0.0122	0.0122	0.0122	0.0122	Off	Off	0.0122
12/11/2022	0.0122	Off	Off	Off	Off	Off	0.0122
12/12/2022	0.0121	0.0121	0.0121	0.0121	0.0120	Off	0.0121
12/13/2022	0.0121	Off	Off	Off	Off	Off	0.0121
12/14/2022	Off	Off	Off	Off	Off	Off	Off
12/15/2022	Off	0.0127	0.0120	0.0120	0.0120	0.0120	0.0127
12/16/2022	Off	Off	Off	Off	Off	Off	Off
12/17/2022	Off	Off	Off	Off	Off	Off	Off
12/18/2022	Off	Off	0.0125	0.0121	0.0121	0.0123	0.0125
12/19/2022	0.0123	0.0123	0.0121	0.0122	Off	Off	0.0123
12/20/2022	Off	Off	Off	Off	Off	Off	Off
12/21/2022	Off	Off	Off	Off	0.0144	0.0123	0.0144
12/22/2022	0.0123	0.0123	0.0124	0.0123	0.0128	Off	0.0128
12/23/2022	Off	Off	Off	Off	Off	Off	Off
12/24/2022	Off	Off	Off	Off	Off	Off	Off
12/25/2022	Off	Off	Off	0.0141	0.0126	Off	0.0141
12/26/2022	Off	Off	Off	Off	0.0124	0.0122	0.0124
12/27/2022	0.0121	0.0122	0.0121	0.0122	0.0122	0.0125	0.0125
12/28/2022	0.0122	0.0123	0.0122	Off	Off	Off	0.0123
12/29/2022	Off	Off	Off	Off	Off	Off	Off
12/30/2022	0.0124	0.0121	0.0121	0.0121	0.0121	0.0122	0.0124
12/31/2022	Off	Off	Off	Off	Off	Off	Off

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings \leq 1 NTU?² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point \geq 0.2 mg/l? Yes/ No

All daily turbidity readings \leq 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: **1/4/2023**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: December-22	Disinfection <i>Giardia</i> Log Inactiv: 0.5
--	--------------	-------------------------	--

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.60	129	206.4	8.0	7.9	32.5	Yes	201
2	1.80	129	232.2	8.0	7.8	32.1	Yes	201
3	1.40	129	180.6	8.0	7.8	30.6	Yes	200
4	Off	129	Off	8.0	7.8	Off	Off	Off
5	1.38	129	178.0	8.0	7.8	30.6	Yes	201
6	1.24	129	160.0	7.8	7.7	29.4	Yes	208
7	Off	129	Off	8.0	7.7	Off	Off	Off
8	Off	129	Off	8.0	7.8	Off	Off	Off
9	1.06	129	136.7	9.0	7.8	27.5	Yes	201
10	1.15	129	148.4	8.0	7.8	29.8	Yes	202
11	1.10	129	141.9	9.0	7.8	27.7	Yes	202
12	1.31	129	169.0	8.0	7.8	30.3	Yes	202
13	1.00	129	129.0	8.0	7.6	27.2	Yes	202
14	Off	129	Off	8.0	7.6	Off	Off	Off
15	1.00	129	129.0	8.0	7.6	27.2	Yes	202
16	Off	129	Off	8.0	7.6	Off	Off	Off
17	Off	129	Off	8.0	7.6	Off	Off	Off
18	0.80	129	103.2	8.0	7.6	26.6	Yes	206
19	1.01	129	130.3	8.0	7.7	28.2	Yes	202
20	Off	129	Off	8.0	7.7	Off	Off	Off
21	0.80	129	103.2	8.0	7.6	26.6	Yes	203
22	1.11	129	143.2	8.0	7.7	28.6	Yes	202
23	Off	129	Off	7.0	7.7	Off	Off	Off
24	Off	129	Off	7.0	7.7	Off	Off	Off
25	0.85	129	109.7	8.0	7.7	27.7	Yes	200
26	0.75	129	96.8	8.0	7.7	27.4	Yes	201
27	0.60	129	77.4	8.0	7.5	25.1	Yes	202
28	0.60	129	77.4	8.0	7.5	25.1	Yes	203
29	Off	129	Off	8.0	7.7	Off	Off	Off
30	0.81	129	104.5	8.0	7.6	26.6	Yes	204
31	Off	129	Off	8.0	7.6	Off	Off	Off

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350