

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Tillamook**

Month/Year: **Jan-23**

System Name: **Neskowin Regional Water District ID#: 4100970**

WTP: **TP - WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1/1/2023	0.0121	0.0122	0.0123	0.0125	0.0121	0.0121	0.0125
1/2/2023	0.0121	Off	Off	Off	Off	Off	0.0121
1/3/2023	Off	Off	Off	Off	Off	Off	Off
1/4/2023	Off	0.0132	0.0122	Off	Off	Off	0.0132
1/5/2023	Off	Off	Off	0.0122	0.0126	0.0122	0.0126
1/6/2023	0.0122	0.0122	0.0122	Off	Off	Off	0.0122
1/7/2023	Off	Off	Off	Off	Off	Off	Off
1/8/2023	Off	Off	Off	0.0136	0.0123	0.0124	0.0136
1/9/2023	0.0124	0.0123	0.0123	Off	0.0129	0.0123	0.0129
1/10/2023	Off	Off	Off	Off	Off	Off	Off
1/11/2023	Off	Off	Off	Off	Off	Off	Off
1/12/2023	Off	Off	Off	0.0128	0.0124	0.0123	0.0128
1/13/2023	Off	Off	0.0128	0.0123	0.0123	0.0123	0.0128
1/14/2023	0.0123	0.0123	Off	Off	Off	Off	0.0123
1/15/2023	Off	Off	Off	Off	Off	Off	Off
1/16/2023	Off	Off	0.0123	0.0122	0.0123	0.0123	0.0123
1/17/2023	0.0123	0.0123	0.0123	Off	Off	Off	0.0123
1/18/2023	Off	Off	Off	Off	Off	Off	Off
1/19/2023	Off	Off	0.0145	0.0121	0.0122	0.0121	0.0145
1/20/2023	0.0121	Off	Off	Off	Off	Off	0.0121
1/21/2023	Off	Off	Off	Off	Off	Off	Off
1/22/2023	0.0123	0.0121	0.0121	0.0121	0.0121	0.0121	0.0123
1/23/2023	Off	Off	Off	Off	Off	Off	Off
1/24/2023	Off	Off	Off	Off	Off	0.0122	0.0122
1/25/2023	0.0121	0.0121	0.0120	0.0121	0.0121	Off	0.0121
1/26/2023	Off	Off	Off	Off	Off	Off	Off
1/27/2023	Off	Off	Off	Off	Off	0.0128	0.0128
1/28/2023	0.0122	0.0121	0.0122	0.0122	0.0122	Off	0.0122
1/29/2023	Off	Off	Off	Off	Off	Off	Off
1/30/2023	Off	Off	Off	Off	Off	0.0123	0.0123
1/31/2023	0.0121	0.0122	0.0121	0.0121	0.0121	0.0121	0.0122

**Slow Sand/Membrane/DE Filtration/Unfiltered**

**Monthly Summary (Answer Yes or No)**

Rev. 7-2-18 T.N.T

95% of daily turbidity readings  $\leq$  1 NTU?<sup>2</sup>  Yes/ No

CT's met everyday? (see back)  Yes/ No

All Cl2 residual at entry point  $\geq$  0.2 mg/l?  Yes/ No

All daily turbidity readings  $\leq$  5 NTU?  Yes/ No

Yes/ No

Yes/ No

**Notes:**

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: **2/9/2023**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	Disinfection <i>Giardia</i> Log Inactiv: 0.5
ID#: 4100970	Month/Year: January-23

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.80	129	103.2	8.0	7.6	26.6	Yes	204
2	0.80	129	103.2	8.0	7.7	27.6	Yes	204
3	Off	129	Off	8.0	7.7	Off	Off	Off
4	0.80	129	103.2	8.0	7.7	27.6	Yes	204
5	0.80	129	103.2	8.0	7.6	26.6	Yes	201
6	1.00	129	129.0	8.0	7.7	28.2	Yes	202
7	Off	129	Off	9.0	7.7	Off	Off	Off
8	1.06	129	136.7	9.0	7.7	26.6	Yes	202
9	1.00	129	129.0	8.0	7.6	27.2	Yes	206
10	Off	129	Off	8.0	7.7	Off	Off	Off
11	Off	129	Off	8.0	7.7	Off	Off	Off
12	1.00	129	129.0	8.0	7.7	28.2	Yes	201
13	1.00	129	129.0	8.0	7.7	28.2	Yes	203
14	1.00	129	129.0	8.0	7.7	28.2	Yes	200
15	Off	129	Off	8.0	7.7	Off	Off	Off
16	0.80	129	103.2	8.0	7.7	27.6	Yes	202
17	0.90	129	116.1	8.0	7.7	27.9	Yes	202
18	Off	129	Off	8.0	7.8	Off	Off	Off
19	0.70	129	90.3	8.0	7.8	28.3	Yes	202
20	0.80	129	103.2	8.0	7.8	28.6	Yes	201
21	Off	129	Off	9.0	7.7	Off	Off	Off
22	0.90	129	116.1	9.0	7.8	27.0	Yes	202
23	Off	129	Off	8.0	7.8	Off	Off	Off
24	0.90	129	116.1	7.0	7.9	32.1	Yes	201
25	1.00	129	129.0	7.0	8.0	33.7	Yes	203
26	Off	129	Off	7.0	8.0	Off	Off	Off
27	0.80	129	103.2	7.0	8.0	32.9	Yes	202
28	1.00	129	129.0	8.0	8.0	31.4	Yes	202
29	Off	129	Off	7.0	8.0	Off	Off	Off
30	1.00	129	129.0	7.0	8.0	33.7	Yes	201
31	1.00	129	129.0	7.0	8.0	33.7	Yes	203

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

[dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350