

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Tillamook**

Month/Year: **Mar-23**

System Name: <b>Neskwin Regional Water District ID#: 4100970</b>		WTP: <b>TP - WTP-A</b>					
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
3/1/2023	Off	Off	Off	0.0122	0.0122	0.0122	0.0122
3/2/2023	0.0123	0.0122	Off	Off	Off	Off	0.0123
3/3/2023	Off	Off	Off	Off	Off	Off	Off
3/4/2023	Off	Off	0.0123	0.0123	0.0123	0.0123	0.0123
3/5/2023	Off	Off	Off	Off	Off	Off	Off
3/6/2023	Off	Off	Off	Off	Off	Off	Off
3/7/2023	Off	Off	Off	0.0122	0.0121	0.0121	0.0122
3/8/2023	0.0121	0.0121	Off	Off	Off	Off	0.0121
3/9/2023	Off	Off	Off	Off	Off	0.0123	0.0123
3/10/2023	0.0121	0.0121	0.0121	0.0121	Off	Off	0.0121
3/11/2023	Off	Off	Off	Off	Off	Off	Off
3/12/2023	Off	Off	Off	Off	0.0122	0.0123	0.0123
3/13/2023	0.0121	0.0123	0.0122	Off	Off	Off	0.0123
3/14/2023	Off	Off	Off	Off	Off	Off	Off
3/15/2023	Off	Off	Off	Off	Off	Off	Off
3/16/2023	Off	0.0121	0.0122	0.0121	0.0122	0.0121	0.0122
3/17/2023	0.0121	Off	Off	Off	Off	Off	0.0121
3/18/2023	Off	Off	Off	Off	Off	0.0123	0.0123
3/19/2023	0.0121	0.0122	0.0121	0.0121	0.0121	Off	0.0122
3/20/2023	Off	Off	Off	Off	Off	Off	Off
3/21/2023	Off	Off	0.0121	0.0121	0.0121	0.0121	0.0121
3/22/2023	0.0121	Off	Off	Off	Off	Off	0.0121
3/23/2023	Off	Off	Off	Off	Off	Off	Off
3/24/2023	Off	Off	Off	0.0122	0.0121	0.0121	0.0122
3/25/2023	0.0121	0.0121	0.0121	Off	Off	Off	0.0121
3/26/2023	Off	Off	Off	Off	Off	Off	Off
3/27/2023	Off	Off	0.0123	0.0121	0.0121	0.0121	0.0123
3/28/2023	0.0121	0.0121	0.0121	Off	Off	Off	0.0121
3/29/2023	Off	Off	Off	Off	Off	0.0122	0.0122
3/30/2023	0.0121	0.0121	0.0122	0.0121	0.0123	0.0122	0.0123
3/31/2023	Off	Off	Off	Off	Off	Off	Off

**Slow Sand/Membrane/DE Filtration/Unfiltered**

**Monthly Summary (Answer Yes or No)**

Rev. 7-2-18 T.N.T

95% of daily turbidity readings  $\leq$  1 NTU? <sup>2</sup>  Yes/ No

CT's met everyday? (see back)  Yes/ No

All Cl2 residual at entry point  $\geq$  0.2 mg/l?  Yes/ No

All daily turbidity readings  $\leq$  5 NTU?  Yes/ No

Yes/ No

Yes/ No

**Notes:**

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **4/3/2023**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:  
Neskowin  
Regional Water  
District

ID#: 4100970

Month/Year: March-23

Disinfection  
Giardia Log  
Inactiv: 0.5

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	0.80	129	103.2	5.0	7.8	35.1	Yes	202
2	1.09	129	140.6	7.0	8.1	35.3	Yes	200
3	Off	129	Off	7.0	8.0	Off	Off	Off
4	0.95	129	122.6	7.0	8.0	33.5	Yes	206
5	Off	129	Off	7.0	8.0	Off	Off	Off
6	Off	129	Off	6.0	7.8	Off	Off	Off
7	1.00	129	129.0	6.0	8.0	36.1	Yes	203
8	1.00	129	129.0	6.0	8.0	36.1	Yes	203
9	1.00	129	129.0	7.0	7.9	32.5	Yes	202
10	1.00	129	129.0	6.0	7.9	34.8	Yes	206
11	Off	129	Off	7.0	7.9	Off	Off	Off
12	1.00	129	129.0	7.0	7.8	31.3	Yes	204
13	0.95	129	122.6	7.0	8.0	33.5	Yes	201
14	Off	129	Off	7.0	8.0	Off	Off	Off
15	Off	129	Off	7.0	7.9	Off	Off	Off
16	0.90	129	116.1	7.0	7.9	32.1	Yes	201
17	1.00	129	129.0	7.0	8.0	33.7	Yes	200
18	1.00	129	129.0	8.0	8.0	31.4	Yes	207
19	1.00	129	129.0	8.0	8.0	31.4	Yes	201
20	Off	129	Off	8.0	8.0	Off	Off	Off
21	0.93	129	120.0	7.0	8.0	33.4	Yes	204
22	1.00	129	129.0	8.0	8.0	31.4	Yes	201
23	Off	129	Off	8.0	8.0	Off	Off	Off
24	0.90	129	116.1	8.0	8.0	31.1	Yes	203
25	0.90	129	116.1	8.0	8.0	31.1	Yes	202
26	Off	129	Off	8.0	8.0	Off	Off	Off
27	1.00	129	129.0	7.0	8.0	33.7	Yes	203
28	1.00	129	129.0	7.0	8.0	33.7	Yes	200
29	1.00	129	129.0	7.0	8.0	33.7	Yes	201
30	1.05	129	135.5	7.0	8.0	33.9	Yes	203
31	Off	129	Off	8.0	8.0	Off	Off	Off

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350