

**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Tillamook**

Month/Year: **Apr-23**

System Name: **Neskowin Regional Water District ID#: 4100970**

WTP: TP - **WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
4/1/2023	Off	Off	Off	Off	Off	Off	Off
4/2/2023	Off	Off	Off	Off	0.0122	0.0121	0.0122
4/3/2023	0.0122	0.0121	0.0121	0.0121	0.0122	0.0122	0.0122
4/4/2023	Off	Off	Off	Off	Off	Off	Off
4/5/2023	Off	Off	Off	Off	Off	0.0123	0.0123
4/6/2023	0.0123	0.0123	0.0124	0.0124	0.0124	Off	0.0124
4/7/2023	Off	Off	Off	Off	Off	Off	Off
4/8/2023	Off	Off	Off	Off	Off	Off	Off
4/9/2023	0.0123	0.0123	0.0124	0.0123	0.0125	Off	0.0125
4/10/2023	Off	Off	Off	Off	Off	Off	Off
4/11/2023	Off	Off	Off	Off	Off	Off	Off
4/12/2023	0.0131	Off	Off	Off	Off	Off	0.0131
4/13/2023	Off	Off	Off	Off	Off	Off	Off
4/14/2023	0.0131	0.0129	0.0127	0.0127	0.0128	0.0127	0.0131
4/15/2023	Off	Off	Off	Off	Off	Off	Off
4/16/2023	Off	Off	Off	Off	0.0135	0.0128	0.0135
4/17/2023	0.0128	0.0128	0.0128	0.0130	0.0128	0.0128	0.0130
4/18/2023	Off	Off	Off	Off	Off	Off	Off
4/19/2023	Off	Off	Off	0.0127	0.0128	0.0128	0.0128
4/20/2023	0.0128	0.0127	Off	Off	Off	Off	0.0128
4/21/2023	Off	Off	Off	0.0131	0.0131	0.0127	0.0131
4/22/2023	0.0127	Off	Off	Off	Off	Off	0.0127
4/23/2023	Off	Off	Off	Off	0.0132	0.0129	0.0132
4/24/2023	0.0132	0.0130	0.0129	0.0128	0.0129	Off	0.0132
4/25/2023	Off	Off	Off	Off	Off	Off	Off
4/26/2023	0.0129	0.0128	0.0130	0.0128	Off	Off	0.0130
4/27/2023	Off	Off	Off	Off	Off	Off	Off
4/28/2023	Off	Off	Off	Off	Off	Off	Off
4/29/2023	Off	Off	Off	Off	Off	Off	Off
4/30/2023	Off	Off	Off	0.0149	0.0128	0.0128	0.0149

**Slow Sand/Membrane/DE Filtration/Unfiltered**

**Monthly Summary (Answer Yes or No)**

Rev. 7-2-18 T.N.T

95% of daily turbidity readings  $\leq$  1 NTU? <sup>2</sup>  Yes/ No

CT's met everyday? (see back)  Yes/ No

All Cl2 residual at entry point  $\geq$  0.2 mg/l?  Yes/ No

All daily turbidity readings  $\leq$  5 NTU?  Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **5/9/2023**

PHONE #: **(503)392-3966**

CERT #: **D-08123 T-08076**

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:  
Neskowin  
Regional Water  
District

ID#: 4100970

Month/Year: April-23

Disinfection  
Giardia Log  
Inactiv:

0.5

Date / Time	Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	8.0	8.1	Off	Off	Off
2	0.99	129	127.7	7.0	8.0	33.6	Yes	204
3	1.00	129	129.0	7.0	8.0	33.7	Yes	203
4	Off	129	Off	7.0	8.0	Off	Off	Off
5	0.90	129	116.1	7.0	8.0	33.3	Yes	202
6	0.90	129	116.1	7.0	8.0	33.3	Yes	202
7	Off	129	Off	8.0	8.0	Off	Off	Off
8	Off	129	Off	8.0	8.0	Off	Off	Off
9	0.90	129	116.1	8.0	8.0	31.1	Yes	209
10	Off	129	Off	8.0	8.0	Off	Off	Off
11	Off	129	Off	8.0	8.0	Off	Off	Off
12	1.01	129	130.3	8.0	8.0	31.5	Yes	201
13	Off	129	Off	8.0	8.0	Off	Off	Off
14	0.98	129	126.4	9.0	8.0	29.3	Yes	221
15	Off	129	Off	9.0	8.0	Off	Off	Off
16	1.09	129	140.6	9.0	8.0	29.7	Yes	211
17	1.00	129	129.0	9.0	8.0	29.4	Yes	219
18	Off	129	Off	8.0	8.0	Off	Off	Off
19	1.00	129	129.0	8.0	8.0	31.4	Yes	202
20	1.00	129	129.0	8.0	8.0	31.4	Yes	202
21	1.00	129	129.0	8.0	8.0	31.4	Yes	204
22	1.00	129	129.0	9.0	8.0	29.4	Yes	206
23	1.00	129	129.0	9.0	8.0	29.4	Yes	206
24	1.00	129	129.0	9.0	8.0	29.4	Yes	208
25	Off	129	Off	9.0	8.0	Off	Off	Off
26	1.00	129	129.0	9.0	8.0	29.4	Yes	202
27	Off	129	Off	9.0	8.0	Off	Off	Off
28	Off	129	Off	9.0	8.0	Off	Off	Off
29	Off	129	Off	9.0	8.0	Off	Off	Off
30	0.85	129	109.7	10.0	8.0	27.0	Yes	209

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350