

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**

Month/Year: **Jun-23**

System Name: **Neskowin Regional Water District ID#: 4100970**

WTP: **TP - WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
6/1/2023	Off	Off	Off	Off	Off	Off	Off
6/2/2023	Off	Off	Off	0.0129	0.0126	0.0127	0.0129
6/3/2023	0.0127	0.0129	0.0127	0.0129	Off	Off	0.0129
6/4/2023	Off	Off	Off	Off	Off	Off	Off
6/5/2023	Off	Off	0.0135	0.0126	0.0126	0.0126	0.0135
6/6/2023	0.0127	0.0127	0.0128	0.0126	0.0126	0.0126	0.0128
6/7/2023	0.0126	0.0126	0.0132	0.0126	0.0127	0.0126	0.0132
6/8/2023	0.0127	0.0127	0.0126	Off	Off	Off	0.0127
6/9/2023	Off	Off	Off	Off	Off	0.0158	0.0158
6/10/2023	0.0126	0.0126	0.0126	0.0126	0.0126	0.0127	0.0127
6/11/2023	0.0126	Off	Off	Off	Off	Off	0.0126
6/12/2023	Off	Off	Off	0.0138	0.0126	0.0126	0.0138
6/13/2023	0.0127	0.0127	0.0127	0.0127	0.0129	Off	0.0129
6/14/2023	Off	Off	Off	Off	Off	Off	Off
6/15/2023	Off	Off	Off	0.0128	0.0127	0.0128	0.0128
6/16/2023	0.0131	0.0128	0.0127	0.0129	Off	Off	0.0131
6/17/2023	Off	Off	Off	Off	Off	Off	Off
6/18/2023	Off	Off	Off	0.0133	0.0127	0.0142	0.0142
6/19/2023	0.0133	0.0132	0.0127	0.0135	0.0131	0.0148	0.0148
6/20/2023	Off	Off	Off	Off	Off	Off	Off
6/21/2023	Off	Off	Off	Off	0.0129	Off	0.0129
6/22/2023	Off	Off	0.0133	0.0128	0.0130	0.0131	0.0133
6/23/2023	0.0131	0.0128	0.0127	0.0131	0.0133	Off	0.0133
6/24/2023	Off	Off	Off	Off	Off	Off	Off
6/25/2023	Off	0.0134	0.0128	0.0138	0.0130	0.0135	0.0138
6/26/2023	0.0131	0.0134	0.0129	0.0136	Off	Off	0.0136
6/27/2023	Off	Off	Off	Off	0.0131	0.0128	0.0131
6/28/2023	0.0135	0.0128	0.0130	0.0129	0.0134	0.0128	0.0135
6/29/2023	Off	Off	Off	0.0126	0.0122	0.0125	0.0126
6/30/2023	0.0125	Off	Off	Off	Off	Off	0.0125
7/1/2023	Off	Off	Off	0.0124	0.0125	0.0123	0.0125

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE:  DATE: **7/3/2023**

PHONE #: **(503)397-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	Disinfection <i>Giardia</i> Log Inactiv: 0.5
ID#: 4100970	Month/Year: June-23

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	Off	129	Off	11.0	8.0	Off	Off	Off
2	0.80	129	103.2	11.0	8.0	25.1	Yes	204
3	0.70	129	90.3	11.0	8.0	24.8	Yes	201
4	Off	129	Off	11.0	8.0	Off	Off	Off
5	0.60	129	77.4	11.0	8.0	24.5	Yes	202
6	0.80	129	103.2	11.0	8.0	25.1	Yes	204
7	0.80	129	103.2	11.0	8.0	25.1	Yes	202
8	0.71	129	91.6	10.0	7.4	21.5	Yes	205
9	0.70	129	90.3	11.0	7.5	20.8	Yes	201
10	0.85	129	109.7	10.0	7.5	22.6	Yes	204
11	0.79	129	101.9	10.0	7.6	23.2	Yes	200
12	0.70	129	90.3	11.0	8.0	24.8	Yes	204
13	0.70	129	90.3	12.0	8.0	23.2	Yes	201
14	Off	129	Off	12.0	8.0	Off	Off	Off
15	0.70	129	90.3	12.0	8.0	23.2	Yes	205
16	0.70	129	90.3	12.0	8.0	23.2	Yes	202
17	Off	129	Off	12.0	8.0	Off	Off	Off
18	0.70	129	90.3	12.0	8.0	23.2	Yes	202
19	0.70	129	90.3	11.0	8.0	24.8	Yes	202
20	Off	129	Off	11.0	8.0	Off	Off	Off
21	0.70	129	90.3	11.0	8.0	24.8	Yes	202
22	0.70	129	90.3	11.0	8.0	24.8	Yes	202
23	0.70	129	90.3	11.0	8.0	24.8	Yes	202
24	Off	129	Off	11.0	7.6	Off	Off	Off
25	0.85	129	109.7	11.0	7.6	21.9	Yes	205
26	0.80	129	103.2	11.0	8.0	25.1	Yes	201
27	0.80	129	103.2	12.0	8.0	23.5	Yes	202
28	0.70	129	90.3	12.0	8.0	23.2	Yes	205
29	0.70	129	90.3	12.0	8.0	23.2	Yes	202
30	0.80	129	103.2	12.0	8.0	23.5	Yes	201

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350