

OHA - Drinking Water Program - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**

Month/Year: **Jul-23**

System Name: Neskowin Regional Water District ID#: 4100970		WTP: TP - WTP-A					
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
7/1/2023	Off	Off	Off	0.0124	0.0123	0.0123	0.0124
7/2/2023	0.0124	0.0125	0.0125	0.0124	0.0123	0.0124	0.0125
7/3/2023	0.0124	0.0125	0.0125	0.0125	0.0124	0.0124	0.0125
7/4/2023	0.0125	0.0126	0.0125	0.0125	0.0124	0.0124	0.0126
7/5/2023	0.0125	0.0126	Off	Off	0.0125	0.0125	0.0126
7/6/2023	0.0126	0.0127	0.0126	0.0126	Off	Off	0.0127
7/7/2023	Off	Off	Off	Off	0.0126	0.0126	0.0126
7/8/2023	0.0126	0.0127	0.0126	0.0127	0.0126	0.0126	0.0127
7/9/2023	0.0126	Off	Off	Off	Off	Off	0.0126
7/10/2023	Off	Off	Off	0.0127	0.0126	0.0126	0.0127
7/11/2023	0.0126	0.0127	0.0127	0.0127	0.0127	0.0127	0.0127
7/12/2023	0.0127	Off	Off	Off	Off	Off	0.0127
7/13/2023	Off	0.0125	0.0128	0.0125	Off	0.0124	0.0128
7/14/2023	0.0131	0.0126	0.0128	0.0126	0.0126	0.0127	0.0131
7/15/2023	0.0131	0.0127	0.0128	Off	Off	Off	0.0131
7/16/2023	Off	Off	0.0126	0.0127	0.0127	0.0127	0.0127
7/17/2023	0.0130	Off	0.0134	0.0142	0.0134	0.0142	0.0142
7/18/2023	0.0132	0.0130	0.0129	Off	Off	Off	0.0132
7/19/2023	Off	Off	Off	0.0130	0.0129	0.0129	0.0130
7/20/2023	0.0131	0.0129	0.0143	0.0139	0.0149	0.0137	0.0149
7/21/2023	0.0141	Off	Off	Off	Off	Off	0.0141
7/22/2023	Off	Off	Off	Off	Off	Off	Off
7/23/2023	Off	Off	Off	Off	0.0127	0.0128	0.0128
7/24/2023	0.0131	0.0130	0.0128	Off	0.0126	0.0125	0.0131
7/25/2023	0.0126	0.0127	0.0125	0.0125	0.0124	0.0124	0.0127
7/26/2023	0.0126	0.0126	0.0124	0.0125	0.0125	0.0124	0.0126
7/27/2023	0.0126	0.0126	0.0124	0.0124	Off	Off	0.0126
7/28/2023	Off	Off	Off	Off	0.0123	0.0124	0.0124
7/29/2023	0.0125	0.0127	0.0124	0.0127	0.0124	0.0125	0.0127
7/30/2023	0.0125	0.0125	0.0124	0.0124	0.0124	0.0124	0.0125
7/31/2023	0.0127	0.0125	Off	Off	Off	Off	0.0127

Slow Sand/Membrane/DE Filtration/Unfiltered

Monthly Summary (Answer Yes or No)

Rev. 7-2-18 T.N.T

95% of daily turbidity readings ≤ 1 NTU?² Yes/ No

CT's met everyday? (see back) Yes/ No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/ No

All daily turbidity readings ≤ 5 NTU? Yes/ No

Yes/ No

Yes/ No

Notes:

PRINTED NAME: **Troy N. Trute**

SIGNATURE: 

DATE: **8/1/2023**

PHONE #: **(503)397-3966**

CERT #: **D-08123 T-08076**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Neskowin Regional Water District	ID#: 4100970	Month/Year: July-23	Disinfection Giardia Log Inactiv: 0.5
--	--------------	---------------------	---

Date / Time	Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.70	129	90.3	12.0	8.0	23.2	Yes	205
2	0.70	129	90.3	12.0	8.0	23.2	Yes	203
3	0.80	129	103.2	12.0	8.0	23.5	Yes	202
4	0.85	129	109.7	11.0	7.7	22.7	Yes	206
5	0.80	129	103.2	12.0	8.0	23.5	Yes	201
6	0.80	129	103.2	12.0	8.0	23.5	Yes	203
7	0.80	129	103.2	12.0	8.0	23.5	Yes	202
8	0.98	129	126.4	12.0	7.8	22.3	Yes	201
9	0.91	129	117.4	12.0	7.8	22.2	Yes	201
10	0.80	129	103.2	13.0	8.0	22.0	Yes	201
11	0.80	129	103.2	13.0	8.0	22.0	Yes	204
12	0.80	129	103.2	13.0	8.0	22.0	Yes	201
13	0.80	129	103.2	13.0	8.0	22.0	Yes	202
14	0.80	129	103.2	13.0	8.0	22.0	Yes	206
15	0.80	129	103.2	13.0	8.0	22.0	Yes	205
16	0.70	129	90.3	13.0	8.0	21.8	Yes	207
17	0.71	129	91.6	13.0	7.8	20.2	Yes	207
18	0.80	129	103.2	13.0	8.0	22.0	Yes	202
19	0.70	129	90.3	13.0	8.0	21.8	Yes	205
20	0.80	129	103.2	13.0	8.0	22.0	Yes	202
21	0.70	129	90.3	13.0	8.0	21.8	Yes	202
22	Off	129	Off	13.0	7.8	Off	Off	Off
23	0.65	129	83.9	13.0	7.8	20.1	Yes	201
24	0.75	129	96.8	13.0	7.8	20.3	Yes	204
25	0.80	129	103.2	13.0	8.0	22.0	Yes	202
26	0.80	129	103.2	14.0	8.0	20.6	Yes	205
27	0.80	129	103.2	14.0	8.0	20.6	Yes	206
28	0.70	129	90.3	14.0	8.0	20.4	Yes	205
29	0.80	129	103.2	14.0	8.0	20.6	Yes	201
30	0.80	129	103.2	14.0	8.0	20.6	Yes	201
31	0.80	129	103.2	14.0	8.0	20.6	Yes	201

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dpw.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350