

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP:-WTP-A: MARCH 2024

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							0
2							0
3							0
4			0.02	0.02			0.02
5							0
6							0
7							0
8			0.02	0.02			0.02
9							0
10							0
11			0.02	0.02			0.02
12							0
13							0
14							0
15			0.02	0.02			0.02
16							0
17							0
18			0.02	0.02			0.02
19							0
20			0.03	0.05			0.05
21							0
22			0.03	0.02			0.03
23							0
24							0
25							0
26			0.02				0.02
27			0.02	0.02			0.02
28							0
29							0
30							0
31							0

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No <sup>2</sup>		
Notes:	PRINTED NAME: Steven Bethke	
	SIGNATURE: <i>Steven Bethke</i>	DATE: 4-3-24
	PHONE #: 541-592-3254	CERT#:6609

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

<sup>2</sup>IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A

MARCH 2024

Req. Log  
Inactivate:1

DATE/ TIME	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand	
	mg/L	minutes	CXT	° C		Use tables	Yes / No	[GPM]	
1 /								0	
2 /								0	
3 /								0	
4 /	7:14	1.00	193	193	8	7.5	60	Yes	1581
5 /								0	
6 /								0	
7 /								0	
8 /	7:08	1.10	187	206	7	7.7	61	Yes	1581
9 /								0	
10 /								0	
11 /	7:01	1.10	232	255	8	7.5	61	Yes	1581
12 /								0	
13 /								0	
14 /								0	
15 /	7:23	1.00	191	191	9	7.5	60	Yes	1581
16 /								0	
17 /								0	
18 /	7:28	1.10	259	285	9	7.5	61	Yes	1581
19 /								0	
20 /	7:27	1.00	186	186	10	7.5	45	Yes	1581
21 /								0	
22 /	7:00	1.10	213	234	10	7.5	46	Yes	1581
23 /								0	
24 /								0	
25 /								0	
26 /	6:59	1.10	301	331	9	7.5	61	Yes	1581
27 /	6:58	1.10	214	236	10	7.5	46	Yes	1581
28 /								0	
29 /								0	
30 /								0	
31 /								0	

<sup>3</sup>If Cl<sub>2</sub> at entry point , < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.