

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP:-WTP-A: JANUARY 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							0
2			0.04	0.04	0.04		0.04
3							0
4							0
5							0
6			0.03	0.03	0.03		0.03
7			0.03	0.02			0.03
8							0
9			0.02	0.02	0.04		0.04
10			0.03	0.03	0.03		0.03
11							0
12							0
13							0
14			0.03	0.03	0.02		0.03
15							0
16							0
17			0.02	0.02	0.02		0.02
18							0
19							0
20							0
21				0.02	0.02		0.02
22			0.02	0.02			0.02
23							0
24			0.02	0.02	0.02		0.02
25							0
26							0
27			0.02	0.02	0.02		0.02
28							0
29			0.02	0.02	0.02		0.02
30							0
31							0

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
Notes:	PRINTED NAME: Steven Bethke	
	SIGNATURE: <i>Steven Bethke</i>	DATE: 2-4-25
	PHONE #: 541-592-3254	CERT#:6609

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A JANUARY 2025								Req. Log Inactivate:1	
DATE/ TIME	Minimum Cl ₂ Residual at 1st User (C) ^a	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand	
	mg/L	minutes	CXT	°C		Use tables	Yes / No	[GPM]	
1 /								0	
2 /	9:07	1.00	208	208	9	7.5	60	Yes	1581
3 /									0
4 /									0
5 /									0
6 /	9:24	1.10	189	208	9	7.4	61	Yes	1581
7 /	8:10	1.10	254	279	10	7.5	46	Yes	1581
8 /									0
9 /	7:02	1.00	193	193	9	7.5	60	Yes	1581
10 /	9:55	1.10	251	276	9	7.7	61	Yes	1581
11 /									0
12 /									0
13 /									0
14 /	7:12	1.00	217	217	8	7.7	60	Yes	1581
15 /									0
16 /									0
17 /	7:40	1.10	171	188	8	7.4	61	Yes	1581
18 /									0
19 /									0
20 /									0
21 /	11:12	1.00	225	225	8	7.6	60	Yes	1581
22 /	8:32	1.00	257	257	7	7.7	60	Yes	1581
23 /									0
24 /	7:09	1.00	187	187	7	7.4	60	Yes	1581
25 /									0
26 /									0
27 /	9:06	1.00	220	220	7	7.5	60	Yes	1581
28 /									0
29 /	7:37	1.00	239	239	7	7.6	60	Yes	1385
30 /									0
31 /									0

^aIf Cl₂ at entry point , < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.