

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP-:WTP-A: NOVEMBER 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							0
2							0
3			0.02	0.02			0.02
4			0.02	0.02	0.02		0.02
5							0
6							0
7							0
8			0.09	0.09	0.08		0.09
9							0
10			0.08	0.09	0.09		0.09
11							0
12			0.09	0.09	0.08		0.09
13				0.07	0.07		0.07
14			0.05	0.04	0.03		0.05
15							0
16							0
17			0.02	0.02	0.02		0.02
18			0.02	0.02	0.02		0.02
19							0
20			0.02	0.02	0.02		0.02
21			0.02	0.02	0.02		0.02
22							0
23							0
24				0.02	0.02		0.02
25							0
26			0.02	0.02	0.02		0.02
27							0
28							0
29			0.02	0.02	0.02		0.02
30							0
31							0

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl_2 residuals at entry point $\geq$ 0.2 mg/l?
All the 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers?	Yes / No ²		
Notes:		PRINTED NAME: Steven Bethke	
		SIGNATURE: <i>Steven Bethke</i>	DATE: 12-2-25
		PHONE #: 541-592-3254	CERT#: 6609

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A NOVEMBER 2025								Req. Log Inactivate:1	
DATE/ TIME	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand	
	mg/L	minutes	C X T	° C		Use tables	Yes / No	[GPM]	
1 /								0	
2 /								0	
3 /	8:23	1.00	285	285	14	7.4	45	Yes	1504
4 /	9:11	1.10	280	308	13	7.4	46	Yes	1488
5 /									0
6 /									0
7 /									0
8 /	9:30	1.00	340	340	13	7.4	45	Yes	869
9 /									0
10 /	9:23	0.60	278	167	13	7.6	43	Yes	1184
11 /									0
12 /	9:30	0.50	303	151	13	7.6	43	Yes	1174
13 /	11:21	0.90	262	236	13	7.7	45	Yes	1207
14 /	8:15	1.30	221	287	13	7.5	47	Yes	1196
15 /									0
16 /	0:00								0
17 /	7:11	1.00	250	250	13	7.5	45	Yes	1188
18 /	7:10	1.10	230	253	13	7.5	46	Yes	1192
19 /									0
20 /	7:08	0.90	206	186	12	7.5	45	Yes	1189
21 /	7:09	1.10	197	217	12	7.5	46	Yes	1561
22 /									0
23 /									0
24 /	9:12	1.00	222	222	11	7.4	45	Yes	1553
25 /									0
26 /	7:26	1.00	209	209	11	7.4	45	Yes	1549
27 /									0
28 /									0
29 /	7:37	1.00	232	232	11	7.4	45	Yes	1557
30 /									0
31 /									

³If Cl₂ at entry point , < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf