

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP:-WTP-A: DECEMBER 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			0.02	0.02			0.02
2							0
3				0.02	0.02		0.02
4							0
5			0.02	0.02	0.02		0.02
6							0
7							0
8			0.02	0.02	0.02		0.02
9			0.02	0.02	0.02		0.02
10				0.02	0.02		0.02
11							0
12			0.02	0.02	0.02		0.02
13							0
14							0
15			0.02	0.02			0.02
16			0.02	0.02			0.02
17							0
18			0.02	0.02	0.03		0.03
19							0
20							0
21							0
22							0
23			0.04	0.03	0.02		0.04
24							0
25							0
26			0.02	0.02	0.02		0.02
27							0
28							0
29			0.03	0.03	0.03		0.03
30							0
31							0

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No <sup>2</sup>		
Notes:	PRINTED NAME: Steven Bethke	
	SIGNATURE: <i>Steven Bethke</i>	DATE: 1-5-26
	PHONE #: 541-592-3254	CERT#:6609

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

<sup>2</sup>IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

**CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A      DECEMBER 2025**

Req. Log  
Inactivate:1

DATE/ TIME		Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand
		mg/L	minutes	C X T	° C		Use tables	Yes / No	[GPM]
1 /	7:23	1.00	361	361	11	7.5	45	Yes	1192
2 /									0
3 /	10:37	1.00	225	225	10	7.5	45	Yes	1588
4 /									0
5 /	9:34	1.00	168	168	10	7.5	45	Yes	1520
6 /									0
7 /									0
8 /	7:13	1.10	176	193	11	7.4	46	Yes	1539
9 /	7:13	1.10	184	202	11	7.5	46	Yes	1537
10 /	7:09	1.10	260	286	12	7.5	46	Yes	1545
11 /									0
12 /	5:30	1.00	193	193	12	7.4	45	Yes	1570
13 /									0
14 /									0
15 /	8:18	1.10	299	329	10	7.5	46	Yes	1336
16 /	7:17	1.10	337	370	10	7.5	46	Yes	1328
17 /									0
18 /	7:14	1.10	229	252	11	7.5	46	Yes	1550
19 /									0
20 /									0
21 /									0
22 /									0
23 /	7:12	0.70	216	151	10	7.5	44	Yes	1578
24 /									0
25 /									0
26 /	7:17	1.00	232	232	9	7.5	60	Yes	1557
27 /									0
28 /									0
29 /	8:31	0.90	215	194	9	7.5	60	Yes	1575
30 /									0
31 /									0

<sup>3</sup>If Cl<sub>2</sub> at entry point , < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.