

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP-:WTP-A: JANUARY 2026							
DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							0
2			0.02	0.02	0.02		0.02
3							0
4							0
5							0
6							0
7			0.02	0.02	0.02		0.02
8				0.02	0.02		0.02
9							0
10							0
11							0
12			0.02	0.02	0.02		0.02
13							0
14				0.02	0.02		0.02
15							0
16			0.02	0.02	0.02		0.02
17							0
18							0
19							0
20							0
21			0.02	0.02	0.02		0.02
22							0
23			0.01	0.01	0.02		0.02
24							0
25							0
26							0
27							0
28				0.02	0.02		0.02
29							0
30			0.02	0.02	0.01		0.02
31							0

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4-hour turbidity readings $\leq$ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / No <sup>2</sup>		
Notes:	PRINTED NAME: Steven Bethke	
	SIGNATURE: <i>Steven Bethke</i>	DATE: 2-2-26
	PHONE #: 541-592-3254	CERT#:6609

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

<sup>2</sup>IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program - Surface Water Quality Data Form

CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A

JANUARY 2026

Req. Log  
Inactivate:1

DATE/ TIME	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand	
	mg/L	minutes	CXT	°C		Use tables	Yes / No	[GPM]	
1 /	0:00	0.00	0	0	0	0	Yes	0	
2 /	7:18	1.10	194	214	8	7.5	61	Yes	1564
3 /								0	
4 /								0	
5 /								0	
6 /								0	
7 /	7:44	1.20	177	212	9	7.5	61	Yes	1564
8 /	11:43	1.40	257	360	9	7.5	62	Yes	1555
9 /								0	
10 /								0	
11 /								0	
12 /	7:51	1.10	193	212	8	7.5	61	Yes	1566
13 /								0	
14 /	10:27	1.20	6	7	7	7.5	61	Yes	1568
15 /								0	
16 /	7:18	1.20	210	252	7	7.4	61	Yes	1260
17 /								0	
18 /								0	
19 /								0	
20 /								0	
21 /	7:30	1.00	186	186	7	7.5	60	Yes	1568
22 /								0	
23 /	7:09	1.10	173	190	7	7.4	61	Yes	1564
24 /								0	
25 /								0	
26 /								0	
27 /								0	
28 /	11:21	1.10	280	308	7	7.5	61	Yes	1167
29 /								0	
30 /	7:17	1.10	171	188	8	7.5	61	Yes	1560
31 /								0	

<sup>3</sup>If Cl<sub>2</sub> at entry point, < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.