

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP:-WTP-A: FEBRUARY 2026

| DAY | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|----------------------------------|
| 1 | | | | | | | 0 |
| 2 | | | | | | | 0 |
| 3 | | | 0.02 | 0.02 | | | 0.02 |
| 4 | | | | | | | 0 |
| 5 | | | 0.02 | 0.02 | 0.02 | | 0.02 |
| 6 | | | | | | | 0 |
| 7 | | | | | | | 0 |
| 8 | | | | | | | 0 |
| 9 | | | | | | | 0 |
| 10 | | | 0.02 | 0.02 | 0.02 | | 0.02 |
| 11 | | | | | | | 0 |
| 12 | | | 0.02 | 0.02 | 0.02 | | 0.02 |
| 13 | | | 0.02 | 0.02 | 0.02 | | 0.02 |
| 14 | | | | | | | 0 |
| 15 | | | | | | | 0 |
| 16 | | | | | | | 0 |
| 17 | | | | | | | 0 |
| 18 | | | 0.02 | 0.02 | 0.01 | | 0.02 |
| 19 | | | | | | | 0 |
| 20 | | | | 0.02 | 0.01 | | 0.02 |
| 21 | | | | | | | 0 |
| 22 | | | | | | | 0 |
| 23 | | | | | | | 0 |
| 24 | | | | | | | 0 |
| 25 | | | 0.02 | 0.02 | | | 0.02 |
| 26 | | | 0.03 | 0.04 | 0.03 | | 0.04 |
| 27 | | | | | | | 0 |
| 28 | | | | | | | 0 |
| 29 | | | | | | | |
| 30 | | | | | | | |
| 31 | | | | | | | |

| Conventional or Direct Filtration | Monthly Summary (Answer Yes or No) | |
|--|---|---|
| 95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / No | CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No | All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / No |
| All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / No | | |
| All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / No ² | | |
| Notes: | PRINTED NAME: Steven Bethke | |
| | SIGNATURE: <i>Steven Bethke</i> | DATE: 3-3-26 |
| | PHONE #: 541-592-3254 | CERT#:6609 |

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C)

OHA - Drinking Water Program - Surface Water Quality Data Form

CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A FEBRUARY 2026

Req. Log
Inactivate:1

| DATE/ TIME | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand | |
|------------|---|-----------------------|--------------|------|----|----------------|----------------------|--------------------------|------|
| | mg/L | minutes | C X T | ° C | | Use tables | Yes / No | [GPM] | |
| 1 / | | | | | | | | 0 | |
| 2 / | | | | | | | | 0 | |
| 3 / | 6:45 | 1.00 | 280 | 280 | 9 | 7.7 | 60 | Yes | 1338 |
| 4 / | | | | | | | | | 0 |
| 5 / | 9:08 | 1.00 | 182 | 182 | 8 | 7.4 | 60 | Yes | 1580 |
| 6 / | | | | | | | | | 0 |
| 7 / | | | | | | | | | 0 |
| 8 / | | | | | | | | | 0 |
| 9 / | | | | | | | | | 0 |
| 10 / | 8:52 | 0.90 | 200 | 180 | 9 | 7.5 | 60 | Yes | 1577 |
| 11 / | | | | | | | | | 0 |
| 12 / | 8:12 | 0.90 | 298 | 268 | 9 | 7.4 | 60 | Yes | 1563 |
| 13 / | 10:08 | 1.00 | 257 | 257 | 9 | 7.4 | 60 | Yes | 1573 |
| 14 / | | | | | | | | | 0 |
| 15 / | | | | | | | | | 0 |
| 16 / | | | | | | | | | 0 |
| 17 / | | | | | | | | | 0 |
| 18 / | 7:25 | 0.90 | 184 | 165 | 9 | 7.4 | 60 | Yes | 1551 |
| 19 / | | | | | | | | | 0 |
| 20 / | 9:14 | 1.00 | 211 | 211 | 8 | 7.4 | 60 | Yes | 1565 |
| 21 / | | | | | | | | | 0 |
| 22 / | | | | | | | | | 0 |
| 23 / | | | | | | | | | 0 |
| 24 / | | | | | | | | | 0 |
| 25 / | 9:13 | 0.90 | 239 | 215 | 8 | 7.4 | 60 | Yes | 1578 |
| 26 / | 8:14 | 1.10 | 200 | 220 | 9 | 7.4 | 61 | Yes | 1571 |
| 27 / | | | | | | | | | 0 |
| 28 / | | | | | | | | | 0 |
| 29 / | | | | | | | | | |
| 30 / | | | | | | | | | |
| 31 / | | | | | | | | | |

³If Cl₂ at entry point , < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.