

Conventional or Direct Filtration

System Name: CAVE JUNCTION, CITY OF #OR4100971 WTP:-WTP-A: MARCH 2026							
DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							0
2				0.03	0.03		0.03
3							0
4				0.03	0.02		0.03
5							0
6			0.02	0.02	0.02		0.02
7							0
8							0
9							0
10				0.02	0.02		0.02
11				0.02	0.02		0.02
12				0.02	0.02		0.02
13							0
14							0
15							0
16				0.02	0.02		0.02
17							0
18				0.01	0.02		0.02
19							0
20			0.01	0.01	0.01		0.01
21							0
22							0
23				0.01	0.01		0.01
24							0
25			0.02	0.02	0.02		0.02
26							0
27			0.02	0.02	0.02		0.02
28							0
29							0
30			0.02	0.02	0.01		0.02
31			0.01	0.01	0.02		0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residuals at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:	PRINTED NAME: Steven Bethke	
	SIGNATURE: <i>Steven Bethke</i>	DATE: 4-9-26
	PHONE #: 541-592-3254	CERT#:6609

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12AM" through "8PM" may not correspond to continuous readings' maximum.

²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

CAVE JUNCTION, CITY OF ID# OR4100971 WTP - A		MARCH 2026		Req. Log Inactivate:1					
DATE/ TIME	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand	
	mg/L	minutes	CXT	° C		Use tables	Yes / No	[GPM]	
1 /								0	
2 /	9:36	1.00	209	209	9	7.5	60	Yes	1562
3 /									0
4 /	10:05	1.00	218	218	10	7.4	45	Yes	1575
5 /									0
6 /	8:18	1.10	166	183	10	7.4	46	Yes	1566
7 /									0
8 /									0
9 /									0
10 /	11:38	1.00	226	226	10	7.4	45	Yes	1585
11 /	11:07	1.00	217	217	10	7.4	45	Yes	1580
12 /	10:09	1.00	253	253	10	7.4	45	Yes	1562
13 /									0
14 /									0
15 /									0
16 /	10:12	0.90	232	209	11	7.5	45	Yes	1570
17 /									0
18 /	10:15	0.90	217	196	11	7.5	45	Yes	1578
19 /									0
20 /	7:47	1.00	164	164	12	7.5	45	Yes	1583
21 /									0
22 /									0
23 /	11:23	0.90	233	210	12	7.5	45	Yes	1578
24 /									0
25 /	8:21	0.90	175	157	12	7.5	45	Yes	1585
26 /									0
27 /	8:00	1.00	158	158	12	7.6	45	Yes	1581
28 /									0
29 /									0
30 /	7:57	0.90	167	150	12	7.5	45	Yes	1610
31 /	7:35	1.00	210	210	12	7.5	45	Yes	1552

³If Cl₂ at entry point , < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.