


System Name: Hillsboro-Cherry Grove

ID#: 41 00985-A

Month/Year: Aug-24

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.08				0.08
2			0.08				0.08
3			0.08				0.08
4			0.08				0.08
5			0.08				0.08
6			0.08				0.08
7			0.08				0.08
8			0.08				0.08
9			0.08				0.08
10			0.08				0.08
11			0.08				0.08
12			0.10				0.10
13			0.08				0.08
14			0.08				0.08
15			0.08				0.08
16			0.08				0.08
17			0.08				0.08
18			0.08				0.08
19			0.08				0.08
20			0.08				0.08
21			0.08				0.08
22			0.08				0.08
23			0.08				0.08
24			0.09				0.09
25			0.09				0.09
26			0.09				0.09
27			0.09				0.09
28			0.09				0.09
29			0.10				0.10
30			0.09				0.09
31			0.09				0.09

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No	<input checked="" type="checkbox"/> Yes / No
Notes:	PRINTED NAME: Todd Evers		Cert: T-6149
	SIGNATURE: 		DATE:
	PHONE #: (541) 497-3945		9/4/2024

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove **ID#: 41 00985-A** **Month / Year:** Aug-24 **Disinfection Giardia Log Inactiv:** 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:30	1.59	302	480	16.4	7.12	27.7	Yes	625
2	8:30	1.63	328	535	16.6	7.12	27.5	Yes	575
3	9:15	1.54	290	447	16.8	7.12	26.9	Yes	650
4	9:15	1.67	302	504	16.7	7.11	27.3	Yes	625
5	9:15	1.66	302	501	16.8	7.11	27.1	Yes	625
6	8:45	1.70	290	494	16.7	7.11	27.4	Yes	650
7	10:15	1.73	302	522	16.9	7.10	27.1	Yes	625
8	9:30	1.60	302	483	17.0	7.11	26.6	Yes	625
9	10:45	1.68	302	507	18.9	7.09	23.4	Yes	625
10	10:15	1.67	290	485	17.3	7.10	26.2	Yes	650
11	15:00	1.65	302	498	18.8	7.08	23.4	Yes	625
12	9:45	1.67	302	504	17.2	7.10	26.3	Yes	625
13	10:15	1.64	315	516	17.0	7.10	26.6	Yes	600
14	8:30	1.72	302	519	16.1	7.11	28.6	Yes	625
15	8:30	1.60	302	483	16.7	7.12	27.2	Yes	625
16	9:00	1.67	302	504	16.4	7.12	28.0	Yes	625
17	7:30	1.71	302	516	16.3	7.12	28.3	Yes	625
18	8:00	1.70	315	535	16.4	7.12	28.1	Yes	600
19	8:45	1.73	343	594	16.3	7.11	28.3	Yes	550
20	9:30	1.74	444	773	16.7	7.10	27.5	Yes	425
21	9:30	1.50	315	472	16.6	7.12	27.1	Yes	600
22	9:15	1.68	377	634	16.5	7.11	27.7	Yes	500
23	10:00	1.72	360	618	16.4	7.10	27.9	Yes	525
24	10:00	1.73	343	594	16.2	7.11	28.5	Yes	550
25	9:15	1.84	419	772	16.1	7.10	28.9	Yes	450
26	9:00	1.73	360	622	16.1	7.11	28.7	Yes	525
27	8:45	1.77	472	835	16.6	7.11	27.8	Yes	400
28	9:30	1.76	419	738	16.4	7.11	28.2	Yes	450
29	8:45	1.70	328	558	16.6	7.11	27.6	Yes	575
30	10:30	1.63	419	684	17.2	7.11	26.3	Yes	450
31	12:00	1.71	397	679	18.4	7.10	24.4	Yes	475

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013