

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove				ID#: 41 00985-A		Month/Year: Jan-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.14				0.14
2			0.13				0.13
3			0.13				0.13
4			0.13				0.13
5			0.12				0.12
6			0.13				0.13
7			0.13				0.13
8			0.09				0.09
9			0.09				0.09
10			0.09				0.09
11			0.09				0.09
12			0.08				0.08
13			0.08				0.08
14			0.08				0.08
15			0.07				0.07
16			0.07				0.07
17			0.06				0.06
18			0.06				0.06
19			0.06				0.06
20			0.06				0.06
21			0.06				0.06
22			0.06				0.06
23			0.06				0.06
24			0.05				0.05
25			0.06				0.06
26			0.06				0.06
27			0.05				0.05
28			0.06				0.06
29			0.05				0.05
30			0.05				0.05
31			0.05				0.05

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	☒ Yes / No	CT's met everyday? (see back)	☒ Yes / No
All daily turbidity readings ≤ 5 NTU?	☒ Yes / No	☒ Yes / No	☒ Yes / No
Notes:		PRINTED NAME: Todd Evers	
		SIGNATURE:	
		PHONE #: (541)497-3945	
		Cert: T-6149	
		DATE: 02/04/25	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove **ID#: 41 00985-A** **Month / Year:** Jan-25 **Disinfection**
Giardia Log **1**
Inactiv:

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	9:30	1.76	539	949	8.4	7.19	50.0	Yes	350
2	9:15	1.81	581	1051	8.5	7.18	49.7	Yes	325
3	9:30	1.65	539	890	8.6	7.20	48.8	Yes	350
4	9:30	1.77	472	835	8.4	7.20	50.2	Yes	400
5	8:45	1.74	503	876	8.6	7.09	47.5	Yes	375
6	9:00	1.84	503	926	8.4	7.08	48.5	Yes	375
7	9:30	1.82	539	981	8.2	7.07	48.8	Yes	350
8	8:15	1.76	503	886	8.2	7.08	48.7	Yes	375
9	10:00	1.73	581	1005	7.9	7.08	49.5	Yes	325
10	9:00	1.76	472	830	7.8	7.08	50.0	Yes	400
11	9:30	1.68	503	846	7.8	7.09	49.7	Yes	375
12	9:30	1.69	539	911	7.8	7.09	49.8	Yes	350
13	10:00	1.63	503	820	7.4	7.09	50.8	Yes	375
14	9:30	1.66	503	836	7.5	7.10	50.8	Yes	375
15	8:30	1.78	503	896	7.3	7.09	52.0	Yes	375
16	7:30	1.82	503	916	7.1	7.09	52.9	Yes	375
17	9:00	1.82	539	981	6.9	7.10	53.9	Yes	350
18	10:00	1.83	503	921	6.6	7.10	55.0	Yes	375
19	10:30	1.83	503	921	6.3	7.10	56.1	Yes	375
20	11:00	1.86	503	936	6.2	7.10	56.7	Yes	375
21	8:00	1.92	503	966	5.9	7.11	58.5	Yes	375
22	10:00	1.83	472	864	5.7	7.12	58.9	Yes	400
23	10:15	1.85	503	931	5.7	7.12	59.0	Yes	375
24	8:30	1.83	472	864	5.7	7.13	59.1	Yes	400
25	11:30	1.78	503	896	5.8	7.13	58.4	Yes	375
26	14:00	1.81	539	976	6.4	7.13	56.2	Yes	350
27	8:00	1.95	503	981	5.3	7.15	62.0	Yes	375
28	7:45	1.91	539	1030	5.2	7.15	62.2	Yes	350
29	8:00	1.81	539	976	5.0	7.16	62.5	Yes	350
30	7:45	1.79	539	965	5.2	7.17	61.8	Yes	350
31	8:00	1.8	503	906	5.6	7.17	60.2	Yes	375

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013