

System Name: Hillsboro-Cherry Grove				ID#: 41 00985-A		Month/Year: Feb-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.06				0.06
2			0.05				0.05
3			0.06				0.06
4			0.06				0.06
5			0.06				0.06
6			0.06				0.06
7			0.06				0.06
8			0.07				0.07
9			0.07				0.07
10			0.06				0.06
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.08				0.08
15			0.08				0.08
16			0.08				0.08
17			0.07				0.07
18			0.07				0.07
19			0.06				0.06
20			0.07				0.07
21			0.07				0.07
22			0.07				0.07
23			0.07				0.07
24			0.06				0.06
25			0.06				0.06
26			0.07				0.07
27			0.07				0.07
28			0.07				0.07

Slow Sand/Membrane/DE Filtration/Unfiltered				Monthly Summary (Answer Yes or No)			
95% of daily turbidity readings ≤ 1 NTU? ²		☒ Yes / No		CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?	
All daily turbidity readings ≤ 5 NTU?		☒ Yes / No		☒ Yes / No		☒ Yes / No	
Notes:				PRINTED NAME: Todd Evers		Cert: T-6149	
				SIGNATURE:		DATE:	
				PHONE #: (541) 497-3945		3/4/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove
ID#: 41 00985-A
Month / Year: Feb-25
Disinfection Giardia Log Inactiv: 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:30	1.82	472	859	5.8	7.18	59.7	Yes	400
2	9:30	1.94	503	976	5.5	7.17	61.6	Yes	375
3	8:30	1.98	581	1150	5.5	7.17	61.9	Yes	325
4	7:45	1.92	581	1115	5.3	7.19	62.7	Yes	325
5	8:30	1.7	629	1070	5.5	7.21	60.7	Yes	300
6	7:30	1.73	444	768	5.4	7.23	61.8	Yes	425
7	8:45	1.74	472	821	5.1	7.17	61.8	Yes	400
8	10:00	1.76	472	830	5.5	7.16	60.1	Yes	400
9	8:30	1.79	503	901	5.4	7.17	60.9	Yes	375
10	9:00	1.83	503	921	5.0	7.16	62.7	Yes	375
11	7:15	1.74	503	876	4.9	7.18	62.9	Yes	375
12	11:00	1.91	503	961	5.0	7.16	63.2	Yes	375
13	9:00	1.85	581	1074	5.0	7.18	63.3	Yes	325
14	8:15	1.75	444	777	5.2	7.17	61.5	Yes	425
15	10:45	1.77	503	891	5.3	7.16	61.0	Yes	375
16	12:00	1.84	503	926	5.8	7.15	59.2	Yes	375
17	11:30	1.79	503	901	6.3	7.14	56.7	Yes	375
18	8:30	1.79	503	901	5.5	7.16	60.3	Yes	375
19	8:00	1.85	472	873	5.9	7.15	58.9	Yes	400
20	8:45	1.79	472	845	5.8	7.15	58.9	Yes	400
21	10:15	1.83	539	987	6.3	7.15	57.2	Yes	350
22	9:30	1.87	472	882	6.7	7.14	55.7	Yes	400
23	13:15	1.72	503	866	7.6	6.98	48.7	Yes	375
24	9:30	1.68	581	976	7.0	6.97	50.3	Yes	325
25	9:00	1.81	444	804	6.4	7.10	55.6	Yes	425
26	8:30	1.74	503	876	6.5	7.11	55.0	Yes	375
27	9:00	1.71	539	922	6.7	7.01	52.2	Yes	350
28	8:45	1.83	581	1063	6.8	7.06	53.5	Yes	325

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013