

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove			ID#: 41 00985-A		Month/Year: Mar-25		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.07				0.07
2			0.08				0.08
3			0.07				0.07
4			0.07				0.07
5			0.07				0.07
6			0.07				0.07
7			0.07				0.07
8			0.07				0.07
9			0.06				0.06
10			0.06				0.06
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.06				0.06
15			0.06				0.06
16			0.06				0.06
17			0.06				0.06
18			0.06				0.06
19			0.06				0.06
20			0.06				0.06
21			0.06				0.06
22			0.06				0.06
23			0.07				0.07
24			0.06				0.06
25			0.05				0.05
26			0.06				0.06
27			0.06				0.06
28			0.06				0.06
29			0.06				0.06
30			0.06				0.06
31			0.06				0.06

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ² ☒ Yes / No	CT's met everyday? (see back) ☒ Yes / No	All Cl2 residual at entry point $\geq$ 0.2 mg/l? ☒ Yes / No	
All daily turbidity readings $\leq$ 5 NTU? ☒ Yes / No			
Notes: 		PRINTED NAME: Todd Evers	
		SIGNATURE:	
		PHONE #: (541) 497-3945	
		Cert: T-6149	
		DATE: 4/2/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:		Hillsboro-Cherry Grove		ID#: 41 00985-A		Month / Year: Mar-25		Disinfection Giardia Log Inactiv: 1	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	9:00	1.70	444	755	7.0	7.05	51.8	Yes	425
2	9:00	1.63	419	684	7.4	7.09	50.8	Yes	450
3	8:30	1.69	444	751	7.3	7.12	52.0	Yes	425
4	9:00	1.63	419	684	7.4	7.09	50.8	Yes	450
5	9:00	1.62	444	719	7.2	7.04	50.5	Yes	425
6	9:00	1.63	397	648	7.3	7.03	50.0	Yes	475
7	8:45	1.65	444	733	7.4	7.04	50.0	Yes	425
8	9:15	1.79	419	751	7.5	7.05	50.6	Yes	450
9	11:30	1.90	472	897	7.5	7.03	50.9	Yes	400
10	8:30	1.84	397	731	7.4	7.05	51.3	Yes	475
11	8:30	1.70	444	755	7.6	7.09	50.5	Yes	425
12	8:00	1.70	397	676	7.7	7.10	50.3	Yes	475
13	8:30	1.66	444	737	7.6	7.11	50.6	Yes	425
14	8:30	1.72	419	721	7.6	7.09	50.6	Yes	450
15	10:45	1.65	397	656	7.7	7.11	50.2	Yes	475
16	11:45	1.66	444	737	7.6	7.12	50.8	Yes	425
17	8:45	1.70	397	676	7.3	7.12	52.1	Yes	475
18	8:30	1.66	444	737	7.2	7.13	52.4	Yes	425
19	9:30	1.67	419	700	7.5	7.13	51.4	Yes	450
20	9:00	1.69	419	709	7.5	7.13	51.5	Yes	450
21	9:30	1.67	419	700	7.6	7.14	51.2	Yes	450
22	9:15	1.71	397	679	7.6	7.14	51.5	Yes	475
23	6:55	1.76	419	738	7.7	7.14	51.4	Yes	450
24	8:30	1.77	419	742	7.9	7.13	50.6	Yes	450
25	8:15	1.68	629	1057	8.1	7.13	49.4	Yes	300
26	10:45	1.57	1079	1693	8.8	7.10	46.1	Yes	175
27	8:30	1.56	755	1178	8.8	7.12	46.4	Yes	250
28	9:00	1.70	629	1070	9.1	7.12	46.2	Yes	300
29	9:30	1.76	629	1107	9.1	7.12	46.5	Yes	300
30	9:30	1.64	686	1126	9.1	7.13	46.0	Yes	275
31	9:30	1.76	839	1476	9.1	7.12	46.5	Yes	225

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.