

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove				ID#: 41 00985-A		Month/Year: Apr-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.06				0.06
2			0.06				0.06
3			0.06				0.06
4			0.06				0.06
5			0.06				0.06
6			0.06				0.06
7			0.06				0.06
8			0.06				0.06
9			0.06				0.06
10			0.08				0.08
11			0.08				0.08
12			0.09				0.09
13			0.08				0.08
14			0.09				0.09
15			0.09				0.09
16			0.09				0.09
17			0.09				0.09
18			0.08				0.08
19			0.08				0.08
20			0.08				0.08
21			0.08				0.08
22			0.08				0.08
23			0.08				0.08
24			0.08				0.08
25			0.08				0.08
26			0.08				0.08
27			0.08				0.08
28			0.07				0.07
29			0.07				0.07
30			0.08				0.08

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes / No	CT's met everyday? (see back)	☒ Yes / No
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes / No	All Cl2 residual at entry point $\geq$ 0.2 mg/l?	☒ Yes / No
Notes:		PRINTED NAME: Todd Evers SIGNATURE:  PHONE #: (541) 497-3945 Cert: T-6149 DATE: 5/5/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:		Hillsboro-Cherry Grove		ID#: 41 00985-A		Month / Year: Apr-25		Disinfection Giardia Log Inactiv:		1	
Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow		
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]		
1	6:45	1.79	755	1351	9.0	7.11	46.8	Yes	250		
2	9:00	1.91	839	1602	9.0	7.11	47.5	Yes	225		
3	9:00	1.93	686	1325	9.0	7.10	47.4	Yes	275		
4	9:30	1.91	1079	2060	9.0	7.10	47.3	Yes	175		
5	10:00	1.85	944	1746	9.2	7.11	46.5	Yes	200		
6	10:45	2.01	944	1897	9.3	7.08	46.6	Yes	200		
7	9:00	1.93	944	1821	9.5	7.10	45.8	Yes	200		
8	8:00	1.86	1079	2006	9.5	7.11	45.6	Yes	175		
9	8:30	1.70	1079	1834	9.4	7.12	45.3	Yes	175		
10	8:45	1.80	503	906	9.6	7.14	45.5	Yes	375		
11	9:15	1.77	503	891	9.7	7.13	44.9	Yes	375		
12	11:45	1.72	472	812	9.8	7.13	44.4	Yes	400		
13	12:00	1.75	444	777	9.9	7.13	44.2	Yes	425		
14	8:15	1.67	397	664	9.7	7.15	44.7	Yes	475		
15	8:00	1.80	377	679	9.9	7.13	44.5	Yes	500		
16	8:30	1.70	629	1070	10.0	7.13	43.7	Yes	300		
17	9:00	1.69	419	709	10.3	7.14	42.9	Yes	450		
18	9:30	1.67	472	788	10.6	7.14	42.0	Yes	400		
19	9:30	1.68	419	705	10.9	7.14	41.2	Yes	450		
20	9:30	1.73	444	768	11.0	7.14	41.2	Yes	425		
21	8:30	1.67	472	788	11.0	7.14	40.9	Yes	400		
22	7:30	1.65	472	779	10.8	7.15	41.5	Yes	400		
23	7:00	1.81	472	854	10.7	7.16	42.7	Yes	400		
24	7:00	1.62	472	764	10.9	7.16	41.2	Yes	400		
25	8:15	1.87	472	882	11.1	7.16	41.9	Yes	400		
26	10:30	1.89	444	839	12.1	7.13	38.9	Yes	425		
27	10:00	1.79	503	901	12.0	7.13	38.7	Yes	375		
28	8:15	1.76	539	949	11.5	7.15	40.1	Yes	350		
29	8:30	1.91	397	759	11.4	7.15	41.1	Yes	475		
30	7:30	1.76	503	886	11.4	7.18	40.8	Yes	375		

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.