

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove				ID#: 41 00985-A		Month/Year: May-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.08				0.08
2			0.06				0.06
3			0.07				0.07
4			0.07				0.07
5			0.06				0.06
6			0.06				0.06
7			0.06				0.06
8			0.06				0.06
9			0.06				0.06
10			0.06				0.06
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.06				0.06
15			0.06				0.06
16			0.06				0.06
17			0.07				0.07
18			0.06				0.06
19			0.06				0.06
20			0.06				0.06
21			0.06				0.06
22			0.07				0.07
23			0.07				0.07
24			0.07				0.07
25			0.07				0.07
26			0.07				0.07
27			0.07				0.07
28			0.07				0.07
29			0.07				0.07
30			0.08				0.08
31			0.08				0.08

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes / No	CT's met everyday? (see back)	☒ Yes / No
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes / No	All Cl2 residual at entry point $\geq$ 0.2 mg/l?	☒ Yes / No

Notes:	PRINTED NAME: Todd Evers	Cert: T-6149
	SIGNATURE:	DATE:
	PHONE #: (541) 497-3945	6/3/2025

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove **ID#: 41 00985-A** **Month / Year:** May-25 **Disinfection Giardia Log Inactiv:** 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	7:45	1.75	539	944	11.6	7.17	40.1	Yes	350
2	9:00	1.85	472	873	12.0	7.15	39.2	Yes	400
3	10:30	1.70	419	713	12.3	7.15	37.8	Yes	450
4	10:30	1.71	444	759	12.4	7.16	37.8	Yes	425
5	8:30	1.76	397	699	12.4	7.18	38.2	Yes	475
6	7:30	1.66	444	737	12.5	7.17	36.9	Yes	425
7	8:45	1.73	397	687	12.7	7.17	36.7	Yes	475
8	8:45	1.87	397	743	12.6	7.16	37.4	Yes	475
9	9:00	2.07	419	868	12.6	7.17	38.4	Yes	450
10	12:00	1.90	444	844	13.1	7.16	36.3	Yes	425
11	14:00	1.93	444	857	13.0	7.16	36.7	Yes	425
12	7:30	1.79	377	676	12.7	7.19	37.3	Yes	500
13	9:00	1.72	397	683	12.5	7.19	37.5	Yes	475
14	7:30	1.88	444	835	12.4	7.19	38.9	Yes	425
15	9:00	1.71	377	646	12.4	7.20	38.3	Yes	500
16	8:45	1.71	377	646	12.3	7.20	38.5	Yes	500
17	9:45	1.67	377	630	12.3	7.22	38.6	Yes	500
18	10:00	1.68	397	668	12.1	7.21	39.1	Yes	475
19	10:00	1.69	377	638	12.2	7.21	38.8	Yes	500
20	8:30	1.76	397	699	12.0	7.21	39.7	Yes	475
21	9:30	1.69	377	638	12.2	7.21	38.8	Yes	500
22	11:15	1.72	377	649	12.4	7.21	38.5	Yes	500
23	8:30	1.77	377	668	12.4	7.21	38.7	Yes	500
24	9:30	1.79	360	644	12.5	7.20	37.9	Yes	525
25	9:00	1.78	377	672	12.6	7.21	37.8	Yes	500
26	9:00	1.79	419	751	13.0	7.21	36.8	Yes	450
27	8:30	1.77	315	557	12.9	7.22	37.1	Yes	600
28	8:30	1.69	397	672	13.4	7.22	35.6	Yes	475
29	8:00	1.78	360	640	13.6	7.22	35.5	Yes	525
30	10:00	1.83	377	691	14.0	7.21	34.6	Yes	500
31	10:30	1.68	360	604	14.4	7.21	33.1	Yes	525

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013