

System Name: Hillsboro-Cherry Grove			ID#: 41 00985-A			Month/Year: Jun-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.08				0.08
2			0.08				0.08
3			0.08				0.08
4			0.09				0.09
5			0.08				0.08
6			0.09				0.09
7			0.08				0.08
8			0.09				0.09
9			0.09				0.09
10			0.09				0.09
11			0.09				0.09
12			0.09				0.09
13			0.09				0.09
14			0.09				0.09
15			0.09				0.09
16			0.09				0.09
17			0.09				0.09
18			0.09				0.09
19			0.09				0.09
20			0.09				0.09
21			0.09				0.09
22			0.09				0.09
23			0.09				0.09
24			0.09				0.09
25			0.09				0.09
26			0.09				0.09
27			0.09				0.09
28			0.09				0.09
29			0.09				0.09
30			0.10				0.10

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	☒ Yes / No	CT's met everyday? (see back)	☒ Yes / No
All daily turbidity readings ≤ 5 NTU?	☒ Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l?	☒ Yes / No
Notes:		PRINTED NAME: Todd Evers SIGNATURE: PHONE #: (541) 497-3945 Cert: T-6149 DATE: 7/2/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove
ID#: 41 00985-A
Month / Year: Jun-25
Disinfection Giardia Log Inactiv: 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:45	1.67	343	573	14.3	7.21	33.3	Yes	550
2	8:30	1.74	360	626	14.1	7.21	34.0	Yes	525
3	8:30	1.83	377	691	14.2	7.22	34.3	Yes	500
4	8:30	1.72	343	590	14.5	7.21	33.0	Yes	550
5	11:15	1.84	360	662	14.6	7.20	33.2	Yes	525
6	9:00	1.77	315	557	14.3	7.21	33.7	Yes	600
7	7:30	1.69	343	580	14.5	7.20	32.8	Yes	550
8	7:15	1.71	377	646	14.6	7.16	32.2	Yes	500
9	9:00	1.73	377	653	15.2	7.15	30.9	Yes	500
10	9:00	1.70	360	611	15.3	7.15	30.6	Yes	525
11	9:00	1.75	343	601	15.6	7.15	30.1	Yes	550
12	8:30	1.66	302	501	15.6	7.16	29.9	Yes	625
13	8:30	1.68	302	507	15.5	7.16	30.2	Yes	625
14	7:45	1.70	315	535	15.0	7.11	30.7	Yes	600
15	10:00	1.68	315	528	14.7	6.96	29.6	Yes	600
16	11:00	1.75	328	574	15.0	6.99	29.6	Yes	575
17	8:15	1.70	315	535	14.8	7.13	31.4	Yes	600
18	9:00	1.79	328	588	15.0	7.12	31.2	Yes	575
19	8:45	1.79	328	588	15.0	6.85	28.2	Yes	575
20	9:15	1.83	328	601	15.0	7.15	31.7	Yes	575
21	8:30	1.80	315	566	14.7	6.85	28.8	Yes	600
22	8:45	1.80	328	591	14.3	6.86	29.7	Yes	575
23	8:30	1.80	328	591	14.0	7.11	33.2	Yes	575
24	11:00	1.81	302	547	14.6	7.06	31.4	Yes	625
25	8:30	1.79	328	588	14.4	7.15	32.8	Yes	575
26	8:00	1.70	328	558	14.4	7.16	32.6	Yes	575
27	9:30	1.79	343	614	14.3	7.15	33.0	Yes	550
28	9:00	1.77	315	557	14.2	7.15	33.2	Yes	600
29	10:00	1.77	315	557	14.5	7.14	32.4	Yes	600
30	9:00	1.69	315	532	14.8	7.15	31.6	Yes	600

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013