


OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove			ID#: 41 00985-A		Month/Year: Jul-25		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.10				0.10
2			0.10				0.10
3			0.10				0.10
4			0.11				0.11
5			0.09				0.09
6			0.09				0.09
7			0.09				0.09
8			0.09				0.09
9			0.09				0.09
10			0.09				0.09
11			0.09				0.09
12			0.09				0.09
13			0.10				0.10
14			0.10				0.10
15			0.09				0.09
16			0.10				0.10
17			0.10				0.10
18			0.09				0.09
19			0.09				0.09
20			0.10				0.10
21			0.09				0.09
22			0.10				0.10
23			0.10				0.10
24			0.10				0.10
25			0.10				0.10
26			0.10				0.10
27			0.09				0.09
28			0.09				0.09
29			0.09				0.09
30			0.09				0.09
31			0.09				0.09

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes No	CT's met everyday? (see back)	☒ Yes No
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes No	All Cl2 residual at entry point $\geq$ 0.2 mg/l?	☒ Yes No
Notes:		PRINTED NAME: Todd Evers SIGNATURE:  PHONE #: (541) 497-3945	
		Cert: T-6149 DATE: 8/4/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove

ID#: 41 00985-A

**Month /
Year:** Jul-25

**Disinfection
Giardia Log
Inactiv:** 1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	9:45	1.73	315	544	15.3	7.14	30.6	Yes	600
2	9:15	1.67	343	573	15.4	7.14	30.2	Yes	550
3	10:00	1.47	302	444	15.5	7.15	29.4	Yes	625
4	5:30	1.68	315	528	15.4	7.15	30.3	Yes	600
5	13:00	1.87	328	614	15.8	7.11	29.7	Yes	575
6	7:00	1.79	343	614	15.2	7.14	31.0	Yes	550
7	8:30	1.88	328	617	15.6	7.14	30.5	Yes	575
8	9:30	1.90	328	624	16.0	7.12	29.5	Yes	575
9	9:00	1.86	328	611	16.0	7.13	29.5	Yes	575
10	11:00	1.80	328	591	16.2	7.12	28.8	Yes	575
11	8:30	1.63	270	440	15.9	7.16	29.2	Yes	700
12	9:10	1.71	270	461	16.2	7.15	28.8	Yes	700
13	7:15	1.79	315	563	16.2	7.14	29.0	Yes	600
14	8:30	1.77	328	581	16.6	7.14	28.2	Yes	575
15	7:45	1.67	328	548	16.4	7.16	28.4	Yes	575
16	8:30	1.70	302	513	16.6	7.16	28.1	Yes	625
17	8:30	1.90	280	531	16.7	7.14	28.4	Yes	675
18	9:00	1.90	302	574	16.8	7.15	28.3	Yes	625
19	8:45	1.93	290	560	16.6	7.14	28.7	Yes	650
20	8:30	1.72	315	541	16.4	7.17	28.7	Yes	600
21	8:30	1.75	328	574	16.0	7.17	29.6	Yes	575
22	8:15	1.66	290	482	15.3	7.17	30.7	Yes	650
23	8:00	1.73	302	522	15.2	7.15	30.9	Yes	625
24	8:00	1.46	302	441	15.2	7.18	30.3	Yes	625
25	10:00	1.59	315	500	15.6	7.16	29.7	Yes	600
26	9:00	1.74	315	547	15.6	7.15	30.1	Yes	600
27	11:00	1.70	315	535	15.4	7.16	30.5	Yes	600
28	10:00	1.82	315	573	15.0	7.16	31.7	Yes	600
29	7:15	1.68	302	507	14.8	7.17	31.8	Yes	625
30	10:30	1.57	302	474	15.3	7.18	30.5	Yes	625
31	8:30	1.72	302	519	14.8	7.15	31.7	Yes	625

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013