

OHA - Drinking Water Program - Turbidity					County: Washington		
System Name: Hillsboro-Cherry Grove				ID#: 41 00985-A		Month/Year: Aug-25	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.09				0.09
2			0.09				0.09
3			0.09				0.09
4			0.09				0.09
5			0.10				0.10
6			0.08				0.08
7			0.08				0.08
8			0.08				0.08
9			0.08				0.08
10			0.08				0.08
11			0.08				0.08
12			0.09				0.09
13			0.09				0.09
14			0.09				0.09
15			0.09				0.09
16			0.09				0.09
17			0.09				0.09
18			0.09				0.09
19			0.08				0.08
20			0.08				0.08
21			0.08				0.08
22			0.08				0.08
23			0.08				0.08
24			0.08				0.08
25			0.08				0.08
26			0.08				0.08
27			0.08				0.08
28			0.08				0.08
29			0.08				0.08
30			0.07				0.07
31			0.07				0.07

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? ²	☒ Yes / No	CT's met everyday? (see back)	☒ Yes / No
All daily turbidity readings $\leq$ 5 NTU?	☒ Yes / No	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?	☒ Yes / No
Notes:		PRINTED NAME: Todd Evers	
		SIGNATURE:	
		PHONE #: (541) 497-3945	
		Cert: T-6149	
		DATE: 9/3/2025	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Hillsboro-Cherry Grove

ID#: 41 00985-A

**Month /
Year:**

Aug-25

**Disinfection
Giardia Log
Inactiv:**

1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	10:30	1.78	328	584	15.3	7.15	30.9	Yes	575
2	9:15	1.82	360	654	16.0	7.21	30.2	Yes	525
3	10:15	1.92	377	725	16.0	7.21	30.6	Yes	500
4	10:15	1.71	377	646	15.7	7.16	29.9	Yes	500
5	9:00	1.82	419	763	14.8	7.15	32.0	Yes	450
6	11:00	1.78	397	707	15.0	7.15	31.5	Yes	475
7	9:00	1.81	360	651	14.5	7.16	32.8	Yes	525
8	9:00	1.72	360	618	13.7	7.21	34.9	Yes	525
9	9:15	1.55	315	488	14.5	7.22	32.5	Yes	600
10	9:30	1.61	377	608	14.9	7.22	31.9	Yes	500
11	9:30	1.78	397	707	15.2	7.18	31.4	Yes	475
12	7:00	1.82	503	916	15.4	7.21	31.5	Yes	375
13	10:30	1.72	360	618	15.9	7.19	29.9	Yes	525
14	8:30	1.66	472	783	15.7	7.20	30.2	Yes	400
15	8:30	1.72	539	928	15.7	7.20	30.4	Yes	350
16	8:45	1.62	581	941	15.7	7.21	30.2	Yes	325
17	8:45	1.67	755	1261	15.6	7.21	30.5	Yes	250
18	8:30	1.55	755	1170	15.6	7.20	30.0	Yes	250
19	9:15	1.61	755	1216	15.5	7.21	30.5	Yes	250
20	8:00	1.64	581	952	15.5	7.21	30.6	Yes	325
21	8:30	1.64	629	1032	15.5	7.21	30.6	Yes	300
22	8:30	1.54	539	830	15.8	7.22	29.8	Yes	350
23	8:00	1.50	503	755	16.0	7.24	29.5	Yes	375
24	7:00	1.73	629	1088	16.1	7.21	29.7	Yes	300
25	8:30	1.75	539	944	16.2	7.21	29.6	Yes	350
26	7:15	1.41	581	819	16.5	7.25	28.3	Yes	325
27	9:15	1.60	472	755	16.6	7.23	28.5	Yes	400
28	9:15	1.62	444	719	16.5	7.24	28.9	Yes	425
29	11:30	1.65	503	830	16.8	7.22	28.2	Yes	375
30	12:15	1.76	539	949	17.1	7.21	27.9	Yes	350
31	9:00	1.69	472	797	16.9	7.22	28.2	Yes	400

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised September 2013